

Part III Form 2
Section 11. ANNUAL REPORT.

Drinking-Water System Number:	220002716
Drinking-Water System Name:	Kincardine Water Treatment Plant
Drinking-Water System Owner:	Municipality of Kincardine
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	Year 2009

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> Municipal Administration Centre 1475 Concession 5, RR #5 Kincardine, Ontario N2Z 2X6 </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
--	--

List Drinking-Water Systems, which receive all of their drinking water from your system:

Huronville Subdivision, WW #260046709

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [X] No [] NA []

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____ Notification by mail _____

Describe your Drinking-Water System

The Kincardine Water System consists of a surface water treatment plant that receives water from Lake Huron. The water treatment plant provides conventional filtration and consists of 2 Actiflo clarifiers, 4 filters, chlorination system and underground reservoir. The intake capacity is 18,750 m³/d. The distribution system serves the town of Kincardine and residents north of the town via a pipeline, plus the Huronville subdivision, with a total of approximately 3300 connections.

List all water treatment chemicals used over this reporting period

Chlorine Gas
Clarion A5
Magnafloc (Polymer)

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Describe

Residential Water Meter Replacement Program - \$16,763.41
Parts Storage Shed - \$11,855.53
Backwash pump, Engineering costs - \$2,526.51
Watermain Replacement - \$69,734.44
Chlorine system parts and maintenance - \$539.51
Analyzer parts and maintenance - \$3,265.75
Filter #4 parts - \$1,239.00
Generator maintenance - \$757.78
Air compressor maintenance - \$688.52
Dehumidifier - \$262.38

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
April 8/09 AWQI #87513	Total Coliform	169	cfu/100 mL	Resample	April 8/09

Microbiological testing done under Schedule 10 during this reporting period

	Number of Samples	Range of E. coli Results (#-#)	Range of Total Coliform Results (#-#)	Number of HPC Samples	Range of HPC Results (#-#)
Raw	52	0 – 13,200	0 – 42	52	0 – 880
Treated	52	0 – 0	0 – 169	52	0 – 180
Distribution	260	0 – 0	0 – 0	260	0 – 41

Operational testing done under Schedule 7 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (#-#)
Turbidity	8760	0.07 – 0.63
Chlorine	8760	0.8 – 2.06
Distribution System Free Chlorine Residual	365	0.4 – 1.16

NOTE: For continuous monitors, 8760 is used as the number of samples.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

Date C of A	Parameter	Date Sampled	Result	Unit of Measure
--none--				

Summary of Inorganic parameters tested during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	Oct 5/09	0.20	ug/L	No
Arsenic	Oct 5/09	0.6	ug/L	No
Barium	Oct 5/09	15.6	ug/L	No
Boron	Oct 5/09	13.3	ug/L	No
Cadmium	Oct 5/09	< 0.003	ug/L	No
Chromium	Oct 5/09	< 0.5	ug/L	No
Mercury	Oct 5/09	< 0.02	ug/L	No
Selenium	Oct 5/09	< 1	ug/L	No
Sodium	Feb 3/09	4.2	mg/L	No
Uranium	Oct 5/09	0.019	ug/L	No
Fluoride	Sept 29/08	0.08	mg/L	No
Nitrite	Jan 5/09 April 6/09 July 6/09 Oct 5/09	<0.005 <0.005 <0.005 <0.005	mg/L	No
Nitrate	Jan 5/09 April 6/09 July 6/09 Oct 5/09	0.552 0.528 0.297 0.304	mg/L	No

Summary of lead testing under Schedule 15.1 during this reporting period

Location Type	Number of Samples	Range of Lead Results (ug/L)	Number of Exceedances
Plumbing	--none--		
Distribution	--none--		

Summary of Organic parameters sampled during this reporting period or most recent

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Oct 5/09	< 0.11	ug/L	No
Aldicarb	Oct 5/09	< 0.3	ug/L	No
Aldrin + Dieldrin	Oct 5/09	< 0.067	ug/L	No
Atrazine + N-dealkylated metabolites	Oct 5/09	< 0.12	ug/L	No
Azinphos-methyl	Oct 5/09	< 0.21	ug/L	No
Bendiocarb	Oct 5/09	< 0.13	ug/L	No
Benzene	Oct 5/09	< 0.32	ug/L	No
Benzo(a)pyrene	Oct 5/09	< 0.004	ug/L	No
Bromoxynil	Oct 5/09	< 0.33	ug/L	No
Carbaryl	Oct 5/09	< 0.16	ug/L	No
Carbofuran	Oct 5/09	< 0.37	ug/L	No
Carbon Tetrachloride	Oct 5/09	< 0.16	ug/L	No
Chlordane (Total)	Oct 5/09	< 0.11	ug/L	No
Chlorpyrifos	Oct 5/09	< 0.18	ug/L	No
Cyanazine	Oct 5/09	< 0.18	ug/L	No
Diazinon	Oct 5/09	< 0.081	ug/L	No
Dicamba	Oct 5/09	< 0.20	ug/L	No
1,2-Dichlorobenzene	Oct 5/09	< 0.41	ug/L	No
1,4-Dichlorobenzene	Oct 5/09	< 0.36	ug/L	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	Oct 5/09	< 0.14	ug/L	No
1,2-Dichloroethane	Oct 5/09	< 0.35	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	Oct 5/09	< 0.33	ug/L	No
Dichloromethane	Oct 5/09	< 0.35	ug/L	No
2-4 Dichlorophenol	Oct 5/09	< 0.15	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	Oct 5/09	< 0.19	ug/L	No
Diclofop-methyl	Oct 5/09	< 0.40	ug/L	No
Dimethoate	Oct 5/09	< 0.12	ug/L	No
Dinoseb	Oct 5/09	< 0.36	ug/L	No
Diquat	Oct 5/09	< 1	ug/L	No
Diuron	Oct 5/09	< 0.087	ug/L	No
Glyphosate	Oct 5/09	< 6	ug/L	No
Heptachlor + Heptachlor Epoxide	Oct 5/09	< 0.11	ug/L	No
Linadane (Total)	Oct 5/09	< 0.056	ug/L	No
Malathion	Oct 5/09	< 0.091	ug/L	No
Methoxychlor	Oct 5/09	< 0.14	ug/L	No
Metolachlor	Oct 5/09	< 0.092	ug/L	No
Metribuzin	Oct 5/09	< 0.12	ug/L	No
Monochlorobenzene	Oct 5/09	< 0.30	ug/L	No
Paraquat	Oct 5/09	< 1	ug/L	No
Parathion	Oct 5/09	< 0.18	ug/L	No
Pentachlorophenol	Oct 5/09	< 0.15	ug/L	No

Drinking-Water Systems Regulation O. Reg. 170/03

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Phorate	Oct 5/09	< 0.11	ug/L	No
Picloram	Oct 5/09	< 0.25	ug/L	No
Polychlorinated Biphenyls (PCB)	Oct 5/09	< 0.04	ug/L	No
Prometryne	Oct 5/09	< 0.23	ug/L	No
Simazine	Oct 5/09	< 0.15	ug/L	No
THM (distribution) (2009 annual average)	Jan 5/09 April 6/09 July 6/09 Oct 5/09	21.2	ug/L	No
Temephos	Oct 5/09	< 0.31	ug/L	No
Terbufos	Oct 5/09	< 0.12	ug/L	No
Tetrachloroethylene	Oct 5/09	< 0.35	ug/L	No
2,3,4,6-Tetrachlorophenol	Oct 5/09	< 0.14	ug/L	No
Triallate	Oct 5/09	< 0.10	ug/L	No
Trichloroethylene	Oct 5/09	< 0.43	ug/L	No
2,4,6-Trichlorophenol	Oct 5/09	< 0.25	ug/L	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	Oct 5/09	< 0.22	ug/L	No
Trifluralin	Oct 5/09	< 0.12	ug/L	No
Vinyl Chloride	Oct 5/09	< 0.17	ug/L	No

Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
--none--			