

2011 Energy Consumption and Greenhouse Gas Emissions Report  
ONTARIO REGULATION 397/11

Operation Name	Area of the Indoor Space in which	Average # Hours Per Week	Annual Flow (Mega Litres)	Energy Type and Amount Purchased and Consumed in Natural Units			Total (These columns will calculate when file is Saved)		
				Electricity	Fuel Oil 1 & 2	Propane	GHG Emissions (Kg)	Energy Intensity (ekWh/sqft)	(ekWh/Mega Litres)
<i>Gatsby Administration Centre</i>	361,280.00 Sq	40		##### kWh					
OPP Office	500.00 Sq	10		760.50 kWh			60.84003	1.52100	
Point Clark Lighthouse	1000.00 Sq	5		1,976.55 kWh			158.12364	1.97655	
Library	2000.00 Sq	30		2,272.00 kWh			181.76000	1.13600	
Old Lucknow Fire Hall (storage)	1500.00 Sq	10		5,206.41 kWh			416.51250	3.47094	
Storage Shed	500.00 Sq	10		5,421.40 kWh			433.71231	10.84281	
Lucknow shed	3000.00 Sq	40		8,262.44 kWh			660.99535	2.75415	
Ripley Library	1000.00 Sq	30		10,642.40 kWh			851.39200	10.64240	
Lucknowpump House # 4	375.00 Sq	80	27.99700	11,187.64 kWh			895.01110	29.83370	399.60134
Holyrood Shed	5000.00 Sq	40		13,108.90 kWh			1,048.71175	2.62178	
Lucknow Fire Hall	5000.00 Sq	10		15,157.10 kWh			1,212.56800	3.03142	
Whitechurch Pump House	375.00 Sq	80	15.98100	21,201.62 kWh			1,696.12941	56.53765	1,326.67653
Ripley Shed	10000.00 Sq	40		23,760.83 kWh			1,900.86600	2.37608	
Ross Street Pump House	500.00 Sq	80		24,629.78 kWh			1,970.38250	49.25956	
Library 2	2000.00 Sq	30		25,243.90 kWh			2,019.51200	12.62195	
Ripley Fire Hall	3000.00 Sq	10		25,658.10 kWh			2,052.64800	8.55270	
Point Clark CC	3500.00 Sq	30		27,347.18 kWh			2,187.77455	7.81348	
Blairs Pump House	375.00 Sq	80	35.80700	27,663.99 kWh			2,213.11938	73.77065	772.58615
Ripley WW treatment plant	375.00 Sq	80	113.43500	31,425.73 kWh			2,514.05821	83.80194	277.03731
Municipal Office	4000.00 Sq	40		50,948.34 kWh			4,075.86682	12.73708	
Ripley Sewage pumping station	375.00 Sq	80	113.43500	51,171.83 kWh			4,093.74658	136.45822	451.11149
lucknowpump House # 5	375.00 Sq	80	178.25800	60,099.01 kWh			4,807.92073	160.26402	337.14621
Huronville Pump House	375.00 Sq	80	123.15100	107,198.08 kWh			8,575.84623	285.86154	870.46047
Murdoch Glen Pump House	375.00 Sq	80	129.52300	114,352.36 kWh			9,148.18845	304.93962	882.87297
Point Clark Pump House	375.00 Sq	80	255.34900	122,391.90 kWh			9,791.35224	326.37841	479.31225
Ripley Pump House	375.00 Sq	80	89.36600	129,253.65 kWh			10,340.29200	344.67640	1,446.34033
Lucknow Sewage pumping station	375.00 Sq	80	225.59100	208,713.73 kWh			16,697.09844	556.56995	925.18642
Lucknow WW treatment plant	375.00 Sq	80	225.59100	282,607.74 kWh			22,608.61922	753.62064	1,252.74386
Ripley Huron CC	27000.00 Sq	80		369,644.75 kWh			29,571.58033	13.69055	
Point Clark Lighthouse	1000.00 Sq	5			914.40 Litre		2,493.94005	9.85520	
Whitechurch Hall	1000.00 Sq	5			2,528.10 Litre		6,895.15511	27.24730	
Ripley Huron CC Olympia	10.00 Sq	5				1,697.00 Litre	2,620.14085	1,193.08518	
lucknow Townhall	2000.00 Sq	20				4,404.11 Litre	6,799.87827	15.48168	

2011 Energy Consumption and Greenhouse Gas Emissions Report  
 ONTARIO REGULATION 397/11

Operation Name	Indoor Space in which	# Hours Per Week	(Mega Litres)	Electricity	Fuel Oil 1 & 2	Propane	GHG Emissions (Kg)	Energy Intensity (ekWh/sqft)	(ekWh/Mega Litres)
Holyrood shed	6000.00 Sq	40				6,170.30 Litre	9,526.84041	7.23010	
Point clark CC	3500.00 Sq	30				8,352.10 Litre	12,895.50877	16.77711	
Ripley Fire Hall	3000.00 Sq	10				8,626.50 Litre	13,319.17798	20.21636	
Municipal Office	4000.00 Sq	40				11,740.90 Litre	18,127.76175	20.63626	
Ripley Huron CC	27000.00 Sq	80				19,664.60 Litre	30,361.82777	5.12048	