

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

20-February-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 17 February 2026
 LR Report: CA20706-FEB26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				18-Feb-26	18-Feb-26	18-Feb-26
2: Analysis Start Time				16:55	16:55	16:30
3: Analysis Completed Date				20-Feb-26	20-Feb-26	20-Feb-26
4: Analysis Completed Time				14:53	14:53	14:53
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	17-Feb-26 08:48	11.9	1.97	0	0	< 10
7: DW DW-East Whitechurch DW-SS	17-Feb-26 08:32	11.9	1.91	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

13-February-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 10 February 2026
 LR Report: CA20506-FEB26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				11-Feb-26	11-Feb-26	11-Feb-26
2: Analysis Start Time				12:20	12:20	11:45
3: Analysis Completed Date				13-Feb-26	13-Feb-26	13-Feb-26
4: Analysis Completed Time				11:41	11:41	11:41
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	10-Feb-26 08:33	1.9	1.79	0	0	< 10
7: DW DW-East Whitechurch DW-SS	10-Feb-26 08:24	1.9	1.49	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

06-February-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 03 February 2026
LR Report: CA20208-FEB26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date			04-Feb-26	04-Feb-26
2: Analysis Start Time			16:15	16:15
3: Analysis Completed Date			06-Feb-26	06-Feb-26
4: Analysis Completed Time			13:40	13:40
5: MAC		---	0	0
6: RW RW1-Whitechurch RW-Well 1	03-Feb-26 09:20	3.9	0	0
7: RW RW2-Whitechurch RW-Well 2	03-Feb-26 09:02	3.9	0	0

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

06-February-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 03 February 2026
LR Report: CA20206-FEB26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Feb-26	04-Feb-26	04-Feb-26
2: Analysis Start Time				16:15	16:15	15:30
3: Analysis Completed Date				06-Feb-26	06-Feb-26	06-Feb-26
4: Analysis Completed Time				13:38	13:38	13:38
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	03-Feb-26 09:07	3.9	1.82	0	0	< 10
7: DW DW-East Whitechurch DW-SS	03-Feb-26 08:48	3.9	1.50	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

30-January-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 27 January 2026
LR Report: CA21149-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	28-Jan-26	28-Jan-26	28-Jan-26
2: Analysis Start Time		---	---	12:35	12:35	12:10
3: Analysis Completed Date		---	---	30-Jan-26	30-Jan-26	30-Jan-26
4: Analysis Completed Time		---	---	11:34	11:34	11:34
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	27-Jan-26 09:32	1.8	1.95	0	0	< 10
7: DW DW-East Whitechurch DW-SS	27-Jan-26 09:08	1.8	1.48	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

23-January-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 20 January 2026
LR Report: CA20832-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	21-Jan-26	21-Jan-26	21-Jan-26
2: Analysis Start Time		---	---	13:55	13:55	13:00
3: Analysis Completed Date		---	---	23-Jan-26	23-Jan-26	23-Jan-26
4: Analysis Completed Time		---	---	11:33	11:33	11:33
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	20-Jan-26 09:21	2.0	1.82	0	0	10
7: DW DW-East Whitechurch DW-SS	20-Jan-26 08:57	2.0	1.44	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

19-January-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 13 January 2026
 LR Report: CA20542-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	14-Jan-26	14-Jan-26	14-Jan-26
2: Analysis Start Time		---	---	15:40	15:40	15:00
3: Analysis Completed Date		---	---	16-Jan-26	16-Jan-26	16-Jan-26
4: Analysis Completed Time		---	---	15:53	15:53	15:53
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	13-Jan-26 08:48	3.1	1.48	0	0	< 10
7: DW DW-East Whitechurch DW-SS	13-Jan-26 08:27	3.1	1.37	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


 Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-January-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 06 January 2026
 LR Report: CA20224-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-Jan-26	07-Jan-26	07-Jan-26
2: Analysis Start Time		---	---	14:45	14:45	14:25
3: Analysis Completed Date		---	---	09-Jan-26	09-Jan-26	09-Jan-26
4: Analysis Completed Time		---	---	12:40	12:40	12:40
5: MAC		---	---	0	0	---
6: RW RW1-Whitechurch RW-Well 1	06-Jan-26 09:21	3.6	---	0	0	---
7: RW RW2-Whitechurch RW-Well 2	06-Jan-26 09:24	3.6	---	0	0	---
8: TW TW-Whitechurch TW	06-Jan-26 09:18	3.6	1.73	0	0	< 10
9: DW DW-East Whitechurch DW-SS	06-Jan-26 08:57	3.6	1.50	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety