



Works #: 220008863

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

03-July-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 29 June 2026
LR Report: CA21779-JUN26

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	30-Jun-26	30-Jun-26	30-Jun-26
2: Analysis Start Time		---	---	15:00	15:00	14:25
3: Analysis Completed Date		---	---	02-Jul-26	02-Jul-26	02-Jul-26
4: Analysis Completed Time		---	---	14:39	14:39	14:39
5: MAC		---	---	0	0	---
6: TW TW-Whitechurch TW	29-Jun-26 08:10	13.9	1.58	0	0	10
7: DW DW-East Whitechurch DW-SS	29-Jun-26 07:56	13.9	1.28	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety