

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-November-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 14 November 2023
LR Report: CA20618-NOV23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	15-Nov-23	15-Nov-23	15-Nov-23
2: Analysis Start Time		---	---	---	09:45	09:45	09:15
3: Analysis Completed Date		---	---	---	17-Nov-23	17-Nov-23	17-Nov-23
4: Analysis Completed Time		---	---	---	09:52	09:52	09:52
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	13-Nov-23 14:55	8.4	---	0.29	0	0	---
7: TW Huronville South Treated Water	13-Nov-23 14:55	8.4	1.80	0.33	0	0	< 10
8: RW Murdock Glen Raw Water	13-Nov-23 14:15	8.4	---	0.16	0	0	---
9: TW Murdock Glen Treated Water	13-Nov-23 14:15	8.4	1.99	0.21	0	0	< 10
10: RW Blairs Grove Raw Water	13-Nov-23 11:45	8.4	---	0.35	0	0	---
11: TW Blairs Grove Treated Water	13-Nov-23 11:45	8.4	1.29	0.44	0	0	< 10
12: RW Point Clark Raw Water #2	13-Nov-23 10:45	8.4	---	0.19	0	0	---
13: RW Point Clark Raw Water #3	13-Nov-23 10:45	8.4	---	0.17	0	0	---
14: TW Point Clark Treated Water	13-Nov-23 10:45	8.4	1.83	0.27	0	0	< 10
15: DW DW Tanglewood DE	13-Nov-23 11:05	8.4	1.47	---	0	0	20
16: DW DW Bruce Beach	13-Nov-23 12:10	8.4	1.74	---	0	0	< 10
17: DW Inverlyn CH	13-Nov-23 14:50	8.4	1.78	---	0	0	< 10
18: DW Amberley Beach SS	13-Nov-23 11:15	8.4	1.52	---	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20618-NOV23

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

10-November-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 07 November 2023

LR Report: CA20349-NOV23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583

Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Nov-23	08-Nov-23	08-Nov-23
2: Analysis Start Time		---	---	14:10	14:10	13:50
3: Analysis Completed Date		---	---	10-Nov-23	10-Nov-23	10-Nov-23
4: Analysis Completed Time		---	---	12:29	12:29	12:29
5: MAC		---	---	0	0	---
6: RW Murdock Glen Raw Water	07-Nov-23 12:00	10.6	---	0	0	---
7: TW Murdock Glen Treated Water	07-Nov-23 12:05	10.6	1.82	0	0	< 10
8: RW Blairs Grove Raw Water	07-Nov-23 11:35	10.6	---	0	0	---
9: TW Blairs Grove Treated Water	07-Nov-23 11:30	10.6	1.16	0	0	< 10
10: RW Point Clark Raw Water #2	07-Nov-23 11:05	10.6	---	0	0	---
11: RW Point Clark Raw Water #3	07-Nov-23 11:10	10.6	---	0	0	---
12: TW Point Clark Treated Water	07-Nov-23 11:15	10.6	1.55	0	0	< 10
13: DW DW Amberly BCH SS	07-Nov-23 10:40	10.6	1.23	0	0	< 10
14: DW DW PCCC	07-Nov-23 11:25	10.6	1.04	0	0	< 10
15: DW Bruce BCH S.S.	07-Nov-23 11:45	10.6	1.51	0	0	NDOGHPC
16: DW Inverlynn CLB HSE	07-Nov-23 12:25	10.6	1.13	0	0	< 10

MAC - Maximum Acceptable Concentration

NDOGHPC - No Data: Overgrown with HPC

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Crista Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20349-NOV23

Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

03-November-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 31 October 2023
LR Report: CA20004-NOV23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	01-Nov-23	01-Nov-23	01-Nov-23
2: Analysis Start Time		---	---	09:45	09:45	09:10
3: Analysis Completed Date		---	---	03-Nov-23	03-Nov-23	03-Nov-23
4: Analysis Completed Time		---	---	11:35	11:35	11:35
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	30-Oct-23 11:10	7.2	---	0	0	---
7: TW Huronville South Treated Water	30-Oct-23 11:10	7.2	1.26	0	0	< 10
8: RW Murdock Glen Raw Water	30-Oct-23 11:40	7.2	---	0	0	---
9: TW Murdock Glen Treated Water	30-Oct-23 11:40	7.2	1.85	0	0	< 10
10: RW Blairs Grove Raw Water	30-Oct-23 12:50	7.2	---	0	0	---
11: TW Blairs Grove Treated Water	30-Oct-23 12:50	7.2	1.09	0	0	< 10
12: RW Point Clark Raw Water #2	30-Oct-23 13:55	7.2	---	0	0	---
13: RW Point Clark Raw Water #3	30-Oct-23 13:55	7.2	---	0	0	---
14: TW Point Clark Treated Water	30-Oct-23 13:55	7.2	1.57	0	0	< 10
15: DW DW Inverlyn CH	30-Oct-23 11:00	7.2	1.21	0	0	< 10
16: DW DW Bruce beach	30-Oct-23 12:05	7.2	1.66	0	0	< 10
17: DW Chem Shed	30-Oct-23 13:30	7.2	1.29	0	0	< 10
18: DW Amberley Beach	30-Oct-23 14:25	7.2	1.43	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20004-NOV23

Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

27-October-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 24 October 2023
LR Report: CA21252-OCT23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	25-Oct-23	25-Oct-23	25-Oct-23
2: Analysis Start Time		---	---	09:05	09:05	08:50
3: Analysis Completed Date		---	---	27-Oct-23	27-Oct-23	27-Oct-23
4: Analysis Completed Time		---	---	11:24	11:24	11:24
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	23-Oct-23 11:50	9.2	---	0	0	---
7: TW Huronville South Treated Water	23-Oct-23 11:50	9.2	1.45	0	0	< 10
8: RW Murdock Glen Raw Water	23-Oct-23 12:15	9.2	---	0	0	---
9: TW Murdock Glen Treated Water	23-Oct-23 12:15	9.2	1.80	0	0	< 10
10: RW Blairs Grove Raw Water	23-Oct-23 12:30	9.2	---	0	0	---
11: TW Blairs Grove Treated Water	23-Oct-23 12:30	9.2	1.11	0	0	< 10
12: RW Point Clark Raw Water #2	23-Oct-23 12:50	9.2	---	0	0	---
13: RW Point Clark Raw Water #3	23-Oct-23 12:50	9.2	---	0	0	---
14: TW Point Clark Treated Water	23-Oct-23 12:55	9.2	1.61	0	0	< 10
15: DW DW Inverlyn CH	23-Oct-23 11:45	9.2	1.39	0	0	< 10
16: DW DW Bruce Beach SS	23-Oct-23 12:05	9.2	1.42	0	0	< 10
17: DW Chem Shed	23-Oct-23 12:38	9.2	1.17	0	0	< 10
18: DW Amberley Beach SS	23-Oct-23 13:05	9.2	1.11	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21252-OCT23

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

20-October-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 17 October 2023
 LR Report: CA20910-OCT23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	18-Oct-23	18-Oct-23	18-Oct-23
2: Analysis Start Time		---	---	---	10:10	10:10	09:25
3: Analysis Completed Date		---	---	---	20-Oct-23	20-Oct-23	20-Oct-23
4: Analysis Completed Time		---	---	---	10:21	10:21	10:21
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	16-Oct-23 11:05	8.4	---	0.15	0	0	---
7: TW Huronville South Treated Water	16-Oct-23 11:05	8.4	1.47	0.22	0	0	< 10
8: RW Murdock Glen Raw Water	16-Oct-23 11:30	8.4	---	0.17	0	0	---
9: TW Murdock Glen Treated Water	16-Oct-23 11:30	8.4	1.78	0.20	0	0	< 10
10: RW Blairs Grove Raw Water	16-Oct-23 12:20	8.4	---	0.33	0	0	---
11: TW Blairs Grove Treated Water	16-Oct-23 12:20	8.4	0.92	0.37	0	0	< 10
12: RW Point Clark Raw Water #2	16-Oct-23 13:10	8.4	---	0.22	0	0	---
13: RW Point Clark Raw Water #3	16-Oct-23 13:10	8.4	---	0.17	0	0	---
14: TW Point Clark Treated Water	16-Oct-23 13:10	8.4	1.49	0.23	0	0	< 10
15: DW DW Inverlyn CH	16-Oct-23 11:00	8.4	1.33	---	0	0	< 10
16: DW DW Chem Shed	16-Oct-23 12:50	8.4	1.10	---	0	0	< 10
17: DW Comm Center	16-Oct-23 13:00	8.4	1.10	---	0	0	< 10
18: DW Amberley Store	16-Oct-23 13:50	8.4	1.29	---	0	0	< 10
19: DW Amberley Beach	16-Oct-23 13:35	8.4	1.30	---	0	0	---
20: DW Birch St.	16-Oct-23 11:55	8.4	1.04	---	0	0	---
21: DW Bruce Beach	16-Oct-23 11:45	8.4	1.55	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20910-OCT23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-October-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 10 October 2023
LR Report: CA20445-OCT23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	11-Oct-23	11-Oct-23	11-Oct-23
2: Analysis Start Time		---	---	09:43	09:43	09:20
3: Analysis Completed Date		---	---	13-Oct-23	13-Oct-23	13-Oct-23
4: Analysis Completed Time		---	---	10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	09-Oct-23 11:05	6.2	---	0	0	---
7: TW Huronville South Treated Water	09-Oct-23 11:05	6.2	1.39	0	0	< 10
8: RW Murdock Glen Raw Water	09-Oct-23 11:30	6.2	---	0	0	---
9: TW Murdock Glen Treated Water	09-Oct-23 11:30	6.2	1.77	0	0	< 10
10: RW Blairs Grove Raw Water	09-Oct-23 12:05	6.2	---	0	0	---
11: TW Blairs Grove Treated Water	09-Oct-23 12:05	6.2	0.98	0	0	< 10
12: RW Point Clark Raw Water #2	09-Oct-23 13:00	6.2	---	0	0	---
13: RW Point Clark Raw Water #3	09-Oct-23 13:00	6.2	---	0	0	---
14: TW Point Clark Treated Water	09-Oct-23 13:00	6.2	1.59	0	0	< 10
15: DW DW Inverlyn CH	09-Oct-23 11:00	6.2	1.21	0	0	< 10
16: DW DW Chem Shed	09-Oct-23 12:30	6.2	1.27	0	0	10
17: DW Comm Center	09-Oct-23 12:40	6.2	1.08	0	0	10
18: DW Amberley Store	09-Oct-23 13:30	6.2	1.38	0	0	< 10
19: DW Amberley Beach	09-Oct-23 13:20	6.2	1.40	0	0	---
20: DW Birch St.	09-Oct-23 11:55	6.2	1.18	0	0	---
21: DW Bruce Beach	09-Oct-23 11:45	6.2	1.59	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20445-OCT23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

06-October-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 03 October 2023
 LR Report: CA20154-OCT23

100 Cove Rd., Goderich
 Canada, N7A 3Z2
 Phone: 519-524-6583, Fax:519-524-9358

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	04-Oct-23	04-Oct-23	04-Oct-23
2: Analysis Start Time		---	---	09:35	09:35	09:10
3: Analysis Completed Date		---	---	06-Oct-23	06-Oct-23	06-Oct-23
4: Analysis Completed Time		---	---	11:29	11:29	11:29
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	02-Oct-23 12:00	14.7	---	0	0	---
7: TW Huronville South Treated Water	02-Oct-23 12:00	14.7	1.48	0	0	10
8: RW Murdock Glen Raw Water	02-Oct-23 12:15	14.7	---	0	0	---
9: TW Murdock Glen Treated Water	02-Oct-23 12:15	14.7	1.67	0	0	< 10
10: RW Blairs Grove Raw Water	02-Oct-23 13:10	14.7	---	0	0	---
11: TW Blairs Grove Treated Water	02-Oct-23 13:10	14.7	1.08	0	0	< 10
12: RW Point Clark Raw Water #2	02-Oct-23 13:55	14.7	---	0	0	---
13: RW Point Clark Raw Water #3	02-Oct-23 13:55	14.7	---	0	0	---
14: TW Point Clark Treated Water	02-Oct-23 13:55	14.7	1.55	0	0	< 10
15: DW DW Inverlyn CH	02-Oct-23 11:50	14.7	1.40	0	0	< 10
16: DW DW Chem Shed	02-Oct-23 13:30	14.7	1.43	0	0	< 10
17: DW Comm Center	02-Oct-23 13:45	14.7	1.35	0	0	< 10
18: DW Amberley Store	02-Oct-23 14:30	14.7	1.33	0	0	< 10
19: DW Amberley Beach	02-Oct-23 14:15	14.7	1.50	0	0	---
20: DW Birch St.	02-Oct-23 13:00	14.7	1.18	0	0	---
21: DW Bruce Beach	02-Oct-23 12:30	14.7	1.48	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20154-OCT23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

29-September-2023

Veolia Water (Lakeshore)
Attn : Gary Nicholson

Date Rec. : 27 September 2023
LR Report: CA21524-SEP23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #2

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report


Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date		---	---	27-Sep-23	27-Sep-23
2: Analysis Start Time		---	---	16:52	16:52
3: Analysis Completed Date		---	---	29-Sep-23	29-Sep-23
4: Analysis Completed Time		---	---	15:54	15:54
5: MAC		---	---	0	0
6: NR Empty Lot	26-Sep-23 12:40	9.2	1.30	0	0
7: NR End	26-Sep-23 12:45	9.2	1.35	0	0
8: NR Empty Lot 2	27-Sep-23 09:25	9.2	1.34	0	0
9: NR End 2	27-Sep-23 09:30	9.2	1.12	0	0

MAC - Maximum Acceptable Concentration

NR - Not reportable under applicable Provincial drinking water regulations as per client.

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

22-September-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 19 September 2023
 LR Report: CA21007-SEP23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	20-Sep-23	20-Sep-23	20-Sep-23
2: Analysis Start Time		---	---	09:40	09:40	09:15
3: Analysis Completed Date		---	---	22-Sep-23	22-Sep-23	22-Sep-23
4: Analysis Completed Time		---	---	10:13	10:13	10:13
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	18-Sep-23 11:35	6.6	---	0	0	---
7: TW Huronville South Treated Water	18-Sep-23 11:35	6.6	1.45	0	0	< 10
8: RW Murdock Glen Raw Water	18-Sep-23 11:50	6.6	---	0	0	---
9: TW Murdock Glen Treated Water	18-Sep-23 11:50	6.6	1.68	0	0	< 10
10: RW Blairs Grove Raw Water	18-Sep-23 12:30	6.6	---	0	0	---
11: TW Blairs Grove Treated Water	18-Sep-23 12:30	6.6	1.01	0	0	< 10
12: RW Point Clark Raw Water #2	18-Sep-23 13:30	6.6	---	0	0	---
13: RW Point Clark Raw Water #3	18-Sep-23 13:30	6.6	---	0	0	---
14: TW Point Clark Treated Water	18-Sep-23 13:30	6.6	1.47	0	0	480
15: DW DW Inverlyn CH	18-Sep-23 11:20	6.6	1.39	0	0	20
16: DW DW Chem Shed	18-Sep-23 13:05	6.6	1.13	0	0	< 10
17: DW Comm Shed	18-Sep-23 13:15	6.6	1.24	0	0	< 10
18: DW Amberley Store	18-Sep-23 14:05	6.6	1.36	0	0	< 10
19: DW Amberley Beach	18-Sep-23 13:55	6.6	1.38	0	0	---
20: DW Birch St.	18-Sep-23 12:20	6.6	1.14	0	0	---
21: DW Bruce Beach	18-Sep-23 12:05	6.6	1.48	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21007-SEP23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

18-September-2023

Veolia Water (Lakeshore)
Attn : Gary Nicholson

Date Rec. : 14 September 2023
LR Report: CA20713-SEP23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	14-Sep-23	14-Sep-23	14-Sep-23
2: Analysis Start Time		---	---	15:35	15:35	15:00
3: Analysis Completed Date		---	---	18-Sep-23	18-Sep-23	18-Sep-23
4: Analysis Completed Time		---	---	10:04	10:04	10:04
5: MAC		---	---	0	0	---
6: NR Start	14-Sep-23 09:50	9.1	1.22	0	0	10
7: NR Tangle SS	14-Sep-23 09:55	9.1	1.16	0	0	< 10
8: NR Jardine	14-Sep-23 10:05	9.1	1.15	0	0	---
9: NR 906 Tangle	14-Sep-23 10:10	9.1	1.34	0	0	---

MAC - Maximum Acceptable Concentration

NR - Not reportable under applicable Provincial drinking water regulations as per client.

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

15-September-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 12 September 2023
 LR Report: CA20558-SEP23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	13-Sep-23	13-Sep-23	13-Sep-23
2: Analysis Start Time		---	---	---	09:30	09:30	09:10
3: Analysis Completed Date		---	---	---	15-Sep-23	15-Sep-23	15-Sep-23
4: Analysis Completed Time		---	---	---	11:25	11:25	11:25
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	11-Sep-23 11:05	5.8	---	0.19	0	0	---
7: TW Huronville South Treated Water	11-Sep-23 11:05	5.8	1.46	0.22	0	0	< 10
8: RW Murdock Glen Raw Water	11-Sep-23 11:30	5.8	---	0.21	0	0	---
9: TW Murdock Glen Treated Water	11-Sep-23 11:30	5.8	1.73	0.25	0	0	< 10
10: RW Blairs Grove Raw Water	11-Sep-23 12:15	5.8	---	0.37	0	0	---
11: TW Blairs Grove Treated Water	11-Sep-23 12:15	5.8	1.05	0.44	0	0	< 10
12: RW Point Clark Raw Water #2	11-Sep-23 13:25	5.8	---	0.20	0	0	---
13: RW Point Clark Raw Water #3	11-Sep-23 13:25	5.8	---	0.19	0	0	---
14: TW Point Clark Treated Water	11-Sep-23 13:25	5.8	1.59	0.25	0	0	< 10
15: DW DW Inverlyn CH	11-Sep-23 11:00	5.8	1.49	---	0	0	< 10
16: DW DW Chem Shed	11-Sep-23 12:25	5.8	1.21	---	0	0	< 10
17: DW Comm Center	11-Sep-23 12:50	5.8	1.29	---	0	0	< 10
18: DW Amberley Store	11-Sep-23 14:00	5.8	1.19	---	0	0	< 10
19: DW Amberley Beach	11-Sep-23 13:50	5.8	1.38	---	0	0	---
20: DW Birch St.	11-Sep-23 12:05	5.8	1.17	---	0	0	---
21: DW Bruce Beach	11-Sep-23 11:45	5.8	1.53	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20558-SEP23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

08-September-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Phone: 519-524-6583
Fax: 519-524-9358

Date Rec. : 05 September 2023
LR Report: CA20092-SEP23

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	06-Sep-23	06-Sep-23	06-Sep-23
2: Analysis Start Time		---	---	11:35	11:35	11:10
3: Analysis Completed Date		---	---	08-Sep-23	08-Sep-23	08-Sep-23
4: Analysis Completed Time		---	---	11:27	11:27	11:27
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	05-Sep-23 07:30	13.9	---	0	0	---
7: TW Huronville South Treated Water	05-Sep-23 07:35	13.9	1.55	0	0	< 10
8: RW Murdock Glen Raw Water	05-Sep-23 08:20	13.9	---	0	0	---
9: TW Murdock Glen Treated Water	05-Sep-23 08:25	13.9	1.68	0	0	< 10
10: RW Blairs Grove Raw Water	05-Sep-23 09:05	13.9	---	0	0	---
11: TW Blairs Grove Treated Water	05-Sep-23 09:00	13.9	1.24	0	0	< 10
12: RW Point Clark Raw Water #2	05-Sep-23 10:25	13.9	---	0	0	---
13: RW Point Clark Raw Water #3	05-Sep-23 10:30	13.9	---	0	0	---
14: TW Point Clark Treated Water	05-Sep-23 10:15	13.9	1.44	0	0	< 10
15: DW DW PC Rec Center	05-Sep-23 08:50	13.9	1.33	0	0	10
16: DW DW Chem Shed	05-Sep-23 09:30	13.9	1.10	0	0	10
17: DW 157 Carway	05-Sep-23 10:00	13.9	1.47	0	0	< 10
18: DW 530 Attawandron	05-Sep-23 10:45	13.9	1.57	0	0	< 10
19: DW Amberley Beach SS	05-Sep-23 10:55	13.9	1.33	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

**SGS Canada Inc.**

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425**LR Report :** CA20092-SEP23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

01-September-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 29 August 2023
LR Report: CA21682-AUG23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1


Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	30-Aug-23	30-Aug-23	30-Aug-23
2: Analysis Start Time		---	---	09:50	09:50	09:15
3: Analysis Completed Date		---	---	01-Sep-23	01-Sep-23	01-Sep-23
4: Analysis Completed Time		---	---	09:38	09:38	09:38
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	28-Aug-23 11:05	6.6	---	0	0	---
7: TW Huronville South Treated Water	28-Aug-23 11:05	6.6	1.52	0	0	< 10
8: RW Murdock Glen Raw Water	28-Aug-23 11:25	6.6	---	0	0	---
9: TW Murdock Glen Treated Water	28-Aug-23 11:25	6.6	1.70	0	0	< 10
10: RW Blairs Grove Raw Water	28-Aug-23 12:10	6.6	---	0	0	---
11: TW Blairs Grove Treated Water	28-Aug-23 12:10	6.6	1.26	0	0	< 10
12: RW Point Clark Raw Water #2	28-Aug-23 13:10	6.6	---	0	0	---
13: RW Point Clark Raw Water #3	28-Aug-23 13:10	6.6	---	0	0	---
14: TW Point Clark Treated Water	28-Aug-23 13:10	6.6	1.67	0	0	< 10
15: DW DW Inverlyn CH	28-Aug-23 11:00	6.6	1.40	0	0	280
16: DW DW Chem Shed	28-Aug-23 12:55	6.6	1.20	0	0	< 10
17: DW Comm Center	28-Aug-23 13:05	6.6	1.47	0	0	< 10
18: DW Amberley Store	28-Aug-23 13:35	6.6	1.37	0	0	< 10
19: DW Amberley Beach	28-Aug-23 13:25	6.6	1.61	0	0	---
20: DW Birch St.	28-Aug-23 12:05	6.6	1.31	0	0	---
21: DW Bruce Beach	28-Aug-23 11:45	6.6	1.56	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

**SGS Canada Inc.**

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425**LR Report :** CA21682-AUG23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

25-August-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

100 Cove Rd., Goderich
Canada, N7A 3Z2
Phone: 519-524-6583, Fax:519-524-9358

Date Rec. : 22 August 2023
LR Report: CA21315-AUG23

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	23-Aug-23	23-Aug-23	23-Aug-23
2: Analysis Start Time		---	---	09:35	09:35	09:10
3: Analysis Completed Date		---	---	25-Aug-23	25-Aug-23	25-Aug-23
4: Analysis Completed Time		---	---	10:22	10:22	10:22
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	21-Aug-23 11:40	9.3	---	0	0	---
7: TW Huronville South Treated Water	21-Aug-23 11:40	9.3	1.51	0	0	< 10
8: RW Murdock Glen Raw Water	21-Aug-23 12:00	9.3	---	0	0	---
9: TW Murdock Glen Treated Water	21-Aug-23 12:00	9.3	1.71	0	0	< 10
10: RW Blairs Grove Raw Water	21-Aug-23 13:15	9.3	---	0	0	---
11: TW Blairs Grove Treated Water	21-Aug-23 13:15	9.3	1.23	0	0	< 10
12: RW Point Clark Raw Water #2	21-Aug-23 14:05	9.3	---	1	0	---
13: RW Point Clark Raw Water #3	21-Aug-23 14:05	9.3	---	0	0	---
14: TW Point Clark Treated Water	21-Aug-23 14:05	9.3	1.65	0	0	< 10
15: DW DW Inverlyn CH	21-Aug-23 11:35	9.3	1.56	0	0	< 10
16: DW DW Chem Shed	21-Aug-23 13:35	9.3	1.31	0	0	< 10
17: DW Comm Center	21-Aug-23 13:50	9.3	1.30	0	0	10
18: DW Amberley Store	21-Aug-23 14:35	9.3	1.53	0	0	< 10
19: DW Amberley Beach	21-Aug-23 14:25	9.3	1.52	0	0	---
20: DW Birch St.	21-Aug-23 12:45	9.3	1.31	0	0	---
21: DW Bruce Beach	21-Aug-23 12:30	9.3	1.67	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21315-AUG23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

18-August-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 15 August 2023
 LR Report: CA20910-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	16-Aug-23	16-Aug-23	16-Aug-23
2: Analysis Start Time		---	---	---	10:05	10:05	09:30
3: Analysis Completed Date		---	---	---	18-Aug-23	18-Aug-23	18-Aug-23
4: Analysis Completed Time		---	---	---	10:33	10:33	10:33
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	14-Aug-23 11:25	5.9	---	0.21	0	0	---
7: TW Huronville South Treated Water	14-Aug-23 11:20	5.9	1.51	0.29	0	0	< 10
8: RW Murdock Glen Raw Water	14-Aug-23 11:40	5.9	---	0.17	0	0	---
9: TW Murdock Glen Treated Water	14-Aug-23 11:40	5.9	1.70	0.25	0	0	< 10
10: RW Blairs Grove Raw Water	14-Aug-23 12:30	5.9	---	0.33	0	0	---
11: TW Blairs Grove Treated Water	14-Aug-23 12:30	5.9	1.37	0.39	0	0	< 10
12: RW Point Clark Raw Water #2	14-Aug-23 13:15	5.9	---	0.22	0	0	---
13: RW Point Clark Raw Water #3	14-Aug-23 13:15	5.9	---	0.20	0	0	---
14: TW Point Clark Treated Water	14-Aug-23 13:15	5.9	1.74	0.23	0	0	< 10
15: DW DW Comm Center	14-Aug-23 11:00	5.9	1.21	---	0	0	10
16: DW DW Inverlyn CH	14-Aug-23 11:15	5.9	1.45	---	0	0	< 10
17: DW Amberley East SS	14-Aug-23 13:55	5.9	1.22	---	0	0	< 10
18: DW Amberley Store	14-Aug-23 13:50	5.9	1.51	---	0	0	< 10
19: DW Amberley Beach	14-Aug-23 13:40	5.9	1.67	---	0	0	---
20: DW Birch St.	14-Aug-23 12:15	5.9	1.32	---	0	0	---
21: DW Bruce Beach	14-Aug-23 12:00	5.9	1.53	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20910-AUG23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

11-August-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 08 August 2023
 LR Report: CA20430-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	09-Aug-23	09-Aug-23	09-Aug-23
2: Analysis Start Time		---	---	11:40	11:40	10:55
3: Analysis Completed Date		---	---	11-Aug-23	11-Aug-23	11-Aug-23
4: Analysis Completed Time		---	---	11:42	11:42	11:42
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	08-Aug-23 08:10	12.4	---	0	0	---
7: TW Huronville South Treated Water	08-Aug-23 08:10	12.4	1.64	0	0	< 10
8: RW Murdock Glen Raw Water	08-Aug-23 08:25	12.4	---	0	0	---
9: TW Murdock Glen Treated Water	08-Aug-23 08:25	12.4	1.69	0	0	< 10
10: RW Blairs Grove Raw Water	08-Aug-23 09:45	12.4	---	0	0	---
11: TW Blairs Grove Treated Water	08-Aug-23 09:40	12.4	1.46	0	0	< 10
12: RW Point Clark Raw Water #2	08-Aug-23 10:30	12.4	---	0	0	---
13: RW Point Clark Raw Water #3	08-Aug-23 10:30	12.4	---	0	0	---
14: TW Point Clark Treated Water	08-Aug-23 10:25	12.4	1.77	0	0	< 10
15: DW DW Inverlyn CH	08-Aug-23 08:00	12.4	1.58	0	0	< 10
16: DW DW Chem Shed	08-Aug-23 09:55	12.4	1.51	0	0	< 10
17: DW Comm Center	08-Aug-23 09:25	12.4	1.65	0	0	< 10
18: DW Amberley Store	08-Aug-23 11:00	12.4	1.67	0	0	< 10
19: DW Amberley Beach	08-Aug-23 10:55	12.4	1.70	0	0	---
20: DW Birch St.	08-Aug-23 09:30	12.4	1.39	0	0	---
21: DW Bruce Beach	08-Aug-23 08:45	12.4	1.65	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20430-AUG23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

04-August-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 01 August 2023
 LR Report: CA20146-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	02-Aug-23	02-Aug-23	02-Aug-23
2: Analysis Start Time		---	---	09:55	09:55	09:20
3: Analysis Completed Date		---	---	04-Aug-23	04-Aug-23	04-Aug-23
4: Analysis Completed Time		---	---	11:23	11:23	11:23
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	31-Jul-23 11:45	6.8	---	1	0	---
7: TW Huronville South Treated Water	31-Jul-23 11:45	6.8	1.84	0	0	< 10
8: RW Murdock Glen Raw Water	31-Jul-23 11:55	6.8	---	0	0	---
9: TW Murdock Glen Treated Water	31-Jul-23 11:55	6.8	1.64	0	0	< 10
10: RW Blairs Grove Raw Water	31-Jul-23 12:30	6.8	---	0	0	---
11: TW Blairs Grove Treated Water	31-Jul-23 12:35	6.8	1.51	0	0	< 10
12: RW Point Clark Raw Water #2	31-Jul-23 13:35	6.8	---	0	0	---
13: RW Point Clark Raw Water #3	31-Jul-23 13:35	6.8	---	0	0	---
14: TW Point Clark Treated Water	31-Jul-23 13:30	6.8	1.86	0	0	< 10
15: DW DW Inverlyn CH	31-Jul-23 11:30	6.8	1.72	0	0	< 10
16: DW DW Chem Shed	31-Jul-23 13:05	6.8	1.49	0	0	100
17: DW Comm Center	31-Jul-23 13:15	6.8	1.59	0	0	< 10
18: DW Amberley Store	31-Jul-23 14:05	6.8	1.47	0	0	< 10
19: DW Amberley Beach	31-Jul-23 13:50	6.8	1.68	0	0	---
20: DW Birch St.	31-Jul-23 12:20	6.8	1.47	0	0	---
21: DW Bruce Beach	31-Jul-23 12:05	6.8	1.67	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20146-AUG23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

31-July-2023
Veolia Water (Lakeshore)
Attn : Gary Nicholson

Date Rec. : 28 July 2023
LR Report: CA21570-JUL23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	28-Jul-23	28-Jul-23	28-Jul-23
2: Analysis Start Time		---	---	12:55	12:55	12:10
3: Analysis Completed Date		---	---	31-Jul-23	31-Jul-23	31-Jul-23
4: Analysis Completed Time		---	---	11:01	11:01	11:01
5: MAC		---	---	0	0	---
6: DW Tanglewood B/O	26-Jul-23 17:05	16.2	2.10	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-July-2023

Veolia Water (Lakeshore)
Attn : Gary Nicholson

Date Rec. : 25 July 2023
LR Report: CA21402-JUL23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date		---	---	26-Jul-23	26-Jul-23
2: Analysis Start Time		---	---	08:40	08:40
3: Analysis Completed Date		---	---	28-Jul-23	28-Jul-23
4: Analysis Completed Time		---	---	10:56	10:56
5: MAC		---	---	0	0
6: NR 204 Jardine	24-Jul-23 09:35	11.6	1.71	0	0
7: NR 506 Ridge Wood	24-Jul-23 09:40	11.6	1.95	0	0
8: NR Tanglewood DE	24-Jul-23 09:50	11.6	1.42	0	0
9: NR 204 Jardine 2	25-Jul-23 08:05	11.6	1.41	0	0
10: NR 506 Ridge Wood 2	25-Jul-23 08:10	11.6	1.67	0	0
11: NR Tanglewood DE 2	25-Jul-23 08:20	11.6	1.63	0	0

MAC - Maximum Acceptable Concentration

NR - Not reportable under applicable Provincial drinking water regulations as per client.

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-July-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 25 July 2023
 LR Report: CA21403-JUL23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Jul-23	26-Jul-23	26-Jul-23
2: Analysis Start Time		---	---	09:45	09:45	09:15
3: Analysis Completed Date		---	---	28-Jul-23	28-Jul-23	28-Jul-23
4: Analysis Completed Time		---	---	10:59	10:59	10:59
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	24-Jul-23 11:05	6.9	---	0	0	---
7: TW Huronville South Treated Water	24-Jul-23 11:05	6.9	1.71	0	0	< 10
8: RW Murdock Glen Raw Water	24-Jul-23 11:25	6.9	---	0	0	---
9: TW Murdock Glen Treated Water	24-Jul-23 11:25	6.9	1.74	0	0	< 10
10: RW Blairs Grove Raw Water	24-Jul-23 12:05	6.9	---	0	0	---
11: TW Blairs Grove Treated Water	24-Jul-23 12:05	6.9	1.50	0	0	< 10
12: RW Point Clark Raw Water #2	24-Jul-23 13:30	6.9	---	0	0	---
13: RW Point Clark Raw Water #3	24-Jul-23 13:30	6.9	---	0	0	---
14: TW Point Clark Treated Water	24-Jul-23 13:20	6.9	1.77	0	0	< 10
15: DW DW Inverlyn CH	24-Jul-23 11:00	6.9	1.68	0	0	< 10
16: DW DW Chem Shed	24-Jul-23 12:20	6.9	1.51	0	0	< 10
17: DW Comm Center	24-Jul-23 12:30	6.9	1.66	0	0	< 10
18: DW Amberley Store	24-Jul-23 14:00	6.9	1.58	0	0	10
19: DW Amberley Beach	24-Jul-23 13:45	6.9	1.75	0	0	---
20: DW Birch St.	24-Jul-23 12:00	6.9	1.51	0	0	---
21: DW Bruce Beach	24-Jul-23 11:45	6.9	1.66	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21403-JUL23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

21-July-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 18 July 2023
LR Report: CA21008-JUL23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1


Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	19-Jul-23	19-Jul-23	19-Jul-23
2: Analysis Start Time		---	---	09:55	09:55	09:20
3: Analysis Completed Date		---	---	21-Jul-23	21-Jul-23	21-Jul-23
4: Analysis Completed Time		---	---	11:23	11:23	11:23
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	17-Jul-23 11:55	9.9	---	0	0	---
7: TW Huronville South Treated Water	17-Jul-23 11:55	9.9	1.70	0	0	90
8: RW Murdock Glen Raw Water	17-Jul-23 12:20	9.9	---	0	0	---
9: TW Murdock Glen Treated Water	17-Jul-23 12:20	9.9	1.76	0	0	20
10: RW Blairs Grove Raw Water	17-Jul-23 13:10	9.9	---	0	0	---
11: TW Blairs Grove Treated Water	17-Jul-23 13:05	9.9	1.33	0	0	10
12: RW Point Clark Raw Water #2	17-Jul-23 14:05	9.9	---	0	0	---
13: RW Point Clark Raw Water #3	17-Jul-23 14:05	9.9	---	0	0	---
14: TW Point Clark Treated Water	17-Jul-23 14:00	9.9	1.48	0	0	< 10
15: DW DW Inverlyn CH	17-Jul-23 11:45	9.9	1.54	0	0	30
16: DW DW Chem Shed	17-Jul-23 13:20	9.9	1.25	0	0	< 10
17: DW Comm Center	17-Jul-23 13:40	9.9	1.42	0	0	< 10
18: DW Amberley Store	17-Jul-23 15:05	9.9	1.38	0	0	< 10
19: DW Amberley Beach	17-Jul-23 14:50	9.9	1.44	0	0	---
20: DW Birch St.	17-Jul-23 12:55	9.9	1.32	0	0	---
21: DW Bruce Beach	17-Jul-23 12:40	9.9	1.66	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21008-JUL23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-July-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 11 July 2023
 LR Report: CA20567-JUL23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	12-Jul-23	12-Jul-23	12-Jul-23
2: Analysis Start Time		---	---	---	10:10	10:10	09:30
3: Analysis Completed Date		---	---	---	14-Jul-23	14-Jul-23	14-Jul-23
4: Analysis Completed Time		---	---	---	10:48	10:48	10:48
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	10-Jul-23 11:05	5.1	---	0.20	0	0	---
7: TW Huronville South Treated Water	10-Jul-23 11:05	5.1	1.57	0.23	0	0	< 10
8: RW Murdock Glen Raw Water	10-Jul-23 11:15	5.1	---	0.21	0	0	---
9: TW Murdock Glen Treated Water	10-Jul-23 11:15	5.1	1.80	0.26	0	0	< 10
10: RW Blairs Grove Raw Water	10-Jul-23 11:50	5.1	---	0.33	0	0	---
11: TW Blairs Grove Treated Water	10-Jul-23 11:50	5.1	1.32	0.37	0	0	< 10
12: RW Point Clark Raw Water #2	10-Jul-23 13:20	5.1	---	0.19	1	0	---
13: RW Point Clark Raw Water #3	10-Jul-23 13:20	5.1	---	0.17	1	0	---
14: TW Point Clark Treated Water	10-Jul-23 13:20	5.1	1.49	0.23	0	0	< 10
15: DW DW Inverlyn CH	10-Jul-23 11:00	5.1	1.57	---	0	0	< 10
16: DW DW Chem Shed	10-Jul-23 12:45	5.1	1.30	---	0	0	10
17: DW Comm Center	10-Jul-23 13:05	5.1	1.20	---	0	0	< 10
18: DW Amberley Store	10-Jul-23 13:55	5.1	1.36	---	0	0	< 10
19: DW Amberley Beach	10-Jul-23 13:45	5.1	1.55	---	0	0	---
20: DW Birch St.	10-Jul-23 11:45	5.1	1.32	---	0	0	---
21: DW Bruce Beach	10-Jul-23 11:35	5.1	1.66	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20567-JUL23

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-July-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 04 July 2023
LR Report: CA20089-JUL23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1


Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Jul-23	05-Jul-23	05-Jul-23
2: Analysis Start Time		---	---	10:05	10:05	09:35
3: Analysis Completed Date		---	---	06-Jul-23	06-Jul-23	07-Jul-23
4: Analysis Completed Time		---	---	16:02	16:02	09:54
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	03-Jul-23 12:50	13.0	---	0	0	---
7: TW Huronville South Treated Water	03-Jul-23 12:45	13.0	1.57	0	0	< 10
8: RW Murdock Glen Raw Water	03-Jul-23 12:20	13.0	---	0	0	---
9: TW Murdock Glen Treated Water	03-Jul-23 12:15	13.0	1.80	0	0	< 10
10: RW Blairs Grove Raw Water	03-Jul-23 13:40	13.0	---	0	0	---
11: TW Blairs Grove Treated Water	03-Jul-23 13:45	13.0	1.34	0	0	< 10
12: RW Point Clark Raw Water #2	03-Jul-23 14:40	13.0	---	0	0	---
13: RW Point Clark Raw Water #3	03-Jul-23 14:45	13.0	---	0	0	---
14: TW Point Clark Treated Water	03-Jul-23 14:35	13.0	1.58	0	0	< 10
15: DW DW Amberly B SS	03-Jul-23 14:50	13.0	1.54	0	0	10
16: DW DW PCCC	03-Jul-23 14:20	13.0	1.42	0	0	< 10
17: DW 702 LR	03-Jul-23 13:15	13.0	1.66	0	0	< 10
18: DW Bruce BCH SS	03-Jul-23 12:55	13.0	1.71	0	0	< 10
19: DW Inverly CLBHSE	03-Jul-23 12:30	13.0	1.28	0	0	---
20: DW 179 Bell Dr	03-Jul-23 13:25	13.0	1.34	0	0	---
21: DW 3048 AR SS	03-Jul-23 15:45	13.0	1.18	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20089-JUL23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

30-June-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 27 June 2023
LR Report: CA21511-JUN23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	28-Jun-23	28-Jun-23	28-Jun-23
2: Analysis Start Time		---	---	09:55	09:55	09:30
3: Analysis Completed Date		---	---	30-Jun-23	30-Jun-23	30-Jun-23
4: Analysis Completed Time		---	---	09:42	09:42	09:42
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	26-Jun-23 11:30	7.1	---	0	0	---
7: TW Huronville South Treated Water	26-Jun-23 11:30	7.1	1.51	0	0	10
8: RW Murdock Glen Raw Water	26-Jun-23 11:50	7.1	---	0	0	---
9: TW Murdock Glen Treated Water	26-Jun-23 11:50	7.1	1.77	0	0	< 10
10: RW Blairs Grove Raw Water	26-Jun-23 12:30	7.1	---	0	0	---
11: TW Blairs Grove Treated Water	26-Jun-23 12:30	7.1	1.39	0	0	< 10
12: RW Point Clark Raw Water #2	26-Jun-23 14:00	7.1	---	0	0	---
13: RW Point Clark Raw Water #3	26-Jun-23 14:00	7.1	---	0	0	---
14: TW Point Clark Treated Water	26-Jun-23 14:00	7.1	1.57	0	0	< 10
15: DW DW Inverlyn CH	26-Jun-23 11:20	7.1	1.47	0	0	< 10
16: DW DW Chem Shed	26-Jun-23 13:20	7.1	1.43	0	0	10
17: DW Comm Center	26-Jun-23 13:40	7.1	1.52	0	0	< 10
18: DW Amberley Store	26-Jun-23 14:30	7.1	1.48	0	0	< 10
19: DW Amberley Beach	26-Jun-23 14:20	7.1	1.44	0	0	---
20: DW Birch St.	26-Jun-23 12:20	7.1	1.58	0	0	---
21: DW Bruce Beach	26-Jun-23 12:05	7.1	1.73	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001





SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21511-JUN23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

23-June-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 20 June 2023
 LR Report: CA21123-JUN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	21-Jun-23	21-Jun-23	21-Jun-23
2: Analysis Start Time		---	---	10:10	10:10	09:45
3: Analysis Completed Date		---	---	23-Jun-23	23-Jun-23	23-Jun-23
4: Analysis Completed Time		---	---	09:40	09:40	09:40
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	19-Jun-23 14:35	8.7	---	0	0	---
7: TW Huronville South Treated Water	19-Jun-23 14:35	8.7	1.51	0	0	< 10
8: RW Murdock Glen Raw Water	19-Jun-23 14:05	8.7	---	0	0	---
9: TW Murdock Glen Treated Water	19-Jun-23 14:05	8.7	1.80	0	0	< 10
10: RW Blairs Grove Raw Water	19-Jun-23 13:40	8.7	---	0	0	---
11: TW Blairs Grove Treated Water	19-Jun-23 13:35	8.7	1.58	0	0	< 10
12: RW Point Clark Raw Water #2	19-Jun-23 11:45	8.7	---	0	0	---
13: RW Point Clark Raw Water #3	19-Jun-23 11:45	8.7	---	0	0	---
14: TW Point Clark Treated Water	19-Jun-23 11:45	8.7	1.65	0	0	< 10
15: DW DW Amberley Store	19-Jun-23 11:05	8.7	1.49	0	0	< 10
16: DW DW Comm Center	19-Jun-23 11:30	8.7	1.34	0	0	< 10
17: DW Chem Shed	19-Jun-23 13:55	8.7	1.41	0	0	< 10
18: DW Inverlyn CH	19-Jun-23 14:30	8.7	1.55	0	0	< 10
19: DW Amberley Beach	19-Jun-23 11:15	8.7	1.69	0	0	---
20: DW 204 Jardine	19-Jun-23 13:15	8.7	1.58	0	0	---
21: DW Bruce Beach	19-Jun-23 13:55	8.7	1.23	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21123-JUN23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

16-June-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 13 June 2023
LR Report: CA20718-JUN23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1


Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	14-Jun-23	14-Jun-23	14-Jun-23
2: Analysis Start Time		---	---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	---	16-Jun-23	16-Jun-23	16-Jun-23
4: Analysis Completed Time		---	---	---	11:32	11:32	11:32
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	12-Jun-23 11:20	9.6	---	0.19	0	0	---
7: TW Huronville South Treated Water	12-Jun-23 11:20	9.6	1.60	0.23	0	0	< 10
8: RW Murdock Glen Raw Water	12-Jun-23 11:40	9.6	---	0.21	0	0	---
9: TW Murdock Glen Treated Water	12-Jun-23 11:40	9.6	1.89	0.25	0	0	< 10
10: RW Blairs Grove Raw Water	12-Jun-23 12:25	9.6	---	0.33	0	0	---
11: TW Blairs Grove Treated Water	12-Jun-23 12:20	9.6	1.71	0.31	0	0	< 10
12: RW Point Clark Raw Water #2	12-Jun-23 14:05	9.6	---	0.22	0	0	---
13: RW Point Clark Raw Water #3	12-Jun-23 14:05	9.6	---	0.24	0	0	---
14: TW Point Clark Treated Water	12-Jun-23 14:05	9.6	1.80	0.27	0	0	< 10
15: DW DW Inverlyn CH	12-Jun-23 11:10	9.6	1.61	---	0	0	10
16: DW DW Comm Center	12-Jun-23 13:35	9.6	1.95	---	0	0	< 10
17: DW Chem Shed	12-Jun-23 12:40	9.6	1.62	---	0	0	< 10
18: DW Amberley Store	12-Jun-23 14:50	9.6	1.83	---	0	0	< 10
19: DW Amberley Beach	12-Jun-23 14:40	9.6	1.83	---	0	0	---
20: DW Birch St.	12-Jun-23 12:15	9.6	1.38	---	0	0	---
21: DW Bruce Beach	12-Jun-23 12:05	9.6	1.73	---	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

**SGS Canada Inc.**

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425**LR Report :** CA20718-JUN23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

09-June-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 06 June 2023
LR Report: CA20336-JUN23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1


Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-Jun-23	07-Jun-23	07-Jun-23
2: Analysis Start Time		---	---	10:25	10:25	09:55
3: Analysis Completed Date		---	---	09-Jun-23	09-Jun-23	09-Jun-23
4: Analysis Completed Time		---	---	11:11	11:11	11:11
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	05-Jun-23 11:35	8.0	---	0	0	---
7: TW Huronville South Treated Water	05-Jun-23 11:35	8.0	1.65	0	0	< 10
8: RW Murdock Glen Raw Water	05-Jun-23 11:55	8.0	---	0	0	---
9: TW Murdock Glen Treated Water	05-Jun-23 11:55	8.0	1.94	0	0	< 10
10: RW Blairs Grove Raw Water	05-Jun-23 12:30	8.0	---	0	0	---
11: TW Blairs Grove Treated Water	05-Jun-23 12:30	8.0	1.80	0	0	< 10
12: RW Point Clark Raw Water #2	05-Jun-23 14:15	8.0	---	4	0	---
13: RW Point Clark Raw Water #3	05-Jun-23 14:15	8.0	---	0	0	---
14: TW Point Clark Treated Water	05-Jun-23 14:15	8.0	1.53	0	0	10
15: DW DW Comm Center	05-Jun-23 11:00	8.0	1.60	0	0	10
16: DW DW Inverlyn CH	05-Jun-23 11:25	8.0	1.49	0	0	< 10
17: DW Chem Shed	05-Jun-23 13:00	8.0	1.55	0	0	< 10
18: DW Amberley Store	05-Jun-23 15:00	8.0	1.41	0	0	< 10
19: DW Amberley Beach	05-Jun-23 14:45	8.0	1.57	0	0	---
20: DW Birch St.	05-Jun-23 13:15	8.0	1.22	0	0	---
21: DW Bruce Beach	05-Jun-23 12:15	8.0	1.73	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

**SGS Canada Inc.**

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425**LR Report :** CA20336-JUN23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

02-June-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 30 May 2023

LR Report: CA21650-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583

Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	31-May-23	31-May-23	31-May-23
2: Analysis Start Time		---	---	10:05	10:05	09:35
3: Analysis Completed Date		---	---	02-Jun-23	02-Jun-23	02-Jun-23
4: Analysis Completed Time		---	---	12:04	12:04	12:04
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	29-May-23 11:30	8.9	---	0	0	---
7: TW Huronville South Treated Water	29-May-23 11:30	8.9	1.74	0	0	< 10
8: RW Murdock Glen Raw Water	29-May-23 12:00	8.9	---	0	0	---
9: TW Murdock Glen Treated Water	29-May-23 12:00	8.9	1.97	0	0	< 10
10: RW Blairs Grove Raw Water	29-May-23 13:25	8.9	---	0	0	---
11: TW Blairs Grove Treated Water	29-May-23 13:25	8.9	1.55	0	0	10
12: RW Point Clark Raw Water #2	29-May-23 14:10	8.9	---	0	0	---
13: RW Point Clark Raw Water #3	29-May-23 14:10	8.9	---	0	0	---
14: TW Point Clark Treated Water	29-May-23 14:10	8.9	1.72	0	0	< 10
15: DW DW Inverlyn CH	29-May-23 11:00	8.9	1.68	0	0	< 10
16: DW DW Chem Shed	29-May-23 13:40	8.9	1.51	0	0	< 10
17: DW Comm Center	29-May-23 14:00	8.9	1.31	0	0	< 10
18: DW Amberley Store	29-May-23 15:05	8.9	1.52	0	0	< 10
19: DW Amberley Beach	29-May-23 14:55	8.9	1.62	0	0	---
20: DW Birch St.	29-May-23 12:35	8.9	1.21	0	0	---
21: DW Bruce beach	29-May-23 12:25	8.9	1.89	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21650-MAY23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

26-May-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 23 May 2023

LR Report: CA21250-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583

Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI mg/L	Free Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	24-May-23	24-May-23	24-May-23
2: Analysis Start Time		---	---	11:55	11:55	11:00
3: Analysis Completed Date		---	---	26-May-23	26-May-23	26-May-23
4: Analysis Completed Time		---	---	11:20	11:20	11:20
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	23-May-23 08:10	10.5	---	0	0	---
7: TW Huronville South Treated Water	23-May-23 08:10	10.5	1.60	0	0	< 10
8: RW Murdock Glen Raw Water	23-May-23 08:30	10.5	---	0	0	---
9: TW Murdock Glen Treated Water	23-May-23 08:30	10.5	1.80	0	0	10
10: RW Blairs Grove Raw Water	23-May-23 10:15	10.5	---	0	0	---
11: TW Blairs Grove Treated Water	23-May-23 10:15	10.5	1.50	0	0	< 10
12: RW Point Clark Raw Water #2	23-May-23 10:50	10.5	---	0	0	---
13: RW Point Clark Raw Water #3	23-May-23 10:50	10.5	---	2	0	---
14: TW Point Clark Treated Water	23-May-23 10:50	10.5	1.69	0	0	< 10
15: DW DW Inverlyn CH	23-May-23 07:55	10.5	1.74	0	0	< 10
16: DW DW Comm Center	23-May-23 09:10	10.5	1.60	0	0	< 10
17: DW Chem Shed	23-May-23 10:25	10.5	1.41	0	0	< 10
18: DW Amberley Store	23-May-23 11:25	10.5	1.47	0	0	< 10
19: DW Amberley Beach	23-May-23 11:15	10.5	1.65	0	0	---
20: DW Birch St.	23-May-23 09:45	10.5	1.09	0	0	---
21: DW Bruce Beach	23-May-23 08:45	10.5	1.66	0	0	---


MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425**LR Report :** CA21250-MAY23

Carrie Greenlaw
Carrie Greenlaw
Project Specialist,
Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

19-May-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Phone: 519-524-6583
Fax: 519-524-9358

Date Rec. : 16 May 2023
LR Report: CA20984-MAY23


Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	17-May-23	17-May-23	17-May-23
2: Analysis Start Time		---	---	---	10:15	10:15	09:45
3: Analysis Completed Date		---	---	---	19-May-23	19-May-23	19-May-23
4: Analysis Completed Time		---	---	---	10:41	10:41	10:41
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	15-May-23 11:05	5.0	---	0.20	0	0	---
7: TW Huronville South Treated Water	15-May-23 11:05	5.0	1.64	0.25	0	0	< 10
8: RW Murdock Glen Raw Water	15-May-23 11:25	5.0	---	0.21	0	0	---
9: TW Murdock Glen Treated Water	15-May-23 11:20	5.0	1.75	0.24	0	0	< 10
10: RW Blairs Grove Raw Water	15-May-23 12:30	5.0	---	0.37	0	0	---
11: TW Blairs Grove Treated Water	15-May-23 12:30	5.0	1.50	0.31	0	0	< 10
12: RW Point Clark Raw Water #2	15-May-23 13:25	5.0	---	0.19	0	0	---
13: RW Point Clark Raw Water #3	15-May-23 13:20	5.0	---	0.22	0	0	---
14: TW Point Clark Treated Water	15-May-23 13:20	5.0	1.65	0.29	0	0	< 10
15: DW DW Inverlyn CH	15-May-23 11:00	5.0	1.44	---	0	0	10
16: DW DW Chem Shed	15-May-23 12:40	5.0	1.33	---	0	0	< 10
17: DW Comm Center	15-May-23 12:55	5.0	1.47	---	0	0	< 10
18: DW Amberley Store	15-May-23 13:55	5.0	1.40	---	0	0	10
19: DW Amberley Beach	15-May-23 13:45	5.0	1.54	---	0	0	---
20: DW Birch St.	15-May-23 11:50	5.0	1.11	---	0	0	---
21: DW Bruce Beach	15-May-23 11:35	5.0	1.53	---	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20984-MAY23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

12-May-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 09 May 2023

LR Report: CA20543-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583

Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-May-23	10-May-23	10-May-23
2: Analysis Start Time		---	---	09:55	09:55	09:25
3: Analysis Completed Date		---	---	12-May-23	12-May-23	12-May-23
4: Analysis Completed Time		---	---	11:37	11:37	11:37
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	08-May-23 11:25	9.2	---	0	0	---
7: TW Huronville South Treated Water	08-May-23 11:20	9.2	1.68	0	0	< 10
8: RW Murdock Glen Raw Water	08-May-23 11:55	9.2	---	0	0	---
9: TW Murdock Glen Treated Water	08-May-23 11:55	9.2	1.77	0	0	< 10
10: RW Blairs Grove Raw Water	08-May-23 13:25	9.2	---	0	0	---
11: TW Blairs Grove Treated Water	08-May-23 13:25	9.2	1.48	0	0	< 10
12: RW Point Clark Raw Water #2	08-May-23 14:10	9.2	---	0	0	---
13: RW Point Clark Raw Water #3	08-May-23 14:10	9.2	---	0	0	---
14: TW Point Clark Treated Water	08-May-23 14:10	9.2	1.73	0	0	< 10
15: DW DW Inverlyn CH	08-May-23 11:05	9.2	1.43	0	0	< 10
16: DW DW Chem Shed	08-May-23 13:30	9.2	1.51	0	0	< 10
17: DW Comm Center	08-May-23 13:55	9.2	1.43	0	0	< 10
18: DW Amberley Store	08-May-23 14:45	9.2	1.43	0	0	< 10
19: DW Amberley Beach	08-May-23 14:35	9.2	1.61	0	0	---
20: DW Birch St.	08-May-23 12:35	9.2	1.23	0	0	---
21: DW Bruce Beach	08-May-23 12:15	9.2	1.65	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20543-MAY23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

05-May-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 02 May 2023
LR Report: CA20211-MAY23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1


Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	03-May-23	03-May-23	03-May-23
2: Analysis Start Time		---	---	10:40	10:40	10:15
3: Analysis Completed Date		---	---	05-May-23	05-May-23	05-May-23
4: Analysis Completed Time		---	---	10:53	10:53	10:53
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	01-May-23 11:00	6.9	---	0	0	---
7: TW Huronville South Treated Water	01-May-23 11:00	6.9	1.58	0	0	< 10
8: RW Murdock Glen Raw Water	01-May-23 11:30	6.9	---	0	0	---
9: TW Murdock Glen Treated Water	01-May-23 11:30	6.9	1.74	0	0	< 10
10: RW Blairs Grove Raw Water	01-May-23 12:50	6.9	---	0	0	---
11: TW Blairs Grove Treated Water	01-May-23 12:50	6.9	1.51	0	0	10
12: RW Point Clark Raw Water #2	01-May-23 13:55	6.9	---	0	0	---
13: RW Point Clark Raw Water #3	01-May-23 13:55	6.9	---	1	0	---
14: TW Point Clark Treated Water	01-May-23 13:50	6.9	1.71	0	0	< 10
15: DW DW Inverlyn CH	01-May-23 11:15	6.9	1.36	0	0	< 10
16: DW DW Chem Shed	01-May-23 13:20	6.9	1.47	0	0	< 10
17: DW Comm Center	01-May-23 13:35	6.9	1.32	0	0	< 10
18: DW Amberley Store	01-May-23 14:20	6.9	1.51	0	0	< 10
19: DW Amberley Beach	01-May-23 14:10	6.9	1.64	0	0	---
20: DW Birch St.	01-May-23 12:10	6.9	1.36	0	0	---
21: DW Bruce beach	01-May-23 11:45	6.9	1.46	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

**SGS Canada Inc.**

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425**LR Report :** CA20211-MAY23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-April-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 25 April 2023

LR Report: CA21211-APR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583

Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Apr-23	26-Apr-23	26-Apr-23
2: Analysis Start Time		---	---	09:55	09:55	09:25
3: Analysis Completed Date		---	---	28-Apr-23	28-Apr-23	28-Apr-23
4: Analysis Completed Time		---	---	09:36	09:36	09:36
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	24-Apr-23 11:10	7.6	---	0	0	---
7: TW Huronville South Treated Water	24-Apr-23 11:10	7.6	1.63	0	0	10
8: RW Murdock Glen Raw Water	24-Apr-23 11:55	7.6	---	0	0	---
9: TW Murdock Glen Treated Water	24-Apr-23 11:55	7.6	1.61	0	0	< 10
10: RW Blairs Grove Raw Water	24-Apr-23 12:40	7.6	---	0	0	---
11: TW Blairs Grove Treated Water	24-Apr-23 12:35	7.6	1.47	0	0	< 10
12: RW Point Clark Raw Water #2	24-Apr-23 13:00	7.6	---	0	0	---
13: RW Point Clark Raw Water #3	24-Apr-23 13:00	7.6	---	0	0	---
14: TW Point Clark Treated Water	24-Apr-23 13:00	7.6	1.71	0	0	< 10
15: DW DW Inverlyn CH	24-Apr-23 11:00	7.6	1.43	0	0	< 10
16: DW DW Chem Shed	24-Apr-23 12:50	7.6	1.33	0	0	< 10
17: DW Comm Center	24-Apr-23 12:55	7.6	1.26	0	0	< 10
18: DW Amberley Store	24-Apr-23 13:25	7.6	1.39	0	0	< 10
19: DW Amberley Beach	24-Apr-23 13:15	7.6	1.55	0	0	---
20: DW Birch St.	24-Apr-23 12:30	7.6	1.27	0	0	---
21: DW Bruce Beach	24-Apr-23 12:10	7.6	1.22	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21211-APR23

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-April-2023

Veolia Water (Lakeshore)
Attn : Gary Nicholson

Date Rec. : 21 April 2023

LR Report: CA21017-APR23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #2

Phone: 519-524-6583

Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report


Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	21-Apr-23	21-Apr-23	21-Apr-23
2: Analysis Start Time		---	---	11:35	11:35	11:15
3: Analysis Completed Date		---	---	24-Apr-23	24-Apr-23	24-Apr-23
4: Analysis Completed Time		---	---	11:48	11:48	11:48
5: MAC		---	---	0	0	---
6: RESAMPLE TW HS TW	20-Apr-23 13:40	3.1	1.71	0	0	NDOGHPC
7: RESAMPLE DW Inverlyn CH	20-Apr-23 13:25	3.1	1.70	0	0	< 10
8: RESAMPLE DW 161 Carloway	20-Apr-23 13:30	3.1	1.72	0	0	---

MAC - Maximum Acceptable Concentration

NDOGHPC - No Data: Overgrown with HPC

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-April-2023
Veolia Water (Lakeshore)
Attn : Gary Nicholson
Date Rec. : 20 April 2023

LR Report: CA20961-APR23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #2

Phone: 519-524-6583

Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report


Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date		---	---	20-Apr-23	20-Apr-23
2: Analysis Start Time		---	---	12:50	12:50
3: Analysis Completed Date		---	---	24-Apr-23	24-Apr-23
4: Analysis Completed Time		---	---	11:02	11:02
5: MAC		---	---	0	0
6: NR PC Well 2 #1	19-Apr-23 08:35	10.9	0.66	0	0
7: NR PC Well 2 #2	19-Apr-23 09:05	10.9	0.27	0	0
8: RW Blairs Grove Raw	19-Apr-23 11:20	10.9	0.69	0	0

MAC - Maximum Acceptable Concentration

NR - Not reportable under applicable Provincial drinking water regulations as per client.

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

21-April-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 18 April 2023
LR Report: CA20854-APR23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	19-Apr-23	19-Apr-23	19-Apr-23
2: Analysis Start Time		---	---	09:55	09:55	09:30
3: Analysis Completed Date		---	---	21-Apr-23	21-Apr-23	21-Apr-23
4: Analysis Completed Time		---	---	10:48	10:48	10:48
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	17-Apr-23 11:20	6.6	---	0	0	---
7: TW Huronville South Treated Water	17-Apr-23 11:20	6.6	1.64	0	0	< 10
8: RW Murdock Glen Raw Water	17-Apr-23 11:40	6.6	---	0	0	---
9: TW Murdock Glen Treated Water	17-Apr-23 11:40	6.6	1.71	0	0	< 10
10: TW Blairs Grove Treated Water	17-Apr-23 12:50	6.6	1.45	0	0	< 10
11: RW Point Clark Raw Water #3	17-Apr-23 13:20	6.6	---	0	0	---
12: TW Point Clark Treated Water	17-Apr-23 13:20	6.6	1.70	0	0	< 10
13: DW DW Inverlyn CH	17-Apr-23 11:15	6.6	1.46	1 MAC	0	< 10
14: DW DW Chem Shed	17-Apr-23 13:05	6.6	1.41	0	0	< 10
15: DW Comm Center	17-Apr-23 11:00	6.6	1.42	0	0	< 10
16: DW Amberley Store	17-Apr-23 13:50	6.6	1.49	0	0	< 10
17: DW Amberley Beach	17-Apr-23 13:40	6.6	1.62	0	0	---
18: DW Birch St.	17-Apr-23 12:20	6.6	1.59	0	0	---
19: DW Bruce Beach	17-Apr-23 12:10	6.6	1.70	0	0	---

MAC - Maximum Acceptable Concentration

MAC - (ADVERSE) Above Maximum Acceptable Concentration

The AWQI # assigned by the MOECP for the adverse result is: 161785



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20854-APR23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-April-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 11 April 2023
LR Report: CA20431-APR23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1


Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	12-Apr-23	12-Apr-23	12-Apr-23
2: Analysis Start Time		---	---	---	10:20	10:20	09:55
3: Analysis Completed Date		---	---	---	14-Apr-23	14-Apr-23	14-Apr-23
4: Analysis Completed Time		---	---	---	12:24	12:24	12:24
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	10-Apr-23 11:15	10.1	---	0.22	0	0	---
7: TW Huronville South Treated Water	10-Apr-23 11:15	10.1	1.61	0.23	0	0	20
8: RW Murdock Glen Raw Water	10-Apr-23 11:30	10.1	---	0.19	0	0	---
9: TW Murdock Glen Treated Water	10-Apr-23 11:30	10.1	1.71	0.25	0	0	>2000
10: TW Blairs Grove Treated Water	10-Apr-23 12:10	10.1	1.51	0.34	0	0	< 10
11: RW Point Clark Raw Water #2	10-Apr-23 13:30	10.1	---	0.23	0	0	---
12: RW Point Clark Raw Water #3	10-Apr-23 13:30	10.1	---	0.23	0	0	---
13: TW Point Clark Treated Water	10-Apr-23 13:30	10.1	1.71	0.26	0	0	< 10
14: DW DW Inverlyn CH	10-Apr-23 11:00	10.1	1.44	---	0	0	< 10
15: DW DW Chem Shed	10-Apr-23 12:20	10.1	1.54	---	0	0	< 10
16: DW Comm Center	10-Apr-23 12:25	10.1	1.37	---	0	0	< 10
17: DW Amberley Store	10-Apr-23 14:05	10.1	1.66	---	0	0	< 10
18: DW Amberley Beach	10-Apr-23 13:55	10.1	1.66	---	0	0	---
19: DW Birch St.	10-Apr-23 12:00	10.1	1.54	---	0	0	---
20: DW Bruce Beach	10-Apr-23 11:45	10.1	1.40	---	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20431-APR23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

10-April-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 04 April 2023
LR Report: CA20185-APR23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Apr-23	05-Apr-23	05-Apr-23
2: Analysis Start Time		---	---	09:55	09:55	09:20
3: Analysis Completed Date		---	---	10-Apr-23	10-Apr-23	10-Apr-23
4: Analysis Completed Time		---	---	09:49	09:49	09:49
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	03-Apr-23 11:05	7.6	---	0	0	---
7: TW Huronville South Treated Water	03-Apr-23 11:05	7.6	1.69	0	0	< 10
8: RW Murdock Glen Raw Water	03-Apr-23 11:30	7.6	---	0	0	---
9: TW Murdock Glen Treated Water	03-Apr-23 11:30	7.6	1.60	0	0	< 10
10: TW Blairs Grove Treated Water	03-Apr-23 12:40	7.6	1.50	0	0	< 10
11: RW Point Clark Raw Water #2	03-Apr-23 13:10	7.6	---	0	0	---
12: RW Point Clark Raw Water #3	03-Apr-23 13:10	7.6	---	2	0	---
13: TW Point Clark Treated Water	03-Apr-23 13:10	7.6	1.71	0	0	< 10
14: DW DW Inverlyn CH	03-Apr-23 11:00	7.6	1.56	0	0	< 10
15: DW DW Chem Shed	03-Apr-23 12:55	7.6	---	0	0	< 10
16: DW Comm Centre	03-Apr-23 13:00	7.6	1.37	0	0	< 10
17: DW Amberley Store	03-Apr-23 13:40	7.6	1.41	0	0	< 10
18: DW Amberley Beach	03-Apr-23 13:30	7.6	1.39	0	0	---
19: DW Birch St.	03-Apr-23 12:00	7.6	1.35	0	0	---
20: DW Bruce Beach	03-Apr-23 11:50	7.6	1.24	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001





SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20185-APR23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

31-March-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 28 March 2023
 LR Report: CA21204-MAR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	29-Mar-23	29-Mar-23	29-Mar-23
2: Analysis Start Time		---	---	10:10	10:10	09:45
3: Analysis Completed Date		---	---	31-Mar-23	31-Mar-23	31-Mar-23
4: Analysis Completed Time		---	---	09:41	09:41	09:41
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	27-Mar-23 11:25	8.4	---	0	0	---
7: TW Huronville South Treated Water	27-Mar-23 11:25	8.4	1.50	0	0	< 10
8: RW Murdock Glen Raw Water	27-Mar-23 11:45	8.4	---	0	0	---
9: TW Murdock Glen Treated Water	27-Mar-23 11:45	8.4	1.63	0	0	< 10
10: TW Blairs Grove Treated Water	27-Mar-23 12:20	8.4	1.60	0	0	< 10
11: RW Point Clark Raw Water #2	27-Mar-23 13:25	8.4	---	0	0	---
12: RW Point Clark Raw Water #3	27-Mar-23 13:25	8.4	---	0	0	---
13: TW Point Clark Treated Water	27-Mar-23 13:25	8.4	1.81	0	0	< 10
14: DW DW Inverlyn CH	27-Mar-23 11:10	8.4	1.45	0	0	< 10
15: DW DW Chem Shed	27-Mar-23 13:00	8.4	1.49	0	0	< 10
16: DW Comm Center	27-Mar-23 13:10	8.4	1.38	0	0	< 10
17: DW Amberley Store	27-Mar-23 14:05	8.4	1.48	0	0	< 10
18: DW Amberley Beach	27-Mar-23 13:55	8.4	1.57	0	0	---
19: DW Birch St	27-Mar-23 12:15	8.4	1.38	0	0	---
20: DW Bruce Beach	27-Mar-23 12:00	8.4	1.47	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21204-MAR23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-March-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 21 March 2023
LR Report: CA20909-MAR23

100 Cove Rd., Goderich
Canada, N7A 3Z2
Phone: 519-524-6583, Fax:519-524-9358

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	22-Mar-23	22-Mar-23	22-Mar-23
2: Analysis Start Time		---	---	---	10:15	10:15	09:50
3: Analysis Completed Date		---	---	---	24-Mar-23	24-Mar-23	24-Mar-23
4: Analysis Completed Time		---	---	---	12:38	12:38	12:38
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	20-Mar-23 11:05	8.4	---	0.21	0	0	---
7: TW Huronville South Treated Water	20-Mar-23 11:05	8.4	1.75	0.25	0	0	< 10
8: RW Murdock Glen Raw Water	20-Mar-23 11:30	8.4	---	0.22	0	0	---
9: TW Murdock Glen Treated Treated	20-Mar-23 11:30	8.4	1.61	0.26	0	0	10
10: TW Blairs Grove Treated Water	20-Mar-23 12:10	8.4	1.64	0.39	0	0	< 10
11: RW Point Clark Raw Water #2	20-Mar-23 13:05	8.4	---	0.23	0	0	---
12: RW Point Clark Raw Water #3	20-Mar-23 13:05	8.4	---	0.19	1	0	---
13: TW Point Clark Treated Water	20-Mar-23 13:05	8.4	1.93	0.25	0	0	< 10
14: DW DW Inverlyn CH	20-Mar-23 11:00	8.4	1.71	---	0	0	< 10
15: DW DW Chem Shed	20-Mar-23 12:45	8.4	1.46	---	0	0	< 10
16: DW Comm Center	20-Mar-23 13:00	8.4	1.26	---	0	0	< 10
17: DW Amberley Store	20-Mar-23 13:30	8.4	1.26	---	0	0	< 10
18: DW Amberley Beach	20-Mar-23 13:20	8.4	1.42	---	0	0	---
19: DW Birch St	20-Mar-23 12:00	8.4	1.31	---	0	0	---
20: DW Bruce Beach	20-Mar-23 11:50	8.4	1.38	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001





SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20909-MAR23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-March-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 14 March 2023
 LR Report: CA20595-MAR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	15-Mar-23	15-Mar-23	15-Mar-23
2: Analysis Start Time		---	---	---	10:25	10:25	10:00
3: Analysis Completed Date		---	---	---	17-Mar-23	17-Mar-23	17-Mar-23
4: Analysis Completed Time		---	---	---	10:13	10:13	10:13
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	13-Mar-23 11:00	11.4	---	0.19	0	0	---
7: TW Huronville South Treated Water	13-Mar-23 11:00	11.4	1.75	0.25	0	0	< 10
8: RW Murdock Glen Raw Water	13-Mar-23 11:30	11.4	---	0.22	0	0	---
9: TW Murdock Glen Treated Water	13-Mar-23 11:30	11.4	1.56	0.29	0	0	< 10
10: TW Blairs Grove Treated Water	13-Mar-23 12:10	11.4	1.62	0.36	0	0	< 10
11: RW Point Clark Raw Water #2	13-Mar-23 13:10	11.4	---	0.23	0	0	---
12: RW Point Clark Raw Water #3	13-Mar-23 13:10	11.4	---	0.22	0	0	---
13: TW Point Clark Treated Water	13-Mar-23 13:10	11.4	1.90	0.29	0	0	< 10
14: DW DW Inverlyn CH	13-Mar-23 11:20	11.4	1.45	---	0	0	< 10
15: DW DW Chem Shed	13-Mar-23 12:55	11.4	1.47	---	0	0	< 10
16: DW Comm Center	13-Mar-23 13:00	11.4	1.10	---	0	0	< 10
17: DW Amberley Store	13-Mar-23 14:00	11.4	1.26	---	0	0	< 10
18: DW Amberley Beach	13-Mar-23 13:45	11.4	1.33	---	0	0	---
19: DW Birch St	13-Mar-23 12:05	11.4	1.29	---	0	0	---
20: DW Bruce Beach	13-Mar-23 11:50	11.4	1.41	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20595-MAR23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Veolia Water (Lakeshore)

Attn : Gary Nicholson

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Phone: 519-524-6583
Fax: 519-524-9358

Works #: 220000425

13-March-2023

Date Rec. : 07 March 2023
LR Report: CA20323-MAR23

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	08-Mar-23	08-Mar-23	08-Mar-23
2: Analysis Start Time		---	---	---	10:00	10:00	09:30
3: Analysis Completed Date		---	---	---	10-Mar-23	10-Mar-23	10-Mar-23
4: Analysis Completed Time		---	---	---	12:38	12:38	12:38
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	06-Mar-23 11:00	10.6	---	0.23	0	0	---
7: TW Huronville South Treated Water	06-Mar-23 11:00	10.6	1.82	0.25	0	0	< 10
8: RW Murdock Glen Raw Water	06-Mar-23 11:25	10.6	---	0.21	0	0	---
9: TW Murdock Glen Treated Water	06-Mar-23 11:25	10.6	1.65	0.22	0	0	< 10
10: TW Blairs Grove Treated Water	06-Mar-23 12:40	10.6	1.55	0.31	0	0	< 10
11: RW Point Clark Raw Water #2	06-Mar-23 13:20	10.6	---	0.22	0	0	---
12: RW Point Clark Raw Water #3	06-Mar-23 13:20	10.6	---	0.21	0	0	---
13: TW Point Clark Treated Water	06-Mar-23 13:15	10.6	1.85	0.27	0	0	< 10
14: DW DW Inverlyn CH	06-Mar-23 11:20	10.6	1.71	---	0	0	< 10
15: DW DW Chem Shed	06-Mar-23 12:55	10.6	1.47	---	0	0	< 10
16: DW Comm Center	06-Mar-23 13:00	10.6	1.57	---	0	0	< 10
17: DW Amberley Store	06-Mar-23 13:55	10.6	1.70	---	0	0	< 10
18: DW Amberley Beach	06-Mar-23 13:40	10.6	1.76	---	0	0	---
19: DW Birch St.	06-Mar-23 12:00	10.6	1.30	---	0	0	---
20: DW Bruce Beach	06-Mar-23 11:45	10.6	1.55	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Phone: 519-524-6583
Fax: 519-524-9358

Works #: 220000425

03-March-2023

Date Rec. : 28 February 2023

LR Report: CA20008-MAR23

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report


Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	01-Mar-23	01-Mar-23	01-Mar-23
2: Analysis Start Time		---	---	---	10:10	10:10	09:50
3: Analysis Completed Date		---	---	---	03-Mar-23	03-Mar-23	03-Mar-23
4: Analysis Completed Time		---	---	---	11:22	11:22	11:22
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	27-Feb-23 11:05	10.6	---	0.21	0	0	---
7: TW Huronville South Treated Water	27-Feb-23 11:05	10.6	1.71	0.29	0	0	< 10
8: RW Murdock Glen Raw Water	27-Feb-23 11:35	10.6	---	0.20	0	0	---
9: TW Murdock Glen Treated Water	27-Feb-23 11:35	10.6	1.53	0.22	0	0	< 10
10: TW Blairs Grove Treated Water	27-Feb-23 12:15	10.6	1.60	0.31	0	0	< 10
11: RW Point Clark Raw Water #2	27-Feb-23 13:20	10.6	---	0.20	0	0	---
12: RW Point Clark Raw Water #3	27-Feb-23 13:20	10.6	---	0.20	0	0	---
13: TW Point Clark Treated Water	27-Feb-23 13:20	10.6	1.88	0.24	0	0	< 10
14: DW DW Inverlyn CH	27-Feb-23 11:00	10.6	1.32	---	0	0	< 10
15: DW DW Chem Shed	27-Feb-23 12:55	10.6	1.50	---	0	0	< 10
16: DW Comm Center	27-Feb-23 13:05	10.6	1.51	---	0	0	< 10

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
17: DW Amberley Store	27-Feb-23 14:15	10.6	1.63	---	0	0	< 10
18: DW Amberley Beach	27-Feb-23 14:05	10.6	1.57	---	0	0	---
19: DW Birch St	27-Feb-23 12:10	10.6	1.55	---	0	0	---
20: DW Bruce Beach	27-Feb-23 11:55	10.6	1.49	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


 Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-February-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 21 February 2023
 LR Report: CA20795-FEB23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	22-Feb-23	22-Feb-23	22-Feb-23
2: Analysis Start Time		---	---	---	11:15	11:15	10:35
3: Analysis Completed Date		---	---	---	24-Feb-23	24-Feb-23	24-Feb-23
4: Analysis Completed Time		---	---	---	14:12	14:12	14:12
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	21-Feb-23 08:50	9.1	---	0.24	0	0	---
7: TW Huronville South Treated Water	21-Feb-23 08:50	9.1	1.61	0.25	0	0	< 10
8: RW Murdock Glen Raw Water	21-Feb-23 08:10	9.1	---	0.17	0	0	---
9: TW Murdock Glen Treated Water	21-Feb-23 08:10	9.1	1.56	0.25	0	0	20
10: TW Blairs Grove Treated Water	21-Feb-23 07:20	9.1	1.60	0.39	0	0	< 10
11: RW Point Clark Raw Water #2	21-Feb-23 06:40	9.1	---	0.19	0	0	---
12: RW Point Clark Raw Water #3	21-Feb-23 06:40	9.1	---	0.22	0	0	---
13: TW Point Clark Treated Water	21-Feb-23 06:40	9.1	1.85	0.26	0	0	< 10
14: DW DW Comm Center	21-Feb-23 07:05	9.1	1.60	---	0	0	< 10
15: DW DW Chem Center	21-Feb-23 07:10	9.1	1.55	---	0	0	< 10
16: DW Inverlyn CH	21-Feb-23 08:30	9.1	1.27	---	0	0	< 10
17: DW Amberley Store	21-Feb-23 06:20	9.1	1.74	---	0	0	< 10
18: DW Amberley Beach	21-Feb-23 06:30	9.1	1.65	---	0	0	---
19: DW Birch St.	21-Feb-23 07:45	9.1	1.46	---	0	0	---
20: DW Bruce Beach	21-Feb-23 08:00	9.1	1.43	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001





SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20795-FEB23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-February-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 14 February 2023
LR Report: CA20596-FEB23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report


Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	15-Feb-23	15-Feb-23	15-Feb-23
2: Analysis Start Time		---	---	---	10:50	10:50	10:10
3: Analysis Completed Date		---	---	---	17-Feb-23	17-Feb-23	17-Feb-23
4: Analysis Completed Time		---	---	---	10:46	10:46	10:46
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	13-Feb-23 11:20	9.7	---	0.20	0	0	---
7: TW Huronville South Treated Water	13-Feb-23 11:20	9.7	---	0.22	0	0	< 10
8: RW Murdock Glen Raw Water	13-Feb-23 11:50	9.7	---	0.21	0	0	---
9: TW Murdock Glen Treated Water	13-Feb-23 11:50	9.7	---	0.29	0	0	< 10
10: TW Blairs Grove Treated Water	13-Feb-23 12:25	9.7	---	0.37	0	0	NDLA
11: RW Point Clark Raw Water #2	13-Feb-23 13:50	9.7	---	0.20	0	0	---
12: RW Point Clark Raw Water #3	13-Feb-23 13:50	9.7	---	0.21	0	0	---
13: TW Point Clark Treated Water	13-Feb-23 13:50	9.7	---	0.26	0	0	< 10
14: DW DW Inverlyn CH	13-Feb-23 11:00	9.7	---	---	0	0	< 10
15: DW DW Chem Shed	13-Feb-23 13:10	9.7	---	---	0	0	< 10
16: DW Comm Center	13-Feb-23 13:25	9.7	---	---	0	0	< 10
17: DW Amberley Store	13-Feb-23 14:25	9.7	---	---	0	0	< 10
18: DW Amberley Beach	13-Feb-23 14:15	9.7	---	---	0	0	---
19: DW Birch St.	13-Feb-23 12:15	9.7	---	---	0	0	---
20: DW Bruce Beach	13-Feb-23 12:00	9.7	---	---	0	0	---

MAC - Maximum Acceptable Concentration

NDLA - No Data: Laboratory Accident/Error(Sample 10 HPC)

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001





SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20596-FEB23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

10-February-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 07 February 2023
LR Report: CA20310-FEB23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1


Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Feb-23	08-Feb-23	08-Feb-23
2: Analysis Start Time		---	---	10:10	10:10	09:45
3: Analysis Completed Date		---	---	10-Feb-23	10-Feb-23	10-Feb-23
4: Analysis Completed Time		---	---	09:14	09:14	09:14
5: MAC		---	---	0	0	---
6: RW Huronville South Raw Water	06-Feb-23 11:05	8.7	---	0	0	---
7: TW Huronville South Treated Water	06-Feb-23 11:05	8.7	1.35	0	0	< 10
8: RW Murdock Glen Raw South	06-Feb-23 11:25	8.7	---	0	0	---
9: TW Murdock Glen Treated	06-Feb-23 11:25	8.7	1.70	0	0	< 10
10: TW Blairs Grove Treated Water	06-Feb-23 11:50	8.7	1.61	0	0	< 10
11: RW Point Clark Raw Water #2	06-Feb-23 13:10	8.7	---	0	0	---
12: RW Point Clark Raw Water #3	06-Feb-23 13:10	8.7	---	0	0	---
13: TW Point Clark Treated Water	06-Feb-23 13:10	8.7	1.94	0	0	< 10
14: DW Inverlyn CH	06-Feb-23 11:00	8.7	1.53	0	0	< 10
15: DW Chem Ched	06-Feb-23 12:30	8.7	1.37	0	0	< 10
16: DW Comm Center	06-Feb-23 12:55	8.7	1.78	0	0	< 10
17: DW Amberley Store	06-Feb-23 13:40	8.7	1.76	0	0	< 10
18: DW Amberley beach	06-Feb-23 13:30	8.7	1.77	0	0	---
19: DW Birch St	06-Feb-23 11:40	8.7	1.17	0	0	---
20: DW Bruce Beach	06-Feb-23 11:30	8.7	1.13	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

**SGS Canada Inc.**

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425**LR Report :** CA20310-FEB23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

03-February-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 31 January 2023
 LR Report: CA20000-FEB23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	01-Feb-23	01-Feb-23	01-Feb-23
2: Analysis Start Time		---	---	---	10:00	10:00	09:35
3: Analysis Completed Date		---	---	---	03-Feb-23	03-Feb-23	03-Feb-23
4: Analysis Completed Time		---	---	---	10:40	10:40	10:40
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	30-Jan-23 11:00	5.8	---	0.26	0	0	---
7: TW Huronville South Treated Water	30-Jan-23 13:30	5.8	1.42	0.27	0	0	< 10
8: RW Murdock Glen Raw Water	30-Jan-23 11:30	5.8	---	0.21	0	0	---
9: TW Murdock Glen Treated Water	30-Jan-23 11:25	5.8	1.71	0.25	0	0	< 10
10: TW Blairs Grove Treated Water	30-Jan-23 12:55	5.8	1.55	0.35	0	0	< 10
11: RW Point Clark Raw Water #2	30-Jan-23 15:15	5.8	---	0.22	0	0	---
12: RW Point Clark Raw Water #3	30-Jan-23 15:15	5.8	---	0.21	0	0	---
13: TW Point Clark Treated Water	30-Jan-23 15:15	5.8	1.80	0.29	0	0	< 10
14: DW DW Inverlyn CH	30-Jan-23 11:15	5.8	1.67	---	0	0	< 10
15: DW DW Chem Shed	30-Jan-23 13:10	5.8	1.49	---	0	0	< 10
16: DW Comm Center	30-Jan-23 13:55	5.8	1.47	---	0	0	< 10
17: DW Amberley Store	30-Jan-23 15:35	5.8	1.62	---	0	0	< 10
18: DW Amberley Beach	30-Jan-23 15:30	5.8	1.72	---	0	0	---
19: DW Birch St.	30-Jan-23 12:15	5.8	1.47	---	0	0	---
20: DW Bruce Beach	30-Jan-23 11:55	5.8	1.49	---	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

**SGS Canada Inc.**

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425**LR Report :** CA20000-FEB23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

27-January-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 24 January 2023
 LR Report: CA21055-JAN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	25-Jan-23	25-Jan-23	25-Jan-23
2: Analysis Start Time		---	---	---	09:45	09:45	09:20
3: Analysis Completed Date		---	---	---	27-Jan-23	27-Jan-23	27-Jan-23
4: Analysis Completed Time		---	---	---	12:08	12:08	12:08
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	24-Jan-23 10:45	9.7	---	0.21	0	0	---
7: TW Huronville South Treated Water	24-Jan-23 10:45	9.7	1.60	0.25	0	0	20
8: RW Murdock Glen Raw Water	24-Jan-23 10:00	9.7	---	0.20	0	0	---
9: TW Murdock Glen Treated Water	24-Jan-23 10:00	9.7	1.77	0.25	0	0	< 10
10: TW Blairs Grove Treated Water	24-Jan-23 09:25	9.7	1.57	0.39	0	0	< 10
11: RW Point Clark Raw Water #2	24-Jan-23 09:00	9.7	---	0.21	0	0	---
12: RW Point Clark Raw Water #3	24-Jan-23 09:00	9.7	---	0.20	2	0	---
13: TW Point Clark Treated Water	24-Jan-23 08:55	9.7	1.34	0.25	0	0	< 10
14: DW DW Comm Center	24-Jan-23 09:10	9.7	1.44	---	0	0	< 10
15: DW DW Chem Shed	24-Jan-23 09:20	9.7	1.44	---	0	0	< 10
16: DW Inverlyn CH	24-Jan-23 10:25	9.7	1.65	---	0	0	< 10
17: DW Amberley Store	24-Jan-23 08:15	9.7	1.49	---	0	0	< 10
18: DW Amberley Beach	24-Jan-23 08:25	9.7	1.72	---	0	0	---
19: DW Bruce Beach	24-Jan-23 09:55	9.7	1.71	---	0	0	---
20: DW 766 Lake Range	23-Jan-23 13:20	9.7	1.59	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21055-JAN23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

20-January-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 17 January 2023
 LR Report: CA20781-JAN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	18-Jan-23	18-Jan-23	18-Jan-23
2: Analysis Start Time		---	---	---	10:30	10:30	09:55
3: Analysis Completed Date		---	---	---	20-Jan-23	20-Jan-23	20-Jan-23
4: Analysis Completed Time		---	---	---	08:59	08:59	10:21
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	16-Jan-23 14:30	9.0	---	0.29	0	0	---
7: TW Huronville South Treated Water	16-Jan-23 14:30	9.0	1.64	0.23	0	0	< 10
8: RW Murdock Glen Raw Water	16-Jan-23 14:40	9.0	---	0.25	0	0	---
9: TW Murdock Glen Treated Water	16-Jan-23 14:40	9.0	1.80	0.27	0	0	< 10
10: TW Blairs Grove Treated Water	16-Jan-23 15:10	9.0	1.49	0.37	0	0	< 10
11: RW Point Clark Raw Water #2	17-Jan-23 08:25	9.0	---	0.24	0	0	---
12: RW Point Clark Raw Water #3	17-Jan-23 08:25	9.0	---	0.26	0	0	---
13: TW Point Clark Treated Water	17-Jan-23 08:25	9.0	1.75	0.29	0	0	< 10
14: DW DW Inverlyn CH	17-Jan-23 14:20	9.0	1.60	---	0	0	< 10
15: DW DW Cher Shed	17-Jan-23 15:20	9.0	1.35	---	0	0	< 10
16: DW Comm Center	16-Jan-23 15:25	9.0	1.54	---	0	0	< 10
17: DW Amberley Store	17-Jan-23 08:10	9.0	1.58	---	0	0	< 10
18: DW Amberley Beach	17-Jan-23 08:20	9.0	1.49	---	0	0	---
19: DW Birch St	17-Jan-23 15:05	9.0	1.37	---	0	0	---
20: DW Bruce Beach	17-Jan-23 14:50	9.0	1.66	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20781-JAN23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

13-January-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 10 January 2023
LR Report: CA20459-JAN23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	11-Jan-23	11-Jan-23	11-Jan-23
2: Analysis Start Time		---	---	---	10:35	10:35	10:10
3: Analysis Completed Date		---	---	---	13-Jan-23	13-Jan-23	13-Jan-23
4: Analysis Completed Time		---	---	---	10:07	10:07	10:07
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	09-Jan-23 13:05	9.6	---	0.25	0	0	---
7: TW Huronville South Treated Water	09-Jan-23 13:05	9.6	1.55	0.25	0	0	< 10
8: RW Murdock Glen Raw Water	09-Jan-23 12:15	9.6	---	0.19	1	0	---
9: TW Murdock Glen Treated Water	09-Jan-23 12:15	9.6	1.37	0.23	0	0	< 10
10: TW Blairs Grove Treated Water	09-Jan-23 11:45	9.6	1.53	0.37	0	0	< 10
11: RW Point Clark Raw Water #2	09-Jan-23 13:45	9.6	---	0.21	0	0	---
12: RW Point Clark Raw Water #3	09-Jan-23 13:45	9.6	---	0.21	6	0	---
13: TW Point Clark Treated Water	09-Jan-23 13:45	9.6	1.80	0.27	0	0	< 10
14: DW DW Inverlyn CH	09-Jan-23 12:40	9.6	1.55	---	0	0	< 10
15: DW DW Comm Center	09-Jan-23 11:05	9.6	1.40	---	0	0	< 10
16: DW Chem Shed	09-Jan-23 11:20	9.6	1.33	---	0	0	< 10
17: DW Amberley Stone	09-Jan-23 14:20	9.6	1.37	---	0	0	< 10
18: DW Amberley Beach	09-Jan-23 14:05	9.6	1.51	---	0	0	---
19: DW Birch St.	09-Jan-23 11:25	9.6	1.44	---	0	0	---
20: DW Bruce Beach	09-Jan-23 12:00	9.6	1.55	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20459-JAN23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-January-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 03 January 2023
 LR Report: CA20099-JAN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	04-Jan-23	04-Jan-23	04-Jan-23
2: Analysis Start Time		---	---	---	15:15	15:15	14:35
3: Analysis Completed Date		---	---	---	06-Jan-23	06-Jan-23	06-Jan-23
4: Analysis Completed Time		---	---	---	14:26	14:26	14:26
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	03-Jan-23 08:10	10.8	---	0.19	0	0	---
7: TW Huronville South Treated Water	03-Jan-23 08:10	10.8	1.61	0.26	0	0	< 10
8: RW Murdock Glen Raw Water	03-Jan-23 08:25	10.8	---	0.22	0	0	---
9: TW Murdock Glen Treated Water	03-Jan-23 08:25	10.8	1.75	0.27	0	0	< 10
10: TW Blairs Grove Treated Water	03-Jan-23 09:10	10.8	1.44	0.33	0	0	< 10
11: RW Point Clark Raw Water #2	03-Jan-23 09:30	10.8	---	0.19	0	0	---
12: RW Point Clark Raw Water #3	03-Jan-23 09:30	10.8	---	0.22	0	0	---
13: TW Point Clark Treated Water	03-Jan-23 09:30	10.8	1.83	0.29	0	0	< 10
14: DW DW Inverlyn CH	03-Jan-23 08:00	10.8	1.65	---	0	0	< 10
15: DW DW Chem Shed	03-Jan-23 08:50	10.8	1.45	---	0	0	< 10
16: DW Comm Center	03-Jan-23 09:20	10.8	1.22	---	0	0	< 10
17: DW Amberley Store	03-Jan-23 10:00	10.8	1.60	---	0	0	< 10
18: DW Amberley Beach	03-Jan-23 09:50	10.8	1.71	---	0	0	---
19: DW Birch St.	03-Jan-23 08:55	10.8	1.46	---	0	0	---
20: DW Bruce Beach	03-Jan-23 08:40	10.8	1.60	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20099-JAN23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

03-January-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 28 December 2022
LR Report: CA21138-DEC22

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1


Phone: 519-524-6583
Fax: 519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	29-Dec-22	29-Dec-22	29-Dec-22
2: Analysis Start Time		---	---	---	13:40	13:40	13:05
3: Analysis Completed Date		---	---	---	30-Dec-22	30-Dec-22	03-Jan-23
4: Analysis Completed Time		---	---	---	14:51	14:51	13:21
5: MAC		---	---	---	0	0	---
6: RW Huronville South Raw Water	28-Dec-22 10:15	10.1	---	0.22	0	0	---
7: TW Huronville South Treated Water	28-Dec-22 10:15	10.1	1.60	0.27	0	0	< 10
8: RW Murdock Glen Raw Water	28-Dec-22 09:30	10.1	---	0.15	0	0	---
9: TW Murdock Glen Treated Water	28-Dec-22 09:30	10.1	1.77	0.29	0	0	< 10
10: TW Blairs Grove Treated Water	28-Dec-22 08:50	10.1	1.48	0.35	0	0	10
11: RW Point Clark Raw Water #2	28-Dec-22 08:15	10.1	---	0.17	0	0	---
12: RW Point Clark Raw Water #3	28-Dec-22 08:15	10.1	---	0.19	0	0	---
13: TW Point Clark Treated Water	28-Dec-22 08:10	10.1	1.66	0.27	0	0	< 10
14: DW DW Amberley Store	28-Dec-22 07:50	10.1	1.51	---	0	0	10
15: DW DW Inverlyn CH	28-Dec-22 09:55	10.1	1.47	---	0	0	< 10
16: DW Comm Center	28-Dec-22 10:45	10.1	1.24	---	0	0	< 10
17: DW Chem Shed	28-Dec-22 08:45	10.1	1.36	---	0	0	< 10
18: DW Amberley Store	28-Dec-22 08:00	10.1	1.64	---	0	0	---
19: DW Birch St	28-Dec-22 09:10	10.1	1.41	---	0	0	---
20: DW Bruce Beach	28-Dec-22 09:25	10.1	1.41	---	0	0	---

MAC - Maximum Acceptable Concentration



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

**SGS Canada Inc.**

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425**LR Report :** CA21138-DEC22

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001