

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

15-September-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 12 September 2023
 LR Report: CA20558-SEP23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 13-Sep-23 | 13-Sep-23 | 13-Sep-23 |
| 2: Analysis Start Time | | --- | --- | --- | 09:30 | 09:30 | 09:10 |
| 3: Analysis Completed Date | | --- | --- | --- | 15-Sep-23 | 15-Sep-23 | 15-Sep-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 11:25 | 11:25 | 11:25 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 11-Sep-23 11:05 | 5.8 | --- | 0.19 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 11-Sep-23 11:05 | 5.8 | 1.46 | 0.22 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 11-Sep-23 11:30 | 5.8 | --- | 0.21 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 11-Sep-23 11:30 | 5.8 | 1.73 | 0.25 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 11-Sep-23 12:15 | 5.8 | --- | 0.37 | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 11-Sep-23 12:15 | 5.8 | 1.05 | 0.44 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 11-Sep-23 13:25 | 5.8 | --- | 0.20 | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 11-Sep-23 13:25 | 5.8 | --- | 0.19 | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 11-Sep-23 13:25 | 5.8 | 1.59 | 0.25 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 11-Sep-23 11:00 | 5.8 | 1.49 | --- | 0 | 0 | < 10 |
| 16: DW DW Chem Shed | 11-Sep-23 12:25 | 5.8 | 1.21 | --- | 0 | 0 | < 10 |
| 17: DW Comm Center | 11-Sep-23 12:50 | 5.8 | 1.29 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Store | 11-Sep-23 14:00 | 5.8 | 1.19 | --- | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 11-Sep-23 13:50 | 5.8 | 1.38 | --- | 0 | 0 | --- |
| 20: DW Birch St. | 11-Sep-23 12:05 | 5.8 | 1.17 | --- | 0 | 0 | --- |
| 21: DW Bruce Beach | 11-Sep-23 11:45 | 5.8 | 1.53 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20558-SEP23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

08-September-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 05 September 2023
 LR Report: CA20092-SEP23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 06-Sep-23 | 06-Sep-23 | 06-Sep-23 |
| 2: Analysis Start Time | | --- | --- | 11:35 | 11:35 | 11:10 |
| 3: Analysis Completed Date | | --- | --- | 08-Sep-23 | 08-Sep-23 | 08-Sep-23 |
| 4: Analysis Completed Time | | --- | --- | 11:27 | 11:27 | 11:27 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 05-Sep-23 07:30 | 13.9 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 05-Sep-23 07:35 | 13.9 | 1.55 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 05-Sep-23 08:20 | 13.9 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 05-Sep-23 08:25 | 13.9 | 1.68 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 05-Sep-23 09:05 | 13.9 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 05-Sep-23 09:00 | 13.9 | 1.24 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 05-Sep-23 10:25 | 13.9 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 05-Sep-23 10:30 | 13.9 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 05-Sep-23 10:15 | 13.9 | 1.44 | 0 | 0 | < 10 |
| 15: DW DW PC Rec Center | 05-Sep-23 08:50 | 13.9 | 1.33 | 0 | 0 | 10 |
| 16: DW DW Chem Shed | 05-Sep-23 09:30 | 13.9 | 1.10 | 0 | 0 | 10 |
| 17: DW 157 Carkeyway | 05-Sep-23 10:00 | 13.9 | 1.47 | 0 | 0 | < 10 |
| 18: DW 530 Attawandron | 05-Sep-23 10:45 | 13.9 | 1.57 | 0 | 0 | < 10 |
| 19: DW Amberley Beach SS | 05-Sep-23 10:55 | 13.9 | 1.33 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20092-SEP23

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

01-September-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 29 August 2023
 LR Report: CA21682-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 30-Aug-23 | 30-Aug-23 | 30-Aug-23 |
| 2: Analysis Start Time | | --- | --- | 09:50 | 09:50 | 09:15 |
| 3: Analysis Completed Date | | --- | --- | 01-Sep-23 | 01-Sep-23 | 01-Sep-23 |
| 4: Analysis Completed Time | | --- | --- | 09:38 | 09:38 | 09:38 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 28-Aug-23 11:05 | 6.6 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 28-Aug-23 11:05 | 6.6 | 1.52 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 28-Aug-23 11:25 | 6.6 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 28-Aug-23 11:25 | 6.6 | 1.70 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 28-Aug-23 12:10 | 6.6 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 28-Aug-23 12:10 | 6.6 | 1.26 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 28-Aug-23 13:10 | 6.6 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 28-Aug-23 13:10 | 6.6 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 28-Aug-23 13:10 | 6.6 | 1.67 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 28-Aug-23 11:00 | 6.6 | 1.40 | 0 | 0 | 280 |
| 16: DW DW Chem Shed | 28-Aug-23 12:55 | 6.6 | 1.20 | 0 | 0 | < 10 |
| 17: DW Comm Center | 28-Aug-23 13:05 | 6.6 | 1.47 | 0 | 0 | < 10 |
| 18: DW Amberley Store | 28-Aug-23 13:35 | 6.6 | 1.37 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 28-Aug-23 13:25 | 6.6 | 1.61 | 0 | 0 | --- |
| 20: DW Birch St. | 28-Aug-23 12:05 | 6.6 | 1.31 | 0 | 0 | --- |
| 21: DW Bruce Beach | 28-Aug-23 11:45 | 6.6 | 1.56 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21682-AUG23

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

25-August-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 22 August 2023
 LR Report: CA21315-AUG23

100 Cove Rd., Goderich
 Canada, N7A 3Z2
 Phone: 519-524-6583, Fax:519-524-9358

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 23-Aug-23 | 23-Aug-23 | 23-Aug-23 |
| 2: Analysis Start Time | | --- | --- | 09:35 | 09:35 | 09:10 |
| 3: Analysis Completed Date | | --- | --- | 25-Aug-23 | 25-Aug-23 | 25-Aug-23 |
| 4: Analysis Completed Time | | --- | --- | 10:22 | 10:22 | 10:22 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 21-Aug-23 11:40 | 9.3 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 21-Aug-23 11:40 | 9.3 | 1.51 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 21-Aug-23 12:00 | 9.3 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 21-Aug-23 12:00 | 9.3 | 1.71 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 21-Aug-23 13:15 | 9.3 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 21-Aug-23 13:15 | 9.3 | 1.23 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 21-Aug-23 14:05 | 9.3 | --- | 1 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 21-Aug-23 14:05 | 9.3 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 21-Aug-23 14:05 | 9.3 | 1.65 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 21-Aug-23 11:35 | 9.3 | 1.56 | 0 | 0 | < 10 |
| 16: DW DW Chem Shed | 21-Aug-23 13:35 | 9.3 | 1.31 | 0 | 0 | < 10 |
| 17: DW Comm Center | 21-Aug-23 13:50 | 9.3 | 1.30 | 0 | 0 | 10 |
| 18: DW Amberley Store | 21-Aug-23 14:35 | 9.3 | 1.53 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 21-Aug-23 14:25 | 9.3 | 1.52 | 0 | 0 | --- |
| 20: DW Birch St. | 21-Aug-23 12:45 | 9.3 | 1.31 | 0 | 0 | --- |
| 21: DW Bruce Beach | 21-Aug-23 12:30 | 9.3 | 1.67 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21315-AUG23

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

18-August-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 15 August 2023
 LR Report: CA20910-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 16-Aug-23 | 16-Aug-23 | 16-Aug-23 |
| 2: Analysis Start Time | | --- | --- | --- | 10:05 | 10:05 | 09:30 |
| 3: Analysis Completed Date | | --- | --- | --- | 18-Aug-23 | 18-Aug-23 | 18-Aug-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 10:33 | 10:33 | 10:33 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 14-Aug-23 11:25 | 5.9 | --- | 0.21 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 14-Aug-23 11:20 | 5.9 | 1.51 | 0.29 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 14-Aug-23 11:40 | 5.9 | --- | 0.17 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 14-Aug-23 11:40 | 5.9 | 1.70 | 0.25 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 14-Aug-23 12:30 | 5.9 | --- | 0.33 | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 14-Aug-23 12:30 | 5.9 | 1.37 | 0.39 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 14-Aug-23 13:15 | 5.9 | --- | 0.22 | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 14-Aug-23 13:15 | 5.9 | --- | 0.20 | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 14-Aug-23 13:15 | 5.9 | 1.74 | 0.23 | 0 | 0 | < 10 |
| 15: DW DW Comm Center | 14-Aug-23 11:00 | 5.9 | 1.21 | --- | 0 | 0 | 10 |
| 16: DW DW Inverlyn CH | 14-Aug-23 11:15 | 5.9 | 1.45 | --- | 0 | 0 | < 10 |
| 17: DW Amberley East SS | 14-Aug-23 13:55 | 5.9 | 1.22 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Store | 14-Aug-23 13:50 | 5.9 | 1.51 | --- | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 14-Aug-23 13:40 | 5.9 | 1.67 | --- | 0 | 0 | --- |
| 20: DW Birch St. | 14-Aug-23 12:15 | 5.9 | 1.32 | --- | 0 | 0 | --- |
| 21: DW Bruce Beach | 14-Aug-23 12:00 | 5.9 | 1.53 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20910-AUG23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

11-August-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 08 August 2023
 LR Report: CA20430-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 09-Aug-23 | 09-Aug-23 | 09-Aug-23 |
| 2: Analysis Start Time | | --- | --- | 11:40 | 11:40 | 10:55 |
| 3: Analysis Completed Date | | --- | --- | 11-Aug-23 | 11-Aug-23 | 11-Aug-23 |
| 4: Analysis Completed Time | | --- | --- | 11:42 | 11:42 | 11:42 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 08-Aug-23 08:10 | 12.4 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 08-Aug-23 08:10 | 12.4 | 1.64 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 08-Aug-23 08:25 | 12.4 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 08-Aug-23 08:25 | 12.4 | 1.69 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 08-Aug-23 09:45 | 12.4 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 08-Aug-23 09:40 | 12.4 | 1.46 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 08-Aug-23 10:30 | 12.4 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 08-Aug-23 10:30 | 12.4 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 08-Aug-23 10:25 | 12.4 | 1.77 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 08-Aug-23 08:00 | 12.4 | 1.58 | 0 | 0 | < 10 |
| 16: DW DW Chem Shed | 08-Aug-23 09:55 | 12.4 | 1.51 | 0 | 0 | < 10 |
| 17: DW Comm Center | 08-Aug-23 09:25 | 12.4 | 1.65 | 0 | 0 | < 10 |
| 18: DW Amberley Store | 08-Aug-23 11:00 | 12.4 | 1.67 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 08-Aug-23 10:55 | 12.4 | 1.70 | 0 | 0 | --- |
| 20: DW Birch St. | 08-Aug-23 09:30 | 12.4 | 1.39 | 0 | 0 | --- |
| 21: DW Bruce Beach | 08-Aug-23 08:45 | 12.4 | 1.65 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20430-AUG23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

04-August-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 01 August 2023
 LR Report: CA20146-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 02-Aug-23 | 02-Aug-23 | 02-Aug-23 |
| 2: Analysis Start Time | | --- | --- | 09:55 | 09:55 | 09:20 |
| 3: Analysis Completed Date | | --- | --- | 04-Aug-23 | 04-Aug-23 | 04-Aug-23 |
| 4: Analysis Completed Time | | --- | --- | 11:23 | 11:23 | 11:23 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 31-Jul-23 11:45 | 6.8 | --- | 1 | 0 | --- |
| 7: TW Huronville South Treated Water | 31-Jul-23 11:45 | 6.8 | 1.84 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 31-Jul-23 11:55 | 6.8 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 31-Jul-23 11:55 | 6.8 | 1.64 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 31-Jul-23 12:30 | 6.8 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 31-Jul-23 12:35 | 6.8 | 1.51 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 31-Jul-23 13:35 | 6.8 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 31-Jul-23 13:35 | 6.8 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 31-Jul-23 13:30 | 6.8 | 1.86 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 31-Jul-23 11:30 | 6.8 | 1.72 | 0 | 0 | < 10 |
| 16: DW DW Chem Shed | 31-Jul-23 13:05 | 6.8 | 1.49 | 0 | 0 | 100 |
| 17: DW Comm Center | 31-Jul-23 13:15 | 6.8 | 1.59 | 0 | 0 | < 10 |
| 18: DW Amberley Store | 31-Jul-23 14:05 | 6.8 | 1.47 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 31-Jul-23 13:50 | 6.8 | 1.68 | 0 | 0 | --- |
| 20: DW Birch St. | 31-Jul-23 12:20 | 6.8 | 1.47 | 0 | 0 | --- |
| 21: DW Bruce Beach | 31-Jul-23 12:05 | 6.8 | 1.67 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20146-AUG23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

31-July-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 28 July 2023
 LR Report: CA21570-JUL23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|----------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 28-Jul-23 | 28-Jul-23 | 28-Jul-23 |
| 2: Analysis Start Time | | --- | --- | 12:55 | 12:55 | 12:10 |
| 3: Analysis Completed Date | | --- | --- | 31-Jul-23 | 31-Jul-23 | 31-Jul-23 |
| 4: Analysis Completed Time | | --- | --- | 11:01 | 11:01 | 11:01 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW Tanglewood B/O | 26-Jul-23 17:05 | 16.2 | 2.10 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-July-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 25 July 2023
 LR Report: CA21402-JUL23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL |
|----------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|
| 1: Analysis Start Date | | --- | --- | 26-Jul-23 | 26-Jul-23 |
| 2: Analysis Start Time | | --- | --- | 08:40 | 08:40 |
| 3: Analysis Completed Date | | --- | --- | 28-Jul-23 | 28-Jul-23 |
| 4: Analysis Completed Time | | --- | --- | 10:56 | 10:56 |
| 5: MAC | | --- | --- | 0 | 0 |
| 6: NR 204 Jardine | 24-Jul-23 09:35 | 11.6 | 1.71 | 0 | 0 |
| 7: NR 506 Ridge Wood | 24-Jul-23 09:40 | 11.6 | 1.95 | 0 | 0 |
| 8: NR Tanglewood DE | 24-Jul-23 09:50 | 11.6 | 1.42 | 0 | 0 |
| 9: NR 204 Jardine 2 | 25-Jul-23 08:05 | 11.6 | 1.41 | 0 | 0 |
| 10: NR 506 Ridge Wood 2 | 25-Jul-23 08:10 | 11.6 | 1.67 | 0 | 0 |
| 11: NR Tanglewood DE 2 | 25-Jul-23 08:20 | 11.6 | 1.63 | 0 | 0 |

MAC - Maximum Acceptable Concentration
 NR - Not reportable under applicable Provincial drinking water regulations as per client.

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|----------------------------------|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-July-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 25 July 2023
 LR Report: CA21403-JUL23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 26-Jul-23 | 26-Jul-23 | 26-Jul-23 |
| 2: Analysis Start Time | | --- | --- | 09:45 | 09:45 | 09:15 |
| 3: Analysis Completed Date | | --- | --- | 28-Jul-23 | 28-Jul-23 | 28-Jul-23 |
| 4: Analysis Completed Time | | --- | --- | 10:59 | 10:59 | 10:59 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 24-Jul-23 11:05 | 6.9 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 24-Jul-23 11:05 | 6.9 | 1.71 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 24-Jul-23 11:25 | 6.9 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 24-Jul-23 11:25 | 6.9 | 1.74 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 24-Jul-23 12:05 | 6.9 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 24-Jul-23 12:05 | 6.9 | 1.50 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 24-Jul-23 13:30 | 6.9 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 24-Jul-23 13:30 | 6.9 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 24-Jul-23 13:20 | 6.9 | 1.77 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 24-Jul-23 11:00 | 6.9 | 1.68 | 0 | 0 | < 10 |
| 16: DW DW Chem Shed | 24-Jul-23 12:20 | 6.9 | 1.51 | 0 | 0 | < 10 |
| 17: DW Comm Center | 24-Jul-23 12:30 | 6.9 | 1.66 | 0 | 0 | < 10 |
| 18: DW Amberley Store | 24-Jul-23 14:00 | 6.9 | 1.58 | 0 | 0 | 10 |
| 19: DW Amberley Beach | 24-Jul-23 13:45 | 6.9 | 1.75 | 0 | 0 | --- |
| 20: DW Birch St. | 24-Jul-23 12:00 | 6.9 | 1.51 | 0 | 0 | --- |
| 21: DW Bruce Beach | 24-Jul-23 11:45 | 6.9 | 1.66 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21403-JUL23

Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

21-July-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 18 July 2023
 LR Report: CA21008-JUL23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 19-Jul-23 | 19-Jul-23 | 19-Jul-23 |
| 2: Analysis Start Time | | --- | --- | 09:55 | 09:55 | 09:20 |
| 3: Analysis Completed Date | | --- | --- | 21-Jul-23 | 21-Jul-23 | 21-Jul-23 |
| 4: Analysis Completed Time | | --- | --- | 11:23 | 11:23 | 11:23 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 17-Jul-23 11:55 | 9.9 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 17-Jul-23 11:55 | 9.9 | 1.70 | 0 | 0 | 90 |
| 8: RW Murdock Glen Raw Water | 17-Jul-23 12:20 | 9.9 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 17-Jul-23 12:20 | 9.9 | 1.76 | 0 | 0 | 20 |
| 10: RW Blairs Grove Raw Water | 17-Jul-23 13:10 | 9.9 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 17-Jul-23 13:05 | 9.9 | 1.33 | 0 | 0 | 10 |
| 12: RW Point Clark Raw Water #2 | 17-Jul-23 14:05 | 9.9 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 17-Jul-23 14:05 | 9.9 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 17-Jul-23 14:00 | 9.9 | 1.48 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 17-Jul-23 11:45 | 9.9 | 1.54 | 0 | 0 | 30 |
| 16: DW DW Chem Shed | 17-Jul-23 13:20 | 9.9 | 1.25 | 0 | 0 | < 10 |
| 17: DW Comm Center | 17-Jul-23 13:40 | 9.9 | 1.42 | 0 | 0 | < 10 |
| 18: DW Amberley Store | 17-Jul-23 15:05 | 9.9 | 1.38 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 17-Jul-23 14:50 | 9.9 | 1.44 | 0 | 0 | --- |
| 20: DW Birch St. | 17-Jul-23 12:55 | 9.9 | 1.32 | 0 | 0 | --- |
| 21: DW Bruce Beach | 17-Jul-23 12:40 | 9.9 | 1.66 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-July-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 11 July 2023
 LR Report: CA20567-JUL23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 12-Jul-23 | 12-Jul-23 | 12-Jul-23 |
| 2: Analysis Start Time | | --- | --- | --- | 10:10 | 10:10 | 09:30 |
| 3: Analysis Completed Date | | --- | --- | --- | 14-Jul-23 | 14-Jul-23 | 14-Jul-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 10:48 | 10:48 | 10:48 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 10-Jul-23 11:05 | 5.1 | --- | 0.20 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 10-Jul-23 11:05 | 5.1 | 1.57 | 0.23 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 10-Jul-23 11:15 | 5.1 | --- | 0.21 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 10-Jul-23 11:15 | 5.1 | 1.80 | 0.26 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 10-Jul-23 11:50 | 5.1 | --- | 0.33 | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 10-Jul-23 11:50 | 5.1 | 1.32 | 0.37 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 10-Jul-23 13:20 | 5.1 | --- | 0.19 | 1 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 10-Jul-23 13:20 | 5.1 | --- | 0.17 | 1 | 0 | --- |
| 14: TW Point Clark Treated Water | 10-Jul-23 13:20 | 5.1 | 1.49 | 0.23 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 10-Jul-23 11:00 | 5.1 | 1.57 | --- | 0 | 0 | < 10 |
| 16: DW DW Chem Shed | 10-Jul-23 12:45 | 5.1 | 1.30 | --- | 0 | 0 | 10 |
| 17: DW Comm Center | 10-Jul-23 13:05 | 5.1 | 1.20 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Store | 10-Jul-23 13:55 | 5.1 | 1.36 | --- | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 10-Jul-23 13:45 | 5.1 | 1.55 | --- | 0 | 0 | --- |
| 20: DW Birch St. | 10-Jul-23 11:45 | 5.1 | 1.32 | --- | 0 | 0 | --- |
| 21: DW Bruce Beach | 10-Jul-23 11:35 | 5.1 | 1.66 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20567-JUL23

Kimberley Didsbury
Project Specialist,
Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

07-July-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 04 July 2023
 LR Report: CA20089-JUL23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 05-Jul-23 | 05-Jul-23 | 05-Jul-23 |
| 2: Analysis Start Time | | --- | --- | 10:05 | 10:05 | 09:35 |
| 3: Analysis Completed Date | | --- | --- | 06-Jul-23 | 06-Jul-23 | 07-Jul-23 |
| 4: Analysis Completed Time | | --- | --- | 16:02 | 16:02 | 09:54 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 03-Jul-23 12:50 | 13.0 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 03-Jul-23 12:45 | 13.0 | 1.57 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 03-Jul-23 12:20 | 13.0 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 03-Jul-23 12:15 | 13.0 | 1.80 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 03-Jul-23 13:40 | 13.0 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 03-Jul-23 13:45 | 13.0 | 1.34 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 03-Jul-23 14:40 | 13.0 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 03-Jul-23 14:45 | 13.0 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 03-Jul-23 14:35 | 13.0 | 1.58 | 0 | 0 | < 10 |
| 15: DW DW Amberly B SS | 03-Jul-23 14:50 | 13.0 | 1.54 | 0 | 0 | 10 |
| 16: DW DW PCCC | 03-Jul-23 14:20 | 13.0 | 1.42 | 0 | 0 | < 10 |
| 17: DW 702 LR | 03-Jul-23 13:15 | 13.0 | 1.66 | 0 | 0 | < 10 |
| 18: DW Bruce BCH SS | 03-Jul-23 12:55 | 13.0 | 1.71 | 0 | 0 | < 10 |
| 19: DW Inverly CLBHSE | 03-Jul-23 12:30 | 13.0 | 1.28 | 0 | 0 | --- |
| 20: DW 179 Bell Dr | 03-Jul-23 13:25 | 13.0 | 1.34 | 0 | 0 | --- |
| 21: DW 3048 AR SS | 03-Jul-23 15:45 | 13.0 | 1.18 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

30-June-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 27 June 2023
 LR Report: CA21511-JUN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 28-Jun-23 | 28-Jun-23 | 28-Jun-23 |
| 2: Analysis Start Time | | --- | --- | 09:55 | 09:55 | 09:30 |
| 3: Analysis Completed Date | | --- | --- | 30-Jun-23 | 30-Jun-23 | 30-Jun-23 |
| 4: Analysis Completed Time | | --- | --- | 09:42 | 09:42 | 09:42 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 26-Jun-23 11:30 | 7.1 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 26-Jun-23 11:30 | 7.1 | 1.51 | 0 | 0 | 10 |
| 8: RW Murdock Glen Raw Water | 26-Jun-23 11:50 | 7.1 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 26-Jun-23 11:50 | 7.1 | 1.77 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 26-Jun-23 12:30 | 7.1 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 26-Jun-23 12:30 | 7.1 | 1.39 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 26-Jun-23 14:00 | 7.1 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 26-Jun-23 14:00 | 7.1 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 26-Jun-23 14:00 | 7.1 | 1.57 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 26-Jun-23 11:20 | 7.1 | 1.47 | 0 | 0 | < 10 |
| 16: DW DW Chem Shed | 26-Jun-23 13:20 | 7.1 | 1.43 | 0 | 0 | 10 |
| 17: DW Comm Center | 26-Jun-23 13:40 | 7.1 | 1.52 | 0 | 0 | < 10 |
| 18: DW Amberley Store | 26-Jun-23 14:30 | 7.1 | 1.48 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 26-Jun-23 14:20 | 7.1 | 1.44 | 0 | 0 | --- |
| 20: DW Birch St. | 26-Jun-23 12:20 | 7.1 | 1.58 | 0 | 0 | --- |
| 21: DW Bruce Beach | 26-Jun-23 12:05 | 7.1 | 1.73 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21511-JUN23

Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

23-June-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 20 June 2023
 LR Report: CA21123-JUN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 21-Jun-23 | 21-Jun-23 | 21-Jun-23 |
| 2: Analysis Start Time | | --- | --- | 10:10 | 10:10 | 09:45 |
| 3: Analysis Completed Date | | --- | --- | 23-Jun-23 | 23-Jun-23 | 23-Jun-23 |
| 4: Analysis Completed Time | | --- | --- | 09:40 | 09:40 | 09:40 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 19-Jun-23 14:35 | 8.7 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 19-Jun-23 14:35 | 8.7 | 1.51 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 19-Jun-23 14:05 | 8.7 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 19-Jun-23 14:05 | 8.7 | 1.80 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 19-Jun-23 13:40 | 8.7 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 19-Jun-23 13:35 | 8.7 | 1.58 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 19-Jun-23 11:45 | 8.7 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 19-Jun-23 11:45 | 8.7 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 19-Jun-23 11:45 | 8.7 | 1.65 | 0 | 0 | < 10 |
| 15: DW DW Amberley Store | 19-Jun-23 11:05 | 8.7 | 1.49 | 0 | 0 | < 10 |
| 16: DW DW Comm Center | 19-Jun-23 11:30 | 8.7 | 1.34 | 0 | 0 | < 10 |
| 17: DW Chem Shed | 19-Jun-23 13:55 | 8.7 | 1.41 | 0 | 0 | < 10 |
| 18: DW Inverlyn CH | 19-Jun-23 14:30 | 8.7 | 1.55 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 19-Jun-23 11:15 | 8.7 | 1.69 | 0 | 0 | --- |
| 20: DW 204 Jardine | 19-Jun-23 13:15 | 8.7 | 1.58 | 0 | 0 | --- |
| 21: DW Bruce Beach | 19-Jun-23 13:55 | 8.7 | 1.23 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21123-JUN23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

16-June-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 13 June 2023
 LR Report: CA20718-JUN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 14-Jun-23 | 14-Jun-23 | 14-Jun-23 |
| 2: Analysis Start Time | | --- | --- | --- | 09:20 | 09:20 | 09:05 |
| 3: Analysis Completed Date | | --- | --- | --- | 16-Jun-23 | 16-Jun-23 | 16-Jun-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 11:32 | 11:32 | 11:32 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 12-Jun-23 11:20 | 9.6 | --- | 0.19 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 12-Jun-23 11:20 | 9.6 | 1.60 | 0.23 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 12-Jun-23 11:40 | 9.6 | --- | 0.21 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 12-Jun-23 11:40 | 9.6 | 1.89 | 0.25 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 12-Jun-23 12:25 | 9.6 | --- | 0.33 | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 12-Jun-23 12:20 | 9.6 | 1.71 | 0.31 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 12-Jun-23 14:05 | 9.6 | --- | 0.22 | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 12-Jun-23 14:05 | 9.6 | --- | 0.24 | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 12-Jun-23 14:05 | 9.6 | 1.80 | 0.27 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 12-Jun-23 11:10 | 9.6 | 1.61 | --- | 0 | 0 | 10 |
| 16: DW DW Comm Center | 12-Jun-23 13:35 | 9.6 | 1.95 | --- | 0 | 0 | < 10 |
| 17: DW Chem Shed | 12-Jun-23 12:40 | 9.6 | 1.62 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Store | 12-Jun-23 14:50 | 9.6 | 1.83 | --- | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 12-Jun-23 14:40 | 9.6 | 1.83 | --- | 0 | 0 | --- |
| 20: DW Birch St. | 12-Jun-23 12:15 | 9.6 | 1.38 | --- | 0 | 0 | --- |
| 21: DW Bruce Beach | 12-Jun-23 12:05 | 9.6 | 1.73 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-June-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 06 June 2023
 LR Report: CA20336-JUN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 07-Jun-23 | 07-Jun-23 | 07-Jun-23 |
| 2: Analysis Start Time | | --- | --- | 10:25 | 10:25 | 09:55 |
| 3: Analysis Completed Date | | --- | --- | 09-Jun-23 | 09-Jun-23 | 09-Jun-23 |
| 4: Analysis Completed Time | | --- | --- | 11:11 | 11:11 | 11:11 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 05-Jun-23 11:35 | 8.0 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 05-Jun-23 11:35 | 8.0 | 1.65 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 05-Jun-23 11:55 | 8.0 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 05-Jun-23 11:55 | 8.0 | 1.94 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 05-Jun-23 12:30 | 8.0 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 05-Jun-23 12:30 | 8.0 | 1.80 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 05-Jun-23 14:15 | 8.0 | --- | 4 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 05-Jun-23 14:15 | 8.0 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 05-Jun-23 14:15 | 8.0 | 1.53 | 0 | 0 | 10 |
| 15: DW DW Comm Center | 05-Jun-23 11:00 | 8.0 | 1.60 | 0 | 0 | 10 |
| 16: DW DW Inverlyn CH | 05-Jun-23 11:25 | 8.0 | 1.49 | 0 | 0 | < 10 |
| 17: DW Chem Shed | 05-Jun-23 13:00 | 8.0 | 1.55 | 0 | 0 | < 10 |
| 18: DW Amberley Store | 05-Jun-23 15:00 | 8.0 | 1.41 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 05-Jun-23 14:45 | 8.0 | 1.57 | 0 | 0 | --- |
| 20: DW Birch St. | 05-Jun-23 13:15 | 8.0 | 1.22 | 0 | 0 | --- |
| 21: DW Bruce Beach | 05-Jun-23 12:15 | 8.0 | 1.73 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

02-June-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 30 May 2023
 LR Report: CA21650-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 31-May-23 | 31-May-23 | 31-May-23 |
| 2: Analysis Start Time | | --- | --- | 10:05 | 10:05 | 09:35 |
| 3: Analysis Completed Date | | --- | --- | 02-Jun-23 | 02-Jun-23 | 02-Jun-23 |
| 4: Analysis Completed Time | | --- | --- | 12:04 | 12:04 | 12:04 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 29-May-23 11:30 | 8.9 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 29-May-23 11:30 | 8.9 | 1.74 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 29-May-23 12:00 | 8.9 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 29-May-23 12:00 | 8.9 | 1.97 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 29-May-23 13:25 | 8.9 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 29-May-23 13:25 | 8.9 | 1.55 | 0 | 0 | 10 |
| 12: RW Point Clark Raw Water #2 | 29-May-23 14:10 | 8.9 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 29-May-23 14:10 | 8.9 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 29-May-23 14:10 | 8.9 | 1.72 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 29-May-23 11:00 | 8.9 | 1.68 | 0 | 0 | < 10 |
| 16: DW DW Chem Shed | 29-May-23 13:40 | 8.9 | 1.51 | 0 | 0 | < 10 |
| 17: DW Comm Center | 29-May-23 14:00 | 8.9 | 1.31 | 0 | 0 | < 10 |
| 18: DW Amberley Store | 29-May-23 15:05 | 8.9 | 1.52 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 29-May-23 14:55 | 8.9 | 1.62 | 0 | 0 | --- |
| 20: DW Birch St. | 29-May-23 12:35 | 8.9 | 1.21 | 0 | 0 | --- |
| 21: DW Bruce beach | 29-May-23 12:25 | 8.9 | 1.89 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21650-MAY23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

26-May-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 23 May 2023
LR Report: CA21250-MAY23

100 Cove Rd.
Goderich, ON
N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
Fax:519-524-9358

CERTIFICATE OF ANALYSIS
Final Report

Table with 7 columns: Sample ID, Sample Date & Time, Temperature Upon Receipt °C, Field ResCI Free mg/L, Total Coliform cfu/100mL, E.Coli cfu/100mL, Heterotrophic Plate Count (HPC) cfu/1mL. Rows include analysis start dates, times, completed dates, times, and various water samples (RW, TW, DW) with their respective parameters.


MAC - Maximum Acceptable Concentration

Method Descriptions

Table with 3 columns: Units, Description, SGS Method Code. Rows describe E.Coli by MF (using DCM), Heterotrophic Plate Count (HPC) by SP (using SPCA), and Total Coliform by MF (using DCM).

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21250-MAY23



Carrie Greenlaw
Carrie Greenlaw
Project Specialist,
Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

19-May-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 16 May 2023
 LR Report: CA20984-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 17-May-23 | 17-May-23 | 17-May-23 |
| 2: Analysis Start Time | | --- | --- | --- | 10:15 | 10:15 | 09:45 |
| 3: Analysis Completed Date | | --- | --- | --- | 19-May-23 | 19-May-23 | 19-May-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 10:41 | 10:41 | 10:41 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 15-May-23 11:05 | 5.0 | --- | 0.20 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 15-May-23 11:05 | 5.0 | 1.64 | 0.25 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 15-May-23 11:25 | 5.0 | --- | 0.21 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 15-May-23 11:20 | 5.0 | 1.75 | 0.24 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 15-May-23 12:30 | 5.0 | --- | 0.37 | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 15-May-23 12:30 | 5.0 | 1.50 | 0.31 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 15-May-23 13:25 | 5.0 | --- | 0.19 | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 15-May-23 13:20 | 5.0 | --- | 0.22 | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 15-May-23 13:20 | 5.0 | 1.65 | 0.29 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 15-May-23 11:00 | 5.0 | 1.44 | --- | 0 | 0 | 10 |
| 16: DW DW Chem Shed | 15-May-23 12:40 | 5.0 | 1.33 | --- | 0 | 0 | < 10 |
| 17: DW Comm Center | 15-May-23 12:55 | 5.0 | 1.47 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Store | 15-May-23 13:55 | 5.0 | 1.40 | --- | 0 | 0 | 10 |
| 19: DW Amberley Beach | 15-May-23 13:45 | 5.0 | 1.54 | --- | 0 | 0 | --- |
| 20: DW Birch St. | 15-May-23 11:50 | 5.0 | 1.11 | --- | 0 | 0 | --- |
| 21: DW Bruce Beach | 15-May-23 11:35 | 5.0 | 1.53 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20984-MAY23

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

12-May-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 09 May 2023
 LR Report: CA20543-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 10-May-23 | 10-May-23 | 10-May-23 |
| 2: Analysis Start Time | | --- | --- | 09:55 | 09:55 | 09:25 |
| 3: Analysis Completed Date | | --- | --- | 12-May-23 | 12-May-23 | 12-May-23 |
| 4: Analysis Completed Time | | --- | --- | 11:37 | 11:37 | 11:37 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 08-May-23 11:25 | 9.2 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 08-May-23 11:20 | 9.2 | 1.68 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 08-May-23 11:55 | 9.2 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 08-May-23 11:55 | 9.2 | 1.77 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 08-May-23 13:25 | 9.2 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 08-May-23 13:25 | 9.2 | 1.48 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 08-May-23 14:10 | 9.2 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 08-May-23 14:10 | 9.2 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 08-May-23 14:10 | 9.2 | 1.73 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 08-May-23 11:05 | 9.2 | 1.43 | 0 | 0 | < 10 |
| 16: DW DW Chem Shed | 08-May-23 13:30 | 9.2 | 1.51 | 0 | 0 | < 10 |
| 17: DW Comm Center | 08-May-23 13:55 | 9.2 | 1.43 | 0 | 0 | < 10 |
| 18: DW Amberley Store | 08-May-23 14:45 | 9.2 | 1.43 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 08-May-23 14:35 | 9.2 | 1.61 | 0 | 0 | --- |
| 20: DW Birch St. | 08-May-23 12:35 | 9.2 | 1.23 | 0 | 0 | --- |
| 21: DW Bruce Beach | 08-May-23 12:15 | 9.2 | 1.65 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20543-MAY23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

05-May-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 02 May 2023
 LR Report: CA20211-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 03-May-23 | 03-May-23 | 03-May-23 |
| 2: Analysis Start Time | | --- | --- | 10:40 | 10:40 | 10:15 |
| 3: Analysis Completed Date | | --- | --- | 05-May-23 | 05-May-23 | 05-May-23 |
| 4: Analysis Completed Time | | --- | --- | 10:53 | 10:53 | 10:53 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 01-May-23 11:00 | 6.9 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 01-May-23 11:00 | 6.9 | 1.58 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 01-May-23 11:30 | 6.9 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 01-May-23 11:30 | 6.9 | 1.74 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 01-May-23 12:50 | 6.9 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 01-May-23 12:50 | 6.9 | 1.51 | 0 | 0 | 10 |
| 12: RW Point Clark Raw Water #2 | 01-May-23 13:55 | 6.9 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 01-May-23 13:55 | 6.9 | --- | 1 | 0 | --- |
| 14: TW Point Clark Treated Water | 01-May-23 13:50 | 6.9 | 1.71 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 01-May-23 11:15 | 6.9 | 1.36 | 0 | 0 | < 10 |
| 16: DW DW Chem Shed | 01-May-23 13:20 | 6.9 | 1.47 | 0 | 0 | < 10 |
| 17: DW Comm Center | 01-May-23 13:35 | 6.9 | 1.32 | 0 | 0 | < 10 |
| 18: DW Amberley Store | 01-May-23 14:20 | 6.9 | 1.51 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 01-May-23 14:10 | 6.9 | 1.64 | 0 | 0 | --- |
| 20: DW Birch St. | 01-May-23 12:10 | 6.9 | 1.36 | 0 | 0 | --- |
| 21: DW Bruce beach | 01-May-23 11:45 | 6.9 | 1.46 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-April-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 25 April 2023
 LR Report: CA21211-APR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 26-Apr-23 | 26-Apr-23 | 26-Apr-23 |
| 2: Analysis Start Time | | --- | --- | 09:55 | 09:55 | 09:25 |
| 3: Analysis Completed Date | | --- | --- | 28-Apr-23 | 28-Apr-23 | 28-Apr-23 |
| 4: Analysis Completed Time | | --- | --- | 09:36 | 09:36 | 09:36 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 24-Apr-23 11:10 | 7.6 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 24-Apr-23 11:10 | 7.6 | 1.63 | 0 | 0 | 10 |
| 8: RW Murdock Glen Raw Water | 24-Apr-23 11:55 | 7.6 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 24-Apr-23 11:55 | 7.6 | 1.61 | 0 | 0 | < 10 |
| 10: RW Blairs Grove Raw Water | 24-Apr-23 12:40 | 7.6 | --- | 0 | 0 | --- |
| 11: TW Blairs Grove Treated Water | 24-Apr-23 12:35 | 7.6 | 1.47 | 0 | 0 | < 10 |
| 12: RW Point Clark Raw Water #2 | 24-Apr-23 13:00 | 7.6 | --- | 0 | 0 | --- |
| 13: RW Point Clark Raw Water #3 | 24-Apr-23 13:00 | 7.6 | --- | 0 | 0 | --- |
| 14: TW Point Clark Treated Water | 24-Apr-23 13:00 | 7.6 | 1.71 | 0 | 0 | < 10 |
| 15: DW DW Inverlyn CH | 24-Apr-23 11:00 | 7.6 | 1.43 | 0 | 0 | < 10 |
| 16: DW DW Chem Shed | 24-Apr-23 12:50 | 7.6 | 1.33 | 0 | 0 | < 10 |
| 17: DW Comm Center | 24-Apr-23 12:55 | 7.6 | 1.26 | 0 | 0 | < 10 |
| 18: DW Amberley Store | 24-Apr-23 13:25 | 7.6 | 1.39 | 0 | 0 | < 10 |
| 19: DW Amberley Beach | 24-Apr-23 13:15 | 7.6 | 1.55 | 0 | 0 | --- |
| 20: DW Birch St. | 24-Apr-23 12:30 | 7.6 | 1.27 | 0 | 0 | --- |
| 21: DW Bruce Beach | 24-Apr-23 12:10 | 7.6 | 1.22 | 0 | 0 | --- |


MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21211-APR23



Kimberley Didsbury
Project Specialist,
Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-April-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 21 April 2023
 LR Report: CA21017-APR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #2

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|-----------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 21-Apr-23 | 21-Apr-23 | 21-Apr-23 |
| 2: Analysis Start Time | | --- | --- | 11:35 | 11:35 | 11:15 |
| 3: Analysis Completed Date | | --- | --- | 24-Apr-23 | 24-Apr-23 | 24-Apr-23 |
| 4: Analysis Completed Time | | --- | --- | 11:48 | 11:48 | 11:48 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RESAMPLE TW HS TW | 20-Apr-23 13:40 | 3.1 | 1.71 | 0 | 0 | NDOGHPC |
| 7: RESAMPLE DW Inverlyn CH | 20-Apr-23 13:25 | 3.1 | 1.70 | 0 | 0 | < 10 |
| 8: RESAMPLE DW 161 Carloway | 20-Apr-23 13:30 | 3.1 | 1.72 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration
 NDOGHPC - No Data: Overgrown with HPC

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-April-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 20 April 2023
 LR Report: CA20961-APR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #2

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL |
|----------------------------|--------------------|-----------------------------|---------------------|--------------------------|------------------|
| 1: Analysis Start Date | | --- | --- | 20-Apr-23 | 20-Apr-23 |
| 2: Analysis Start Time | | --- | --- | 12:50 | 12:50 |
| 3: Analysis Completed Date | | --- | --- | 24-Apr-23 | 24-Apr-23 |
| 4: Analysis Completed Time | | --- | --- | 11:02 | 11:02 |
| 5: MAC | | --- | --- | 0 | 0 |
| 6: NR PC Well 2 #1 | 19-Apr-23 08:35 | 10.9 | 0.66 | 0 | 0 |
| 7: NR PC Well 2 #2 | 19-Apr-23 09:05 | 10.9 | 0.27 | 0 | 0 |
| 8: RW Blairs Grove Raw | 19-Apr-23 11:20 | 10.9 | 0.69 | 0 | 0 |

MAC - Maximum Acceptable Concentration
 NR - Not reportable under applicable Provincial drinking water regulations as per client.

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|----------------------------------|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

21-April-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 18 April 2023
 LR Report: CA20854-APR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 19-Apr-23 | 19-Apr-23 | 19-Apr-23 |
| 2: Analysis Start Time | | --- | --- | 09:55 | 09:55 | 09:30 |
| 3: Analysis Completed Date | | --- | --- | 21-Apr-23 | 21-Apr-23 | 21-Apr-23 |
| 4: Analysis Completed Time | | --- | --- | 10:48 | 10:48 | 10:48 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 17-Apr-23 11:20 | 6.6 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 17-Apr-23 11:20 | 6.6 | 1.64 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 17-Apr-23 11:40 | 6.6 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 17-Apr-23 11:40 | 6.6 | 1.71 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 17-Apr-23 12:50 | 6.6 | 1.45 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #3 | 17-Apr-23 13:20 | 6.6 | --- | 0 | 0 | --- |
| 12: TW Point Clark Treated Water | 17-Apr-23 13:20 | 6.6 | 1.70 | 0 | 0 | < 10 |
| 13: DW DW Inverlyn CH | 17-Apr-23 11:15 | 6.6 | 1.46 | 1 MAC | 0 | < 10 |
| 14: DW DW Chem Shed | 17-Apr-23 13:05 | 6.6 | 1.41 | 0 | 0 | < 10 |
| 15: DW Comm Center | 17-Apr-23 11:00 | 6.6 | 1.42 | 0 | 0 | < 10 |
| 16: DW Amberley Store | 17-Apr-23 13:50 | 6.6 | 1.49 | 0 | 0 | < 10 |
| 17: DW Amberley Beach | 17-Apr-23 13:40 | 6.6 | 1.62 | 0 | 0 | --- |
| 18: DW Birch St. | 17-Apr-23 12:20 | 6.6 | 1.59 | 0 | 0 | --- |
| 19: DW Bruce Beach | 17-Apr-23 12:10 | 6.6 | 1.70 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

MAC - (ADVERSE) Above Maximum Acceptable Concentration

The AWQI # assigned by the MOECP for the adverse result is: 161785

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-April-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 11 April 2023
 LR Report: CA20431-APR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 12-Apr-23 | 12-Apr-23 | 12-Apr-23 |
| 2: Analysis Start Time | | --- | --- | --- | 10:20 | 10:20 | 09:55 |
| 3: Analysis Completed Date | | --- | --- | --- | 14-Apr-23 | 14-Apr-23 | 14-Apr-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 12:24 | 12:24 | 12:24 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 10-Apr-23 11:15 | 10.1 | --- | 0.22 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 10-Apr-23 11:15 | 10.1 | 1.61 | 0.23 | 0 | 0 | 20 |
| 8: RW Murdock Glen Raw Water | 10-Apr-23 11:30 | 10.1 | --- | 0.19 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 10-Apr-23 11:30 | 10.1 | 1.71 | 0.25 | 0 | 0 | >2000 |
| 10: TW Blairs Grove Treated Water | 10-Apr-23 12:10 | 10.1 | 1.51 | 0.34 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 10-Apr-23 13:30 | 10.1 | --- | 0.23 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 10-Apr-23 13:30 | 10.1 | --- | 0.23 | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 10-Apr-23 13:30 | 10.1 | 1.71 | 0.26 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 10-Apr-23 11:00 | 10.1 | 1.44 | --- | 0 | 0 | < 10 |
| 15: DW DW Chem Shed | 10-Apr-23 12:20 | 10.1 | 1.54 | --- | 0 | 0 | < 10 |
| 16: DW Comm Center | 10-Apr-23 12:25 | 10.1 | 1.37 | --- | 0 | 0 | < 10 |
| 17: DW Amberley Store | 10-Apr-23 14:05 | 10.1 | 1.66 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 10-Apr-23 13:55 | 10.1 | 1.66 | --- | 0 | 0 | --- |
| 19: DW Birch St. | 10-Apr-23 12:00 | 10.1 | 1.54 | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 10-Apr-23 11:45 | 10.1 | 1.40 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

10-April-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 04 April 2023
 LR Report: CA20185-APR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 05-Apr-23 | 05-Apr-23 | 05-Apr-23 |
| 2: Analysis Start Time | | --- | --- | 09:55 | 09:55 | 09:20 |
| 3: Analysis Completed Date | | --- | --- | 10-Apr-23 | 10-Apr-23 | 10-Apr-23 |
| 4: Analysis Completed Time | | --- | --- | 09:49 | 09:49 | 09:49 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 03-Apr-23 11:05 | 7.6 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 03-Apr-23 11:05 | 7.6 | 1.69 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 03-Apr-23 11:30 | 7.6 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 03-Apr-23 11:30 | 7.6 | 1.60 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 03-Apr-23 12:40 | 7.6 | 1.50 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 03-Apr-23 13:10 | 7.6 | --- | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 03-Apr-23 13:10 | 7.6 | --- | 2 | 0 | --- |
| 13: TW Point Clark Treated Water | 03-Apr-23 13:10 | 7.6 | 1.71 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 03-Apr-23 11:00 | 7.6 | 1.56 | 0 | 0 | < 10 |
| 15: DW DW Chem Shed | 03-Apr-23 12:55 | 7.6 | --- | 0 | 0 | < 10 |
| 16: DW Comm Centre | 03-Apr-23 13:00 | 7.6 | 1.37 | 0 | 0 | < 10 |
| 17: DW Amberley Store | 03-Apr-23 13:40 | 7.6 | 1.41 | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 03-Apr-23 13:30 | 7.6 | 1.39 | 0 | 0 | --- |
| 19: DW Birch St. | 03-Apr-23 12:00 | 7.6 | 1.35 | 0 | 0 | --- |
| 20: DW Bruce Beach | 03-Apr-23 11:50 | 7.6 | 1.24 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20185-APR23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

31-March-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 28 March 2023
LR Report: CA21204-MAR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 29-Mar-23 | 29-Mar-23 | 29-Mar-23 |
| 2: Analysis Start Time | | --- | --- | 10:10 | 10:10 | 09:45 |
| 3: Analysis Completed Date | | --- | --- | 31-Mar-23 | 31-Mar-23 | 31-Mar-23 |
| 4: Analysis Completed Time | | --- | --- | 09:41 | 09:41 | 09:41 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 27-Mar-23 11:25 | 8.4 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 27-Mar-23 11:25 | 8.4 | 1.50 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 27-Mar-23 11:45 | 8.4 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 27-Mar-23 11:45 | 8.4 | 1.63 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 27-Mar-23 12:20 | 8.4 | 1.60 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 27-Mar-23 13:25 | 8.4 | --- | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 27-Mar-23 13:25 | 8.4 | --- | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 27-Mar-23 13:25 | 8.4 | 1.81 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 27-Mar-23 11:10 | 8.4 | 1.45 | 0 | 0 | < 10 |
| 15: DW DW Chem Shed | 27-Mar-23 13:00 | 8.4 | 1.49 | 0 | 0 | < 10 |
| 16: DW Comm Center | 27-Mar-23 13:10 | 8.4 | 1.38 | 0 | 0 | < 10 |
| 17: DW Amberley Store | 27-Mar-23 14:05 | 8.4 | 1.48 | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 27-Mar-23 13:55 | 8.4 | 1.57 | 0 | 0 | --- |
| 19: DW Birch St | 27-Mar-23 12:15 | 8.4 | 1.38 | 0 | 0 | --- |
| 20: DW Bruce Beach | 27-Mar-23 12:00 | 8.4 | 1.47 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21204-MAR23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-March-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 21 March 2023
 LR Report: CA20909-MAR23

100 Cove Rd., Goderich
 Canada, N7A 3Z2
 Phone: 519-524-6583, Fax:519-524-9358

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 22-Mar-23 | 22-Mar-23 | 22-Mar-23 |
| 2: Analysis Start Time | | --- | --- | --- | 10:15 | 10:15 | 09:50 |
| 3: Analysis Completed Date | | --- | --- | --- | 24-Mar-23 | 24-Mar-23 | 24-Mar-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 12:38 | 12:38 | 12:38 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 20-Mar-23 11:05 | 8.4 | --- | 0.21 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 20-Mar-23 11:05 | 8.4 | 1.75 | 0.25 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 20-Mar-23 11:30 | 8.4 | --- | 0.22 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Treated | 20-Mar-23 11:30 | 8.4 | 1.61 | 0.26 | 0 | 0 | 10 |
| 10: TW Blairs Grove Treated Water | 20-Mar-23 12:10 | 8.4 | 1.64 | 0.39 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 20-Mar-23 13:05 | 8.4 | --- | 0.23 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 20-Mar-23 13:05 | 8.4 | --- | 0.19 | 1 | 0 | --- |
| 13: TW Point Clark Treated Water | 20-Mar-23 13:05 | 8.4 | 1.93 | 0.25 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 20-Mar-23 11:00 | 8.4 | 1.71 | --- | 0 | 0 | < 10 |
| 15: DW DW Chem Shed | 20-Mar-23 12:45 | 8.4 | 1.46 | --- | 0 | 0 | < 10 |
| 16: DW Comm Center | 20-Mar-23 13:00 | 8.4 | 1.26 | --- | 0 | 0 | < 10 |
| 17: DW Amberley Store | 20-Mar-23 13:30 | 8.4 | 1.26 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 20-Mar-23 13:20 | 8.4 | 1.42 | --- | 0 | 0 | --- |
| 19: DW Birch St | 20-Mar-23 12:00 | 8.4 | 1.31 | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 20-Mar-23 11:50 | 8.4 | 1.38 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20909-MAR23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-March-2023

Veolia Water (Lakeshore)

Attn : Gary Nicholson

Date Rec. : 14 March 2023
 LR Report: CA20595-MAR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|--------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 15-Mar-23 | 15-Mar-23 | 15-Mar-23 |
| 2: Analysis Start Time | | --- | --- | --- | 10:25 | 10:25 | 10:00 |
| 3: Analysis Completed Date | | --- | --- | --- | 17-Mar-23 | 17-Mar-23 | 17-Mar-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 10:13 | 10:13 | 10:13 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 13-Mar-23 11:00 | 11.4 | --- | 0.19 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 13-Mar-23 11:00 | 11.4 | 1.75 | 0.25 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 13-Mar-23 11:30 | 11.4 | --- | 0.22 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 13-Mar-23 11:30 | 11.4 | 1.56 | 0.29 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 13-Mar-23 12:10 | 11.4 | 1.62 | 0.36 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 13-Mar-23 13:10 | 11.4 | --- | 0.23 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 13-Mar-23 13:10 | 11.4 | --- | 0.22 | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 13-Mar-23 13:10 | 11.4 | 1.90 | 0.29 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 13-Mar-23 11:20 | 11.4 | 1.45 | --- | 0 | 0 | < 10 |
| 15: DW DW Chem Shed | 13-Mar-23 12:55 | 11.4 | 1.47 | --- | 0 | 0 | < 10 |
| 16: DW Comm Center | 13-Mar-23 13:00 | 11.4 | 1.10 | --- | 0 | 0 | < 10 |
| 17: DW Amberley Store | 13-Mar-23 14:00 | 11.4 | 1.26 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 13-Mar-23 13:45 | 11.4 | 1.33 | --- | 0 | 0 | --- |
| 19: DW Birch St | 13-Mar-23 12:05 | 11.4 | 1.29 | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 13-Mar-23 11:50 | 11.4 | 1.41 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20595-MAR23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*



SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

Veolia Water (Lakeshore)

Attn : Gary Nicholson

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Phone: 519-524-6583
 Fax:519-524-9358

Works #: 220000425

13-March-2023

Date Rec. : 07 March 2023
LR Report: CA20323-MAR23

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 08-Mar-23 | 08-Mar-23 | 08-Mar-23 |
| 2: Analysis Start Time | | --- | --- | --- | 10:00 | 10:00 | 09:30 |
| 3: Analysis Completed Date | | --- | --- | --- | 10-Mar-23 | 10-Mar-23 | 10-Mar-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 12:38 | 12:38 | 12:38 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 06-Mar-23 11:00 | 10.6 | --- | 0.23 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 06-Mar-23 11:00 | 10.6 | 1.82 | 0.25 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 06-Mar-23 11:25 | 10.6 | --- | 0.21 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 06-Mar-23 11:25 | 10.6 | 1.65 | 0.22 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 06-Mar-23 12:40 | 10.6 | 1.55 | 0.31 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 06-Mar-23 13:20 | 10.6 | --- | 0.22 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 06-Mar-23 13:20 | 10.6 | --- | 0.21 | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 06-Mar-23 13:15 | 10.6 | 1.85 | 0.27 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 06-Mar-23 11:20 | 10.6 | 1.71 | --- | 0 | 0 | < 10 |
| 15: DW DW Chem Shed | 06-Mar-23 12:55 | 10.6 | 1.47 | --- | 0 | 0 | < 10 |
| 16: DW Comm Center | 06-Mar-23 13:00 | 10.6 | 1.57 | --- | 0 | 0 | < 10 |
| 17: DW Amberley Store | 06-Mar-23 13:55 | 10.6 | 1.70 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 06-Mar-23 13:40 | 10.6 | 1.76 | --- | 0 | 0 | --- |
| 19: DW Birch St. | 06-Mar-23 12:00 | 10.6 | 1.30 | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 06-Mar-23 11:45 | 10.6 | 1.55 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Phone: 519-524-6583
 Fax:519-524-9358

Works #: 220000425

03-March-2023

Date Rec. : 28 February 2023
LR Report: CA20008-MAR23

Copy: #1

CERTIFICATE OF ANALYSIS Final Report


| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 01-Mar-23 | 01-Mar-23 | 01-Mar-23 |
| 2: Analysis Start Time | | --- | --- | --- | 10:10 | 10:10 | 09:50 |
| 3: Analysis Completed Date | | --- | --- | --- | 03-Mar-23 | 03-Mar-23 | 03-Mar-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 11:22 | 11:22 | 11:22 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 27-Feb-23 11:05 | 10.6 | --- | 0.21 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 27-Feb-23 11:05 | 10.6 | 1.71 | 0.29 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 27-Feb-23 11:35 | 10.6 | --- | 0.20 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 27-Feb-23 11:35 | 10.6 | 1.53 | 0.22 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 27-Feb-23 12:15 | 10.6 | 1.60 | 0.31 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 27-Feb-23 13:20 | 10.6 | --- | 0.20 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 27-Feb-23 13:20 | 10.6 | --- | 0.20 | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 27-Feb-23 13:20 | 10.6 | 1.88 | 0.24 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 27-Feb-23 11:00 | 10.6 | 1.32 | --- | 0 | 0 | < 10 |
| 15: DW DW Chem Shed | 27-Feb-23 12:55 | 10.6 | 1.50 | --- | 0 | 0 | < 10 |
| 16: DW Comm Center | 27-Feb-23 13:05 | 10.6 | 1.51 | --- | 0 | 0 | < 10 |

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|-----------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 17: DW Amberley Store | 27-Feb-23 14:15 | 10.6 | 1.63 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 27-Feb-23 14:05 | 10.6 | 1.57 | --- | 0 | 0 | --- |
| 19: DW Birch St | 27-Feb-23 12:10 | 10.6 | 1.55 | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 27-Feb-23 11:55 | 10.6 | 1.49 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-February-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 21 February 2023
 LR Report: CA20795-FEB23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 22-Feb-23 | 22-Feb-23 | 22-Feb-23 |
| 2: Analysis Start Time | | --- | --- | --- | 11:15 | 11:15 | 10:35 |
| 3: Analysis Completed Date | | --- | --- | --- | 24-Feb-23 | 24-Feb-23 | 24-Feb-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 14:12 | 14:12 | 14:12 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 21-Feb-23 08:50 | 9.1 | --- | 0.24 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 21-Feb-23 08:50 | 9.1 | 1.61 | 0.25 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 21-Feb-23 08:10 | 9.1 | --- | 0.17 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 21-Feb-23 08:10 | 9.1 | 1.56 | 0.25 | 0 | 0 | 20 |
| 10: TW Blairs Grove Treated Water | 21-Feb-23 07:20 | 9.1 | 1.60 | 0.39 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 21-Feb-23 06:40 | 9.1 | --- | 0.19 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 21-Feb-23 06:40 | 9.1 | --- | 0.22 | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 21-Feb-23 06:40 | 9.1 | 1.85 | 0.26 | 0 | 0 | < 10 |
| 14: DW DW Comm Center | 21-Feb-23 07:05 | 9.1 | 1.60 | --- | 0 | 0 | < 10 |
| 15: DW DW Chem Center | 21-Feb-23 07:10 | 9.1 | 1.55 | --- | 0 | 0 | < 10 |
| 16: DW Inverlyn CH | 21-Feb-23 08:30 | 9.1 | 1.27 | --- | 0 | 0 | < 10 |
| 17: DW Amberley Store | 21-Feb-23 06:20 | 9.1 | 1.74 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 21-Feb-23 06:30 | 9.1 | 1.65 | --- | 0 | 0 | --- |
| 19: DW Birch St. | 21-Feb-23 07:45 | 9.1 | 1.46 | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 21-Feb-23 08:00 | 9.1 | 1.43 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20795-FEB23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-February-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 14 February 2023
LR Report: CA20596-FEB23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | *** | --- | 15-Feb-23 | 15-Feb-23 | 15-Feb-23 |
| 2: Analysis Start Time | | --- | *** | --- | 10:50 | 10:50 | 10:10 |
| 3: Analysis Completed Date | | --- | *** | --- | 17-Feb-23 | 17-Feb-23 | 17-Feb-23 |
| 4: Analysis Completed Time | | --- | *** | --- | 10:46 | 10:46 | 10:46 |
| 5: MAC | | --- | *** | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 13-Feb-23 11:20 | 9.7 | *** | 0.20 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 13-Feb-23 11:20 | 9.7 | *** | 0.22 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 13-Feb-23 11:50 | 9.7 | *** | 0.21 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 13-Feb-23 11:50 | 9.7 | *** | 0.29 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 13-Feb-23 12:25 | 9.7 | *** | 0.37 | 0 | 0 | NDLA |
| 11: RW Point Clark Raw Water #2 | 13-Feb-23 13:50 | 9.7 | *** | 0.20 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 13-Feb-23 13:50 | 9.7 | *** | 0.21 | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 13-Feb-23 13:50 | 9.7 | *** | 0.26 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 13-Feb-23 11:00 | 9.7 | *** | --- | 0 | 0 | < 10 |
| 15: DW DW Chem Shed | 13-Feb-23 13:10 | 9.7 | *** | --- | 0 | 0 | < 10 |
| 16: DW Comm Center | 13-Feb-23 13:25 | 9.7 | *** | --- | 0 | 0 | < 10 |
| 17: DW Amberley Store | 13-Feb-23 14:25 | 9.7 | *** | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 13-Feb-23 14:15 | 9.7 | *** | --- | 0 | 0 | --- |
| 19: DW Birch St. | 13-Feb-23 12:15 | 9.7 | *** | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 13-Feb-23 12:00 | 9.7 | *** | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

NDLA - No Data: Laboratory Accident/Error(Sample 10 HPC)

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20596-FEB23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

10-February-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 07 February 2023
LR Report: CA20310-FEB23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 08-Feb-23 | 08-Feb-23 | 08-Feb-23 |
| 2: Analysis Start Time | | --- | --- | 10:10 | 10:10 | 09:45 |
| 3: Analysis Completed Date | | --- | --- | 10-Feb-23 | 10-Feb-23 | 10-Feb-23 |
| 4: Analysis Completed Time | | --- | --- | 09:14 | 09:14 | 09:14 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 06-Feb-23 11:05 | 8.7 | --- | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 06-Feb-23 11:05 | 8.7 | 1.35 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw South | 06-Feb-23 11:25 | 8.7 | --- | 0 | 0 | --- |
| 9: TW Murdock Glen Treated | 06-Feb-23 11:25 | 8.7 | 1.70 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 06-Feb-23 11:50 | 8.7 | 1.61 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 06-Feb-23 13:10 | 8.7 | --- | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 06-Feb-23 13:10 | 8.7 | --- | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 06-Feb-23 13:10 | 8.7 | 1.94 | 0 | 0 | < 10 |
| 14: DW Inverlyn CH | 06-Feb-23 11:00 | 8.7 | 1.53 | 0 | 0 | < 10 |
| 15: DW Chem Ched | 06-Feb-23 12:30 | 8.7 | 1.37 | 0 | 0 | < 10 |
| 16: DW Comm Center | 06-Feb-23 12:55 | 8.7 | 1.78 | 0 | 0 | < 10 |
| 17: DW Amberley Store | 06-Feb-23 13:40 | 8.7 | 1.76 | 0 | 0 | < 10 |
| 18: DW Amberley beach | 06-Feb-23 13:30 | 8.7 | 1.77 | 0 | 0 | --- |
| 19: DW Birch St | 06-Feb-23 11:40 | 8.7 | 1.17 | 0 | 0 | --- |
| 20: DW Bruce Beach | 06-Feb-23 11:30 | 8.7 | 1.13 | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20310-FEB23

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

03-February-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 31 January 2023
 LR Report: CA20000-FEB23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 01-Feb-23 | 01-Feb-23 | 01-Feb-23 |
| 2: Analysis Start Time | | --- | --- | --- | 10:00 | 10:00 | 09:35 |
| 3: Analysis Completed Date | | --- | --- | --- | 03-Feb-23 | 03-Feb-23 | 03-Feb-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 10:40 | 10:40 | 10:40 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 30-Jan-23 11:00 | 5.8 | --- | 0.26 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 30-Jan-23 13:30 | 5.8 | 1.42 | 0.27 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 30-Jan-23 11:30 | 5.8 | --- | 0.21 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 30-Jan-23 11:25 | 5.8 | 1.71 | 0.25 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 30-Jan-23 12:55 | 5.8 | 1.55 | 0.35 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 30-Jan-23 15:15 | 5.8 | --- | 0.22 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 30-Jan-23 15:15 | 5.8 | --- | 0.21 | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 30-Jan-23 15:15 | 5.8 | 1.80 | 0.29 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 30-Jan-23 11:15 | 5.8 | 1.67 | --- | 0 | 0 | < 10 |
| 15: DW DW Chem Shed | 30-Jan-23 13:10 | 5.8 | 1.49 | --- | 0 | 0 | < 10 |
| 16: DW Comm Center | 30-Jan-23 13:55 | 5.8 | 1.47 | --- | 0 | 0 | < 10 |
| 17: DW Amberley Store | 30-Jan-23 15:35 | 5.8 | 1.62 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 30-Jan-23 15:30 | 5.8 | 1.72 | --- | 0 | 0 | --- |
| 19: DW Birch St. | 30-Jan-23 12:15 | 5.8 | 1.47 | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 30-Jan-23 11:55 | 5.8 | 1.49 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20000-FEB23

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

27-January-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 24 January 2023
 LR Report: CA21055-JAN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 25-Jan-23 | 25-Jan-23 | 25-Jan-23 |
| 2: Analysis Start Time | | --- | --- | --- | 09:45 | 09:45 | 09:20 |
| 3: Analysis Completed Date | | --- | --- | --- | 27-Jan-23 | 27-Jan-23 | 27-Jan-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 12:08 | 12:08 | 12:08 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 24-Jan-23 10:45 | 9.7 | --- | 0.21 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 24-Jan-23 10:45 | 9.7 | 1.60 | 0.25 | 0 | 0 | 20 |
| 8: RW Murdock Glen Raw Water | 24-Jan-23 10:00 | 9.7 | --- | 0.20 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 24-Jan-23 10:00 | 9.7 | 1.77 | 0.25 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 24-Jan-23 09:25 | 9.7 | 1.57 | 0.39 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 24-Jan-23 09:00 | 9.7 | --- | 0.21 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 24-Jan-23 09:00 | 9.7 | --- | 0.20 | 2 | 0 | --- |
| 13: TW Point Clark Treated Water | 24-Jan-23 08:55 | 9.7 | 1.34 | 0.25 | 0 | 0 | < 10 |
| 14: DW DW Comm Center | 24-Jan-23 09:10 | 9.7 | 1.44 | --- | 0 | 0 | < 10 |
| 15: DW DW Chem Shed | 24-Jan-23 09:20 | 9.7 | 1.44 | --- | 0 | 0 | < 10 |
| 16: DW Inverlyn CH | 24-Jan-23 10:25 | 9.7 | 1.65 | --- | 0 | 0 | < 10 |
| 17: DW Amberley Store | 24-Jan-23 08:15 | 9.7 | 1.49 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 24-Jan-23 08:25 | 9.7 | 1.72 | --- | 0 | 0 | --- |
| 19: DW Bruce Beach | 24-Jan-23 09:55 | 9.7 | 1.71 | --- | 0 | 0 | --- |
| 20: DW 766 Lake Range | 23-Jan-23 13:20 | 9.7 | 1.59 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21055-JAN23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

20-January-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 17 January 2023
 LR Report: CA20781-JAN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 18-Jan-23 | 18-Jan-23 | 18-Jan-23 |
| 2: Analysis Start Time | | --- | --- | --- | 10:30 | 10:30 | 09:55 |
| 3: Analysis Completed Date | | --- | --- | --- | 20-Jan-23 | 20-Jan-23 | 20-Jan-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 08:59 | 08:59 | 10:21 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 16-Jan-23 14:30 | 9.0 | --- | 0.29 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 16-Jan-23 14:30 | 9.0 | 1.64 | 0.23 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 16-Jan-23 14:40 | 9.0 | --- | 0.25 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 16-Jan-23 14:40 | 9.0 | 1.80 | 0.27 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 16-Jan-23 15:10 | 9.0 | 1.49 | 0.37 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 17-Jan-23 08:25 | 9.0 | --- | 0.24 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 17-Jan-23 08:25 | 9.0 | --- | 0.26 | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 17-Jan-23 08:25 | 9.0 | 1.75 | 0.29 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 17-Jan-23 14:20 | 9.0 | 1.60 | --- | 0 | 0 | < 10 |
| 15: DW DW Cher Shed | 17-Jan-23 15:20 | 9.0 | 1.35 | --- | 0 | 0 | < 10 |
| 16: DW Comm Center | 16-Jan-23 15:25 | 9.0 | 1.54 | --- | 0 | 0 | < 10 |
| 17: DW Amberley Store | 17-Jan-23 08:10 | 9.0 | 1.58 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 17-Jan-23 08:20 | 9.0 | 1.49 | --- | 0 | 0 | --- |
| 19: DW Birch St | 17-Jan-23 15:05 | 9.0 | 1.37 | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 17-Jan-23 14:50 | 9.0 | 1.66 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20781-JAN23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

13-January-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 10 January 2023
 LR Report: CA20459-JAN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 11-Jan-23 | 11-Jan-23 | 11-Jan-23 |
| 2: Analysis Start Time | | --- | --- | --- | 10:35 | 10:35 | 10:10 |
| 3: Analysis Completed Date | | --- | --- | --- | 13-Jan-23 | 13-Jan-23 | 13-Jan-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 10:07 | 10:07 | 10:07 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 09-Jan-23 13:05 | 9.6 | --- | 0.25 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 09-Jan-23 13:05 | 9.6 | 1.55 | 0.25 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 09-Jan-23 12:15 | 9.6 | --- | 0.19 | 1 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 09-Jan-23 12:15 | 9.6 | 1.37 | 0.23 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 09-Jan-23 11:45 | 9.6 | 1.53 | 0.37 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 09-Jan-23 13:45 | 9.6 | --- | 0.21 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 09-Jan-23 13:45 | 9.6 | --- | 0.21 | 6 | 0 | --- |
| 13: TW Point Clark Treated Water | 09-Jan-23 13:45 | 9.6 | 1.80 | 0.27 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 09-Jan-23 12:40 | 9.6 | 1.55 | --- | 0 | 0 | < 10 |
| 15: DW DW Comm Center | 09-Jan-23 11:05 | 9.6 | 1.40 | --- | 0 | 0 | < 10 |
| 16: DW Chem Shed | 09-Jan-23 11:20 | 9.6 | 1.33 | --- | 0 | 0 | < 10 |
| 17: DW Amberley Stone | 09-Jan-23 14:20 | 9.6 | 1.37 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 09-Jan-23 14:05 | 9.6 | 1.51 | --- | 0 | 0 | --- |
| 19: DW Birch St. | 09-Jan-23 11:25 | 9.6 | 1.44 | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 09-Jan-23 12:00 | 9.6 | 1.55 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20459-JAN23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-January-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 03 January 2023
LR Report: CA20099-JAN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 04-Jan-23 | 04-Jan-23 | 04-Jan-23 |
| 2: Analysis Start Time | | --- | --- | --- | 15:15 | 15:15 | 14:35 |
| 3: Analysis Completed Date | | --- | --- | --- | 06-Jan-23 | 06-Jan-23 | 06-Jan-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 14:26 | 14:26 | 14:26 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 03-Jan-23 08:10 | 10.8 | --- | 0.19 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 03-Jan-23 08:10 | 10.8 | 1.61 | 0.26 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 03-Jan-23 08:25 | 10.8 | --- | 0.22 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 03-Jan-23 08:25 | 10.8 | 1.75 | 0.27 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 03-Jan-23 09:10 | 10.8 | 1.44 | 0.33 | 0 | 0 | < 10 |
| 11: RW Point Clark Raw Water #2 | 03-Jan-23 09:30 | 10.8 | --- | 0.19 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 03-Jan-23 09:30 | 10.8 | --- | 0.22 | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 03-Jan-23 09:30 | 10.8 | 1.83 | 0.29 | 0 | 0 | < 10 |
| 14: DW DW Inverlyn CH | 03-Jan-23 08:00 | 10.8 | 1.65 | --- | 0 | 0 | < 10 |
| 15: DW DW Chem Shed | 03-Jan-23 08:50 | 10.8 | 1.45 | --- | 0 | 0 | < 10 |
| 16: DW Comm Center | 03-Jan-23 09:20 | 10.8 | 1.22 | --- | 0 | 0 | < 10 |
| 17: DW Amberley Store | 03-Jan-23 10:00 | 10.8 | 1.60 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Beach | 03-Jan-23 09:50 | 10.8 | 1.71 | --- | 0 | 0 | --- |
| 19: DW Birch St. | 03-Jan-23 08:55 | 10.8 | 1.46 | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 03-Jan-23 08:40 | 10.8 | 1.60 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20099-JAN23

*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

03-January-2023

Veolia Water (Lakeshore)

Attn : Nancy Mayhew

Date Rec. : 28 December 2022
LR Report: CA21138-DEC22

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Field ResCl Free mg/L | Field Turbidity NTU | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|--------------------------------------|--------------------|-----------------------------|-----------------------|---------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | --- | 29-Dec-22 | 29-Dec-22 | 29-Dec-22 |
| 2: Analysis Start Time | | --- | --- | --- | 13:40 | 13:40 | 13:05 |
| 3: Analysis Completed Date | | --- | --- | --- | 30-Dec-22 | 30-Dec-22 | 03-Jan-23 |
| 4: Analysis Completed Time | | --- | --- | --- | 14:51 | 14:51 | 13:21 |
| 5: MAC | | --- | --- | --- | 0 | 0 | --- |
| 6: RW Huronville South Raw Water | 28-Dec-22 10:15 | 10.1 | --- | 0.22 | 0 | 0 | --- |
| 7: TW Huronville South Treated Water | 28-Dec-22 10:15 | 10.1 | 1.60 | 0.27 | 0 | 0 | < 10 |
| 8: RW Murdock Glen Raw Water | 28-Dec-22 09:30 | 10.1 | --- | 0.15 | 0 | 0 | --- |
| 9: TW Murdock Glen Treated Water | 28-Dec-22 09:30 | 10.1 | 1.77 | 0.29 | 0 | 0 | < 10 |
| 10: TW Blairs Grove Treated Water | 28-Dec-22 08:50 | 10.1 | 1.48 | 0.35 | 0 | 0 | 10 |
| 11: RW Point Clark Raw Water #2 | 28-Dec-22 08:15 | 10.1 | --- | 0.17 | 0 | 0 | --- |
| 12: RW Point Clark Raw Water #3 | 28-Dec-22 08:15 | 10.1 | --- | 0.19 | 0 | 0 | --- |
| 13: TW Point Clark Treated Water | 28-Dec-22 08:10 | 10.1 | 1.66 | 0.27 | 0 | 0 | < 10 |
| 14: DW DW Amberley Store | 28-Dec-22 07:50 | 10.1 | 1.51 | --- | 0 | 0 | 10 |
| 15: DW DW Inverlyn CH | 28-Dec-22 09:55 | 10.1 | 1.47 | --- | 0 | 0 | < 10 |
| 16: DW Comm Center | 28-Dec-22 10:45 | 10.1 | 1.24 | --- | 0 | 0 | < 10 |
| 17: DW Chem Shed | 28-Dec-22 08:45 | 10.1 | 1.36 | --- | 0 | 0 | < 10 |
| 18: DW Amberley Store | 28-Dec-22 08:00 | 10.1 | 1.64 | --- | 0 | 0 | --- |
| 19: DW Birch St | 28-Dec-22 09:10 | 10.1 | 1.41 | --- | 0 | 0 | --- |
| 20: DW Bruce Beach | 28-Dec-22 09:25 | 10.1 | 1.41 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21138-DEC22

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |