



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-November-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 25 November 2025
LR Report: CA21241-NOV25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Nov-25	26-Nov-25	26-Nov-25
2: Analysis Start Time				16:00	16:00	15:30
3: Analysis Completed Date				28-Nov-25	28-Nov-25	28-Nov-25
4: Analysis Completed Time				13:57	13:57	13:57
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW - Well 3	25-Nov-25 10:26	6.3	---	0	0	---
7: TW TW1-Blairs Grove TW	25-Nov-25 10:22	6.3	1.28	0	0	< 10
8: DW DW-Chem Shed	25-Nov-25 10:41	6.3	1.30	0	0	< 10
9: DW DW-Amberley Beach SS (ACW)	25-Nov-25 08:55	6.3	1.17	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	25-Nov-25 11:27	6.3	---	0	0	---
11: TW TW2-Huronville South TW	25-Nov-25 11:25	6.3	1.54	0	0	< 10
12: DW DW-Inverlyn Club House	25-Nov-25 11:33	6.3	1.37	0	0	< 10
13: RW RW3-Point Clark RW-Well 2	25-Nov-25 09:39	6.3	---	0	0	---
14: RW RW4-Point Clark RW-Well 3	25-Nov-25 09:42	6.3	---	0	0	---
15: TW TW3-Point Clark TW	25-Nov-25 09:33	6.3	1.48	0	0	< 10
16: DW DW-Point Clark Community Centre	25-Nov-25 09:55	6.3	1.27	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-November-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 25 November 2025
LR Report: CA21236-NOV25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Nov-25	26-Nov-25	26-Nov-25
2: Analysis Start Time		---	---	15:40	15:40	15:05
3: Analysis Completed Date		---	---	28-Nov-25	28-Nov-25	28-Nov-25
4: Analysis Completed Time		---	---	13:54	13:54	13:54
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	25-Nov-25 11:05	6.3	---	0	0	---
7: TW TW4-Murdoch Glen TW	25-Nov-25 11:02	6.3	1.44	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

21-November-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 18 November 2025
LR Report: CA20868-NOV25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	19-Nov-25	19-Nov-25	19-Nov-25
2: Analysis Start Time		---	---	10:15	10:15	09:55
3: Analysis Completed Date		---	---	21-Nov-25	21-Nov-25	21-Nov-25
4: Analysis Completed Time		---	---	10:51	10:51	10:51
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	17-Nov-25 16:39	2.9	---	0	0	---
7: TW TW2-Huronville South TW	17-Nov-25 16:36	2.9	1.55	0	0	< 10
8: DW DW-Inverlyn Club House	17-Nov-25 16:46	2.9	1.57	0	0	< 10
9: RW RW5-Murdoch Glen RW-Well	17-Nov-25 16:20	2.9	---	0	0	---
10: TW TW4-Murdoch Glen TW	17-Nov-25 16:18	2.9	1.42	0	0	< 10
11: RW RW3-Point Clark RW-Well 2	17-Nov-25 15:08	2.9	---	0	0	---
12: RW RW4-Point Clark RW-Well 3	17-Nov-25 15:07	2.9	---	0	0	---
13: TW TW3-Point Clark TW	17-Nov-25 15:05	2.9	1.52	0	0	NDOGHPC
14: DW DW-Point Clark Community Centre	17-Nov-25 15:20	2.9	1.32	0	0	< 10
15: RW RW1-Blairs Grove RW-Well 3	18-Nov-25 11:59	2.9	---	0	0	---
16: TW TW1-Blairs Grove TW	18-Nov-25 11:53	2.9	0.89	0	0	< 10
17: DW DW-Chem Shed	17-Nov-25 16:03	2.9	1.26	0	0	< 10
18: DW DW-Amberly Beach SS (ACW)	17-Nov-25 14:52	2.9	1.19	0	0	< 10

MAC - Maximum Acceptable Concentration
NDOGHPC - No Data: Overgrown with HPC

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20868-NOV25

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-November-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 12 November 2025
LR Report: CA20593-NOV25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	13-Nov-25	13-Nov-25	13-Nov-25
2: Analysis Start Time		---	---	11:00	11:00	10:40
3: Analysis Completed Date		---	---	17-Nov-25	17-Nov-25	17-Nov-25
4: Analysis Completed Time		---	---	10:25	10:25	10:25
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW-Well 3	12-Nov-25 09:01	4.0	---	0	0	---
7: TW TW1-Blairs Grove TW	12-Nov-25 08:57	4.0	1.09	0	0	10
8: DW DW-Chem Shed	12-Nov-25 08:45	4.0	1.18	0	0	< 10
9: DW DW-Amberley Beach SS (ACW)	12-Nov-25 08:05	4.0	1.21	0	0	< 10
10: RW RW3-Point Clark RW-Well 2	12-Nov-25 08:24	4.0	---	0	0	---
11: RW RW4-Point Clark RW-Well 3	12-Nov-25 08:27	4.0	---	0	0	---
12: TW TW3-Point Clark TW	12-Nov-25 08:19	4.0	1.50	0	0	< 10
13: DW DW-Point Clark Community Centre	12-Nov-25 08:37	4.0	1.16	0	0	< 10
14: RW RW5-Murdoch Glen RW-Well 2	12-Nov-25 09:22	4.0	---	0	0	---
15: TW TW4-Murdoch Glen TW	12-Nov-25 09:19	4.0	1.30	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	12-Nov-25 09:46	4.0	---	0	0	---
17: TW TW2-Huronville South TW	12-Nov-25 09:43	4.0	1.57	0	0	< 10
18: DW DW-Inverlyn Club House	12-Nov-25 09:33	4.0	1.21	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20593-NOV25

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

07-November-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 04 November 2025
 LR Report: CA20220-NOV25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Nov-25	05-Nov-25	05-Nov-25
2: Analysis Start Time		---	---	09:45	09:45	09:10
3: Analysis Completed Date		---	---	07-Nov-25	07-Nov-25	07-Nov-25
4: Analysis Completed Time		---	---	11:18	11:18	11:18
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	03-Nov-25 13:22	4.6	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	03-Nov-25 13:25	4.6	---	0	0	---
8: TW TW3-Point Clark TW	03-Nov-25 13:19	4.6	1.65	0	0	< 10
9: DW DW-Point Clark Community Centre	03-Nov-25 13:38	4.6	1.22	0	0	< 10
10: RW RW1-Blairs Grove RW-Well 3	03-Nov-25 14:04	4.6	---	0	0	---
11: TW TW1-Blairs Grove TW	03-Nov-25 13:59	4.6	1.19	0	0	< 10
12: DW DW-Chem Shed	03-Nov-25 14:12	4.6	1.30	0	0	< 10
13: DW DW-Amberley Beach SS (ACW)	03-Nov-25 12:47	4.6	1.61	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	03-Nov-25 15:42	4.6	---	0	0	---
15: TW TW2-Huronville South TW	03-Nov-25 15:30	4.6	1.53	0	0	< 10
16: DW DW-Inverlyn Club House	03-Nov-25 15:48	4.6	1.61	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well 2	03-Nov-25 15:01	4.6	---	0	0	---
18: TW TW4-Murdoch Glen TW	03-Nov-25 14:58	4.6	1.30	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


 Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20220-NOV25

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

03-November-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 28 October 2025

LR Report: CA21490-OCT25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				29-Oct-25	29-Oct-25	29-Oct-25
2: Analysis Start Time				12:30	12:30	11:40
3: Analysis Completed Date				31-Oct-25	31-Oct-25	31-Oct-25
4: Analysis Completed Time				13:16	13:16	13:16
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	28-Oct-25 12:06	5.1	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	28-Oct-25 12:09	5.1	---	0	0	---
8: TW TW3-Point Clark TW	28-Oct-25 12:04	5.1	1.69	0	0	< 10
9: DW DW-Point Clark Community Centre	28-Oct-25 11:47	5.1	1.23	0	0	< 10
10: RW RW1-Blairs Grove RW-Well 3	28-Oct-25 11:20	5.1	---	0	0	---
11: TW TW1-Blairs Grove TW	28-Oct-25 11:14	5.1	1.55	0	0	< 10
12: DW DW-Chem Shed	28-Oct-25 11:27	5.1	1.34	0	0	10
13: DW DW-Amberley Beach SS (ACW)	28-Oct-25 12:17	5.1	1.12	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	28-Oct-25 12:42	5.1	---	0	0	---
15: TW TW2-Huronville South TW	28-Oct-25 12:40	5.1	1.61	0	0	< 10
16: DW DW-Inverlyn Club House	28-Oct-25 10:11	5.1	1.54	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well 2	28-Oct-25 10:46	5.1	---	0	0	---
18: TW TW4-Murdoch Glen TW	28-Oct-25 10:44	5.1	1.47	0	0	< 10

MAC - Maximum Acceptable Concentration


Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21490-OCT25



Carrie Greenlaw
Carrie Greenlaw
Project Specialist,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-October-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban

Date Rec. : 21 October 2025
LR Report: CA21104-OCT25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				22-Oct-25	22-Oct-25	22-Oct-25
2: Analysis Start Time				10:25	10:25	09:30
3: Analysis Completed Date				24-Oct-25	24-Oct-25	24-Oct-25
4: Analysis Completed Time				11:24	11:24	11:24
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	20-Oct-25 13:22	9.4	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	20-Oct-25 13:25	9.4	---	0	0	---
8: TW TW3-Point Clark TW	20-Oct-25 13:20	9.4	1.76	0	0	< 10
9: DW DW-Point Clark Community Centre	20-Oct-25 13:40	9.4	1.18	0	0	< 10
10: RW RW1-Blairs Grove RW-Well 3	20-Oct-25 14:09	9.4	---	0	0	---
11: TW TW1-Blairs Grove TW	20-Oct-25 14:03	9.4	1.98	0	0	< 10
12: DW DW-Chem Shed	20-Oct-25 13:52	9.4	1.21	0	0	< 10
13: DW DW-Amberley Beach SS (ACW)	20-Oct-25 12:54	9.4	1.09	0	0	< 10
14: RW RW5-Murdoch Glen RW-Well 2	20-Oct-25 14:33	9.4	---	0	0	---
15: TW TW4-Murdoch Glen TW	20-Oct-25 14:30	9.4	1.30	0	0	10
16: RW RW2-Huronville South RW-Well 1	20-Oct-25 14:59	9.4	---	0	0	---
17: TW TW2-Huronville South TW	20-Oct-25 14:55	9.4	1.61	0	0	< 10
18: DW DW-Inverlyn Club House	20-Oct-25 15:06	9.4	1.64	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21104-OCT25

Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-October-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban

Date Rec. : 14 October 2025
LR Report: CA20677-OCT25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				15-Oct-25	15-Oct-25	15-Oct-25
2: Analysis Start Time				13:45	13:45	12:50
3: Analysis Completed Date				17-Oct-25	17-Oct-25	17-Oct-25
4: Analysis Completed Time				11:43	11:43	11:43
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	14-Oct-25 10:47	8.9	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	14-Oct-25 10:41	8.9	---	0	0	---
8: TW TW3-Point Clark TW	14-Oct-25 10:44	8.9	1.53	0	0	< 10
9: DW DW-Point Clark Community Centre	14-Oct-25 10:59	8.9	1.17	0	0	< 10
10: RW RW1-Blairs Grove RW - Well 3	14-Oct-25 11:20	8.9	---	0	0	---
11: TW TW1-Blairs Grove TW	14-Oct-25 11:16	8.9	1.63	0	0	< 10
12: DW DW-Chem Shed	14-Oct-25 11:27	8.9	1.34	0	0	< 10
13: DW DW-Amberley Beach SS (ACW)	14-Oct-25 10:29	8.9	1.03	0	0	< 10
14: RW RW5-Murdoch Glen RW-Well 2	14-Oct-25 11:56	8.9	---	0	0	---
15: TW TW4-Murdoch Glen TW	14-Oct-25 11:58	8.9	1.40	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	14-Oct-25 12:28	8.9	---	0	0	---
17: TW TW2-Huronville South TW	14-Oct-25 12:13	8.9	1.70	0	0	< 10
18: DW DW-Inverlyn Club House	14-Oct-25 12:36	8.9	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20677-OCT25

Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-October-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 07 October 2025
LR Report: CA20388-OCT25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				08-Oct-25	08-Oct-25	08-Oct-25
2: Analysis Start Time				10:55	10:55	10:20
3: Analysis Completed Date				10-Oct-25	10-Oct-25	10-Oct-25
4: Analysis Completed Time				10:37	10:37	10:37
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	06-Oct-25 14:49	8.4	---	0	0	---
7: TW TW4-Murdoch Glen TW	06-Oct-25 14:47	8.4	1.47	0	0	< 10
8: RW RW3-Point Clark RW-Well 2	07-Oct-25 12:18	8.4	---	0	0	---
9: RW RW4-Point Clark RW-Well 3	07-Oct-25 12:14	8.4	---	0	0	---
10: TW TW3-Point Clark TW	07-Oct-25 12:10	8.4	1.45	0	0	< 10
11: DW DW-Point Clark Community Centre	07-Oct-25 12:32	8.4	1.31	0	0	< 10
12: RW RW1-Blairs Grove RW-Well 3	06-Oct-25 14:14	8.4	---	0	0	---
13: TW TW1-Blairs Grove TW	06-Oct-25 14:08	8.4	1.80	0	0	< 10
14: DW DW-Chem Shed	06-Oct-25 14:24	8.4	1.41	0	0	< 10
15: DW DW-Amberley Beach SS (ACW)	06-Oct-25 12:25	8.4	1.21	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	06-Oct-25 15:12	8.4	---	0	0	---
17: TW TW2-Huronville South TW	06-Oct-25 15:05	8.4	1.63	0	0	< 10
18: DW DW-Inverlyn Club House	06-Oct-25 15:29	8.4	1.49	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20388-OCT25

Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

06-October-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 01 October 2025
LR Report: CA20050-OCT25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	02-Oct-25	02-Oct-25	02-Oct-25
2: Analysis Start Time		---	---	10:55	10:55	10:15
3: Analysis Completed Date		---	---	06-Oct-25	06-Oct-25	06-Oct-25
4: Analysis Completed Time		---	---	09:48	09:48	09:48
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	01-Oct-25 09:58	13.6	---	0	0	---
7: TW TW4-Murdoch Glen TW	01-Oct-25 09:55	13.6	1.57	0	0	< 10
8: RW RW2-Huronville South RW-Well 1	01-Oct-25 10:13	13.6	---	0	0	---
9: TW TW2-Huronville South TW	01-Oct-25 10:15	13.6	1.72	0	0	< 10
10: DW DW-Inverlyn Club House	01-Oct-25 08:57	13.6	1.40	0	0	< 10
11: RW RW1-Blairs Grove RW- Well 3	01-Oct-25 09:08	13.6	---	0	0	---
12: TW TW1-Blairs Grove TW	01-Oct-25 09:06	13.6	1.53	0	0	< 10
13: DW DW-Chem Shed	01-Oct-25 08:36	13.6	1.20	0	0	< 10
14: DW DW-Amberley Beach SS (ACW)	01-Oct-25 08:12	13.6	1.12	0	0	< 10
15: RW RW3-Point Clark RW-Well 2	01-Oct-25 08:44	13.6	---	0	0	---
16: RW RW4-Point Clark RW-Well 3	01-Oct-25 08:42	13.6	---	0	0	---
17: TW TW3-Point Clark TW	01-Oct-25 08:40	13.6	1.41	0	0	< 10
18: DW DW-Point Clark Community Centre	01-Oct-25 08:27	13.6	1.29	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20050-OCT25

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

26-September-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 23 September 2025
 LR Report: CA21389-SEP25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				24-Sep-25	24-Sep-25	24-Sep-25
2: Analysis Start Time				09:45	09:45	09:20
3: Analysis Completed Date				26-Sep-25	26-Sep-25	26-Sep-25
4: Analysis Completed Time				11:04	11:04	11:04
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW- Well 3	22-Sep-25 14:09	13.5	---	0	0	---
7: TW TW1-Blairs Grove TW	22-Sep-25 14:13	13.5	1.56	0	0	< 10
8: DW DW-Chem Shed	22-Sep-25 14:25	13.5	1.53	0	0	< 10
9: DW DW-Amberly Beach SS (ACW)	22-Sep-25 12:50	13.5	1.12	0	0	< 10
10: RW RW5-Murdoch Glen RW-Well 2	22-Sep-25 15:07	13.5	---	0	0	---
11: TW TW4-Murdoch Glen TW	22-Sep-25 15:04	13.5	1.51	0	0	< 10
12: RW RW3-Point Clark RW-Well 2	22-Sep-25 13:19	13.5	---	0	0	---
13: RW RW4-Point Clark RW-Well 3	22-Sep-25 13:16	13.5	---	0	0	---
14: TW TW3-Point Clark TW	22-Sep-25 13:14	13.5	1.41	0	0	< 10
15: DW DW-Point Clark Community Centre	22-Sep-25 13:45	13.5	1.27	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	22-Sep-25 15:45	13.5	---	0	0	---
17: TW TW2-Huronville South TW	22-Sep-25 15:23	13.5	1.65	0	0	< 10
18: DW DW-Inverlyn Club House	22-Sep-25 15:35	13.5	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21389-SEP25

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

22-September-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 16 September 2025
 LR Report: CA21013-SEP25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				17-Sep-25	17-Sep-25	17-Sep-25
2: Analysis Start Time				17:15	17:15	16:35
3: Analysis Completed Date				19-Sep-25	19-Sep-25	19-Sep-25
4: Analysis Completed Time				16:00	16:00	16:00
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	16-Sep-25 12:20	5.4	---	0	0	---
7: TW TW2-Huronville South TW	16-Sep-25 12:05	5.4	1.63	0	0	< 10
8: DW DW-Inverlyn Club House	16-Sep-25 12:31	5.4	1.59	0	0	< 10
9: RW RW1-Blairs Grove RW-Well 3	16-Sep-25 10:39	5.4	---	0	0	---
10: TW TW1-Blairs Grove TW	16-Sep-25 10:34	5.4	1.51	0	0	20
11: DW DW-Chem Shed	16-Sep-25 11:11	5.4	1.34	0	0	< 10
12: DW DW-Amberly Beach SS (ACW)	16-Sep-25 09:00	5.4	1.32	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	16-Sep-25 11:39	5.4	---	0	0	---
14: TW TW4-Murdoch Glen TW	16-Sep-25 11:36	5.4	1.58	0	0	< 10
15: RW RW3-Point Clark RW-Well 2	16-Sep-25 09:41	5.4	---	0	0	---
16: RW RW4-Point Clark RW-Well 3	16-Sep-25 09:16	5.4	---	0	0	---
17: TW TW3-Point Clark TW	16-Sep-25 09:27	5.4	1.40	0	0	< 10
18: DW DW-Point Clark Community Centre	16-Sep-25 10:04	5.4	1.22	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21013-SEP25

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

15-September-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 09 September 2025
LR Report: CA20607-SEP25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				10-Sep-25	10-Sep-25	10-Sep-25
2: Analysis Start Time				16:30	16:30	16:05
3: Analysis Completed Date				12-Sep-25	12-Sep-25	12-Sep-25
4: Analysis Completed Time				15:50	15:50	15:50
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	09-Sep-25 10:35	8.6	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	09-Sep-25 10:28	8.6	---	0	0	---
8: TW TW3-Point Clark TW	09-Sep-25 10:32	8.6	1.16	0	0	< 10
9: DW DW-Point Clark Community Centre	09-Sep-25 11:09	8.6	1.18	0	0	10
10: RW RW1-Blairs Grove RW-Well 3	09-Sep-25 11:31	8.6	---	0	0	---
11: TW TW1-Blairs Grove TW	09-Sep-25 11:28	8.6	1.53	0	0	< 10
12: DW DW-Chem Shed	09-Sep-25 11:41	8.6	1.40	0	0	< 10
13: DW DW-Amberly Beach SS (ACW)	09-Sep-25 10:12	8.6	1.21	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	09-Sep-25 12:30	8.6	---	0	0	---
15: TW TW2-Huronville South TW	09-Sep-25 12:25	8.6	1.71	0	0	>2000
16: DW DW-Inverlyn Club House	09-Sep-25 12:42	8.6	1.61	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well 2	09-Sep-25 13:01	8.6	---	0	0	---
18: TW TW4-Murdoch Glen TW	09-Sep-25 12:59	8.6	1.38	0	0	80

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20607-SEP25

Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

05-September-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 02 September 2025
LR Report: CA20089-SEP25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				03-Sep-25	03-Sep-25	03-Sep-25
2: Analysis Start Time				14:10	14:10	13:55
3: Analysis Completed Date				05-Sep-25	05-Sep-25	05-Sep-25
4: Analysis Completed Time				13:26	13:26	13:26
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	02-Sep-25 09:56	16.0	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	02-Sep-25 09:55	16.0	---	0	0	---
8: TW TW3-Point Clark TW	02-Sep-25 09:50	16.0	1.34	0	0	< 10
9: DW DW-Point Clark Community Centre	02-Sep-25 10:35	16.0	1.28	0	0	< 10
10: RW RW1-Blairs Grove RW - Well 3	02-Sep-25 11:05	16.0	---	0	0	---
11: TW TW1-Blairs Grove TW	02-Sep-25 10:59	16.0	1.36	0	0	30
12: DW DW-Chem Shed	02-Sep-25 11:22	16.0	1.29	0	0	< 10
13: DW DW-Amberley Beach SS (ACW)	02-Sep-25 09:06	16.0	1.30	0	0	< 10
14: RW RW5-Murdoch Glen RW-Well 2	02-Sep-25 11:47	16.0	---	0	0	---
15: TW TW4-Murdoch Glen TW	02-Sep-25 11:52	16.0	1.48	0	0	NDOGHPC
16: RW RW2-Huronville South RW-Well 1	02-Sep-25 12:37	16.0	---	0	0	---
17: TW TW2-Huronville South TW	02-Sep-25 12:21	16.0	1.75	0	0	40
18: DW DW-Inverlyn Club House	02-Sep-25 12:46	16.0	1.70	0	0	< 10

MAC - Maximum Acceptable Concentration
NDOGHPC - No Data: Overgrown with HPC

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20089-SEP25



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

29-August-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 26 August 2025
LR Report: CA21518-AUG25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	27-Aug-25	27-Aug-25	27-Aug-25
2: Analysis Start Time		---	---	13:10	13:10	12:40
3: Analysis Completed Date		---	---	29-Aug-25	29-Aug-25	29-Aug-25
4: Analysis Completed Time		---	---	14:05	14:05	14:05
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	26-Aug-25 09:03	10.4	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	26-Aug-25 09:05	10.4	---	0	0	---
8: TW TW3-Point Clark TW	26-Aug-25 09:07	10.4	1.86	0	0	< 10
9: DW DW-Point Clark Community Centre	26-Aug-25 09:35	10.4	1.36	0	0	< 10
10: RW RW1-Blairs Grove RW - Well 3	26-Aug-25 10:05	10.4	---	0	0	---
11: TW TW1-Blairs Grove TW	26-Aug-25 09:57	10.4	1.24	0	0	< 10
12: DW DW-Chem Shed	26-Aug-25 10:29	10.4	1.47	0	0	< 10
13: DW DW-Amberley Beach SS (ACW)	26-Aug-25 08:33	10.4	1.47	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	26-Aug-25 11:13	10.4	---	0	0	---
15: TW TW2-Huronville South TW	26-Aug-25 11:10	10.4	1.68	0	0	< 10
16: DW DW-Inverlyn Club House	26-Aug-25 11:28	10.4	1.68	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well 2	26-Aug-25 10:53	10.4	---	0	0	---
18: TW TW4-Murdoch Glen TW	26-Aug-25 10:51	10.4	1.58	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21518-AUG25

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

22-August-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 19 August 2025
LR Report: CA21121-AUG25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	20-Aug-25	20-Aug-25	20-Aug-25
2: Analysis Start Time		---	---	15:30	15:30	14:45
3: Analysis Completed Date		---	---	22-Aug-25	22-Aug-25	22-Aug-25
4: Analysis Completed Time		---	---	13:20	13:20	13:20
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	19-Aug-25 08:36	6.0	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	19-Aug-25 08:43	6.0	---	0	0	---
8: TW TW3-Point Clark TW	19-Aug-25 08:40	6.0	1.88	0	0	< 10
9: DW DW-Point Clark Community Centre	19-Aug-25 09:05	6.0	1.51	0	0	< 10
10: RW RW1-Blairs Grove RW- Well 3	19-Aug-25 09:42	6.0	---	0	0	---
11: TW TW1-Blairs Grove TW	19-Aug-25 09:37	6.0	1.31	0	0	< 10
12: DW DW-Chem Shed	19-Aug-25 10:00	6.0	1.62	0	0	< 10
13: DW DW-Amberley Beach SS (ACW)	19-Aug-25 08:18	6.0	1.60	0	0	< 10
14: RW RW5-Murdoch Glen RW-Well 2	19-Aug-25 10:26	6.0	---	0	0	---
15: TW TW4-Murdoch Glen TW	19-Aug-25 10:22	6.0	1.56	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	19-Aug-25 10:50	6.0	---	0	0	---
17: TW TW2-Huronville South TW	19-Aug-25 10:47	6.0	1.56	0	0	< 10
18: DW DW-Inverlyn Club House	19-Aug-25 11:12	6.0	1.59	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21121-AUG25

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

15-August-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 12 August 2025
LR Report: CA20689-AUG25

6242 Fallon Drive, Lucan
Canada, N0M 2J0

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson), Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	13-Aug-25	13-Aug-25	13-Aug-25
2: Analysis Start Time		---	---	10:15	10:15	10:00
3: Analysis Completed Date		---	---	15-Aug-25	15-Aug-25	15-Aug-25
4: Analysis Completed Time		---	---	12:03	12:03	12:03
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW-Well 3	11-Aug-25 14:24	5.6	---	0	0	---
7: TW TW1-Blairs Grove TW	11-Aug-25 14:28	5.6	1.71	0	0	10
8: DW DW-Chem Shed	11-Aug-25 14:49	5.6	1.64	0	0	< 10
9: DW DW-Amberly Beach SS (ACW)	11-Aug-25 13:21	5.6	1.87	0	0	< 10
10: RW RW3-Point Clark RW-Well 2	11-Aug-25 13:33	5.6	---	0	0	---
11: RW RW4-Point Clark RW-Well 3	11-Aug-25 13:54	5.6	---	0	0	---
12: TW TW3-Point Clark TW	11-Aug-25 13:44	5.6	2.36	0	0	< 10
13: DW DW-Point Clark Community Centre	11-Aug-25 14:11	5.6	1.91	0	0	< 10
14: RW RW5-Murdoch Glen RW-Well 2	11-Aug-25 15:00	5.6	---	0	0	---
15: TW TW4-Murdoch Glen TW	11-Aug-25 15:04	5.6	1.65	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	11-Aug-25 15:32	5.6	---	0	0	---
17: TW TW2-Huronville South TW	11-Aug-25 15:26	5.6	1.69	0	0	10
18: DW DW-Inverlyn Club House	11-Aug-25 15:45	5.6	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
Branch Manager-London



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20689-AUG25

Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

11-August-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 05 August 2025
LR Report: CA20223-AUG25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	06-Aug-25	06-Aug-25	06-Aug-25
2: Analysis Start Time		---	---	15:20	15:20	15:00
3: Analysis Completed Date		---	---	08-Aug-25	08-Aug-25	08-Aug-25
4: Analysis Completed Time		---	---	14:14	14:14	14:14
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW- Well 3	05-Aug-25 08:57	12.3	---	0	0	---
7: TW TW1-Blairs Grove TW	05-Aug-25 09:00	12.3	1.55	0	0	< 10
8: DW DW-Chem Shed	05-Aug-25 09:09	12.3	1.70	0	0	30
9: DW DW-Amberley Beach SS (ACW)	05-Aug-25 08:14	12.3	1.80	0	0	10
10: RW RW2-Huronville South RW-Well 1	05-Aug-25 09:47	12.3	---	0	0	---
11: TW TW2-Huronville South TW	05-Aug-25 09:52	12.3	1.79	0	0	< 10
12: DW DW-Inverlyn Club House	05-Aug-25 09:42	12.3	1.57	0	0	< 10
13: RW RW3-Point Clark RW-Well 2	05-Aug-25 08:23	12.3	---	0	0	---
14: RW RW4-Point Clark RW-Well 3	05-Aug-25 08:42	12.3	---	0	0	---
15: TW TW3-Point Clark TW	05-Aug-25 08:30	12.3	2.39	0	0	< 10
16: DW DW-Point Clark Community Centre	05-Aug-25 08:48	12.3	1.40	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well 2	05-Aug-25 09:31	12.3	---	0	0	---
18: TW TW4-Murdoch Glen TW	05-Aug-25 09:29	12.3	1.60	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20223-AUG25

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

01-August-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 29 July 2025
 LR Report: CA21665-JUL25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	30-Jul-25	30-Jul-25	30-Jul-25
2: Analysis Start Time		---	---	10:35	10:35	10:00
3: Analysis Completed Date		---	---	01-Aug-25	01-Aug-25	01-Aug-25
4: Analysis Completed Time		---	---	11:06	11:06	11:06
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	28-Jul-25 14:00	16.9	---	0	0	---
7: TW TW4-Murdoch Glen TW	28-Jul-25 13:55	16.9	1.55	0	0	< 10
8: RW RW3-Point Clark RW-Well 2	28-Jul-25 14:58	16.9	---	0	0	---
9: RW RW4-Point Clark RW-Well 3	28-Jul-25 15:14	16.9	---	0	0	---
10: TW TW3-Point Clark TW	28-Jul-25 15:03	16.9	1.51	0	0	< 10
11: DW DW-Point Clark Community Centre	28-Jul-25 14:49	16.9	1.76	0	0	< 10
12: RW RW1-Blairs Grove RW-Well 3	28-Jul-25 14:28	16.9	---	0	0	---
13: TW TW1-Blairs Grove TW	28-Jul-25 14:25	16.9	1.35	0	0	< 10
14: DW DW-Chem Shed	28-Jul-25 14:40	16.9	1.58	0	0	< 10
15: DW DW-Amberly Beach SS (ACW)	28-Jul-25 15:26	16.9	1.63	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	28-Jul-25 13:38	16.9	---	0	0	---
17: TW TW2-Huronville South TW	28-Jul-25 13:44	16.9	1.55	0	0	< 10
18: DW DW-Inverlyn Club House	28-Jul-25 13:26	16.9	1.29	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21665-JUL25

Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

25-July-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 22 July 2025
LR Report: CA21291-JUL25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	23-Jul-25	23-Jul-25	23-Jul-25
2: Analysis Start Time		---	---	13:15	13:15	12:10
3: Analysis Completed Date		---	---	25-Jul-25	25-Jul-25	25-Jul-25
4: Analysis Completed Time		---	---	12:14	12:14	12:14
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW- Well 3	22-Jul-25 09:13	7.7	---	0	0	---
7: TW TW1-Blairs Grove TW	22-Jul-25 09:08	7.7	1.59	0	0	< 10
8: DW DW-Chem Shed	22-Jul-25 09:20	7.7	1.58	0	0	< 10
9: DW DW-Amberly Beach SS (ACW)	22-Jul-25 08:16	7.7	1.77	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	22-Jul-25 09:55	7.7	---	0	0	---
11: TW TW2-Huronville South TW	22-Jul-25 09:59	7.7	1.68	0	0	< 10
12: DW DW-Inverlyn Club House	22-Jul-25 10:07	7.7	1.42	0	0	< 10
13: RW RW3-Point Clark RW-Well 2	22-Jul-25 08:34	7.7	---	0	0	---
14: RW RW4-Point Clark RW-Well 3	22-Jul-25 08:38	7.7	---	0	0	---
15: TW TW3-Point Clark TW	22-Jul-25 08:33	7.7	2.29	0	0	< 10
16: DW DW-Point Clark Community Centre	22-Jul-25 08:48	7.7	1.51	0	0	10
17: RW RW5-Murdoch Glen RW-Well 2	22-Jul-25 09:41	7.7	---	0	0	---
18: TW TW4-Murdoch Glen TW	22-Jul-25 09:38	7.7	1.54	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21291-JUL25

Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

18-July-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban

Date Rec. : 15 July 2025
LR Report: CA20923-JUL25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	16-Jul-25	16-Jul-25	16-Jul-25
2: Analysis Start Time		---	---	13:35	13:35	13:15
3: Analysis Completed Date		---	---	18-Jul-25	18-Jul-25	18-Jul-25
4: Analysis Completed Time		---	---	12:19	12:19	12:19
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW- Well 3	15-Jul-25 10:41	11.8	---	0	0	---
7: TW TW1-Blairs Grove TW	15-Jul-25 10:38	11.8	1.56	0	0	< 10
8: DW DW-Chem Shed	15-Jul-25 11:00	11.8	1.35	0	0	< 10
9: DW DW-Amberly Beach SS (ACW)	15-Jul-25 08:41	11.8	1.65	0	0	< 10
10: RW RW3-Point Clark RW-Well 2	15-Jul-25 09:00	11.8	---	0	0	---
11: RW RW4-Point Clark RW-Well 3	15-Jul-25 09:13	11.8	---	0	0	---
12: TW TW3-Point Clark TW	15-Jul-25 08:59	11.8	1.45	0	0	< 10
13: DW DW-Point Clark Community Centre	15-Jul-25 10:03	11.8	1.41	0	0	< 10
14: RW RW5-Murdoch Glen RW-Well 2	15-Jul-25 11:22	11.8	---	0	0	---
15: TW TW4-Murdoch Glen TW	15-Jul-25 11:19	11.8	1.57	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	15-Jul-25 11:38	11.8	---	0	0	---
17: TW TW2-Huronville South TW	15-Jul-25 11:42	11.8	1.57	0	0	< 10
18: DW DW-Inverlyn Club House	15-Jul-25 11:33	11.8	1.22	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20923-JUL25

Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-July-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 08 July 2025
 LR Report: CA20519-JUL25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				09-Jul-25	09-Jul-25	09-Jul-25
2: Analysis Start Time				15:30	15:30	15:10
3: Analysis Completed Date				11-Jul-25	11-Jul-25	11-Jul-25
4: Analysis Completed Time				13:25	13:25	13:25
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	08-Jul-25 10:24	10.5	---	0	0	---
7: TW TW2-Huronville South TW	08-Jul-25 10:28	10.5	1.73	0	0	< 10
8: DW DW-Inverlyn Club House	08-Jul-25 10:16	10.5	1.55	0	0	< 10
9: RW RW5-Murdoch Glen RW-Well 2	08-Jul-25 10:03	10.5	---	0	0	---
10: TW TW4-Murdoch Glen TW	08-Jul-25 09:59	10.5	1.53	0	0	< 10
11: RW RW1-Blairs Grove RW - Well 3	08-Jul-25 09:32	10.5	---	0	0	---
12: TW TW1-Blairs Grove TW	08-Jul-25 09:33	10.5	1.64	0	0	< 10
13: DW DW-Chem Shed	08-Jul-25 09:43	10.5	1.78	0	0	< 10
14: DW DW-Amberly Beach SS (ACW)	08-Jul-25 08:21	10.5	1.70	0	0	< 10
15: RW RW3-Point Clark RW-Well 2	08-Jul-25 08:40	10.5	---	0	0	---
16: RW RW4-Point Clark RW-Well 3	08-Jul-25 08:55	10.5	---	0	0	---
17: TW TW3-Point Clark TW	08-Jul-25 08:39	10.5	1.56	0	0	< 10
18: DW DW-Point Clark Community Centre	08-Jul-25 09:04	10.5	1.79	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20519-JUL25

Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-July-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 02 July 2025
LR Report: CA20110-JUL25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1


Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				03-Jul-25	03-Jul-25	03-Jul-25
2: Analysis Start Time				16:40	16:40	16:05
3: Analysis Completed Date				07-Jul-25	07-Jul-25	07-Jul-25
4: Analysis Completed Time				11:14	11:14	11:14
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW- Well 3	02-Jul-25 09:46	14.5	---	0	0	---
7: TW TW1-Blairs Grove TW	02-Jul-25 09:38	14.5	1.70	0	0	200
8: DW DW-Chem Shed	02-Jul-25 09:55	14.5	2.12	0	0	< 10
9: DW DW-Amberly Beach SS (ACW)	02-Jul-25 08:36	14.5	1.81	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	02-Jul-25 10:42	14.5	---	0	0	---
11: TW TW2-Huronville South TW	02-Jul-25 10:48	14.5	1.73	0	0	< 10
12: DW DW-Inverlyn Club House	02-Jul-25 11:07	14.5	1.63	0	0	< 10
13: RW RW3-Point Clark RW-Well 2	02-Jul-25 08:47	14.5	---	0	0	---
14: RW RW4-Point Clark RW-Well 3	02-Jul-25 09:10	14.5	---	0	0	---
15: TW TW3-Point Clark TW	02-Jul-25 08:53	14.5	1.75	0	0	< 10
16: DW DW-Point Clark Community Centre	02-Jul-25 09:19	14.5	1.74	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well 2	02-Jul-25 10:19	14.5	---	0	0	---
18: TW TW4-Murdoch Glen TW	02-Jul-25 10:14	14.5	1.59	0	0	< 10

MAC - Maximum Acceptable Concentration


 Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20110-JUL25

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

30-June-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 24 June 2025
LR Report: CA21546-JUN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1


Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				25-Jun-25	25-Jun-25	25-Jun-25
2: Analysis Start Time				15:30	15:30	14:50
3: Analysis Completed Date				27-Jun-25	27-Jun-25	27-Jun-25
4: Analysis Completed Time				14:58	14:58	14:58
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW- Well 3	24-Jun-25 09:59	14.9	---	0	0	---
7: TW TW1-Blairs Grove TW	24-Jun-25 09:53	14.9	2.34	0	0	< 10
8: DW DW-Chem Shed	24-Jun-25 10:06	14.9	2.17	0	0	< 10
9: DW DW-Amberly Beach SS (ACW)	24-Jun-25 07:57	14.9	1.84	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	24-Jun-25 09:18	14.9	---	0	0	---
11: TW TW2-Huronville South TW	24-Jun-25 09:14	14.9	1.89	0	0	< 10
12: DW DW-Inverlyn Club House	24-Jun-25 09:07	14.9	1.62	0	0	< 10
13: RW RW3-Point Clark RW-Well 2	24-Jun-25 10:42	14.9	---	0	0	---
14: RW RW4-Point Clark RW-Well 3	24-Jun-25 10:58	14.9	---	0	0	---
15: TW TW3-Point Clark TW	24-Jun-25 10:45	14.9	1.80	0	0	10
16: DW DW-Point Clark Community Centre	24-Jun-25 10:33	14.9	1.66	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well 2	24-Jun-25 08:56	14.9	---	0	0	---
18: TW TW4-Murdoch Glen TW	24-Jun-25 08:54	14.9	1.50	0	0	< 10

MAC - Maximum Acceptable Concentration


 Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA21546-JUN25

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

23-June-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 17 June 2025
LR Report: CA21144-JUN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				18-Jun-25	18-Jun-25	18-Jun-25
2: Analysis Start Time				16:50	16:50	16:20
3: Analysis Completed Date				20-Jun-25	20-Jun-25	20-Jun-25
4: Analysis Completed Time				17:55	17:55	17:55
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	17-Jun-25 10:43	10.8	---	0	0	---
7: TW TW2-Huronville South TW	17-Jun-25 10:40	10.8	1.98	0	0	< 10
8: DW DW-Inverlyn Club House	17-Jun-25 10:50	10.8	1.89	0	0	< 10
9: RW RW5-Murdoch Glen RW-Well 2	17-Jun-25 10:25	10.8	---	0	0	---
10: TW TW4-Murdoch Glen TW	17-Jun-25 10:23	10.8	1.58	0	0	< 10
11: RW RW1-Blairs Grove RW- Well 3	17-Jun-25 09:20	10.8	---	0	0	---
12: TW TW1-Blairs Grove TW	17-Jun-25 09:18	10.8	1.88	0	0	< 10
13: DW DW-Chem Shed	17-Jun-25 09:01	10.8	1.75	0	0	< 10
14: DW DW-Amberly Beach SS (ACW)	17-Jun-25 08:19	10.8	1.54	0	0	< 10
15: RW RW3-Point Clark RW-Well 2	17-Jun-25 08:31	10.8	---	0	0	---
16: RW RW4-Point Clark RW-Well 3	17-Jun-25 08:33	10.8	---	0	0	---
17: TW TW3-Point Clark TW	17-Jun-25 08:38	10.8	2.58	0	0	< 10
18: DW DW-Point Clark Community Centre	17-Jun-25 08:50	10.8	2.04	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

09-June-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 03 June 2025
LR Report: CA20241-JUN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Jun-25	04-Jun-25	04-Jun-25
2: Analysis Start Time				09:40	09:40	09:30
3: Analysis Completed Date				06-Jun-25	06-Jun-25	06-Jun-25
4: Analysis Completed Time				11:10	11:10	11:10
5: MAC		---	---	0	0	---
6: TW TW1-Blairs Grove TW	03-Jun-25 08:48	11.0	1.44	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-June-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 03 June 2025
 LR Report: CA20240-JUN25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Jun-25	04-Jun-25	04-Jun-25
2: Analysis Start Time				09:40	09:40	09:30
3: Analysis Completed Date				06-Jun-25	06-Jun-25	06-Jun-25
4: Analysis Completed Time				11:10	11:10	11:10
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	02-Jun-25 13:52	11.0	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	02-Jun-25 14:17	11.0	---	0	0	---
8: TW TW3-Point Clark TW	02-Jun-25 14:12	11.0	1.35	0	0	< 10
9: DW DW-Point Clark Community Centre	02-Jun-25 14:35	11.0	1.50	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	02-Jun-25 15:44	11.0	---	0	0	---
11: TW TW2-Huronville South TW	02-Jun-25 15:39	11.0	1.85	0	0	< 10
12: DW DW-Inverlyn Club House	02-Jun-25 15:58	11.0	1.74	0	0	< 10
13: RW RW5 Murdoch Glen RW-Well 2	02-Jun-25 15:13	11.0	---	0	0	---
14: TW TW4-Murdoch Glen TW	02-Jun-25 15:04	11.0	1.60	0	0	< 10
15: DW DW-Chem Shed	02-Jun-25 16:15	11.0	1.48	0	0	< 10
16: DW DW-Amberly Beach SS (ACW)	02-Jun-25 13:33	11.0	1.39	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

04-June-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 31 May 2025
LR Report: CA21655-MAY25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				31-May-25	31-May-25	31-May-25
2: Analysis Start Time				12:55	12:55	12:45
3: Analysis Completed Date				02-Jun-25	02-Jun-25	02-Jun-25
4: Analysis Completed Time				16:10	16:10	16:10
5: MAC		---	---	0	0	---
6: TW TW1-Huronville TW	30-May-25 13:36	7.7	1.32	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20240-JUN25



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

30-May-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 27 May 2025

LR Report: CA21523-MAY25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				28-May-25	28-May-25	28-May-25
2: Analysis Start Time				09:35	09:35	09:15
3: Analysis Completed Date				30-May-25	30-May-25	30-May-25
4: Analysis Completed Time				12:02	12:02	12:02
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	26-May-25 14:59	6.4	---	0	0	---
7: TW TW2-Huronville South TW	26-May-25 14:56	6.4	1.75	0	0	< 10
8: DW DW-Inverlyn Club House	26-May-25 15:08	6.4	1.60	0	0	< 10
9: RW RW3-Point Clark RW-Well 2	26-May-25 13:40	6.4	---	0	0	---
10: RW RW4-Point Clark RW-Well 3	26-May-25 13:18	6.4	---	0	0	---
11: TW TW3-Point Clark TW	26-May-25 13:10	6.4	2.62	0	0	< 10
12: DW DW-Point Clark Community Centre	26-May-25 13:50	6.4	1.38	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	26-May-25 14:32	6.4	---	0	0	---
14: TW TW4-Murdoch Glen TW	26-May-25 14:30	6.4	1.48	0	0	< 10
15: DW DW-Chem Shed	26-May-25 14:00	6.4	1.44	0	0	< 10
16: DW DW-Amberly Beach SS (ACW)	26-May-25 12:50	6.4	1.44	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21523-MAY25



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

23-May-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 20 May 2025

LR Report: CA21043-MAY25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				21-May-25	21-May-25	21-May-25
2: Analysis Start Time				11:00	11:00	10:30
3: Analysis Completed Date				23-May-25	23-May-25	23-May-25
4: Analysis Completed Time				11:27	11:27	11:27
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	20-May-25 09:58	12.7	---	0	0	---
7: TW TW2-Huronville South TW	20-May-25 10:03	12.7	1.76	0	0	< 10
8: DW DW-Inverlyn Club House	20-May-25 10:17	12.7	1.68	0	0	< 10
9: RW RW3-Point Clark RW-Well 2	20-May-25 08:27	12.7	---	0	0	---
10: RW RW4-Point Clark RW-Well 3	20-May-25 08:26	12.7	---	0	0	---
11: TW TW3-Point Clark TW	20-May-25 08:35	12.7	1.67	0	0	< 10
12: DW DW-Point Clark Community Centre	20-May-25 08:57	12.7	1.34	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	20-May-25 09:34	12.7	---	0	0	---
14: TW TW4-Murdoch Glen TW	20-May-25 09:32	12.7	1.48	0	0	< 10
15: DW DW-Chem Shed	20-May-25 09:07	12.7	1.56	0	0	< 10
16: DW DW-Amberly Beach SS (ACW)	20-May-25 08:18	12.7	1.54	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21043-MAY25



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

16-May-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 13 May 2025

LR Report: CA20744-MAY25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	14-May-25	14-May-25	14-May-25
2: Analysis Start Time		---	---	10:00	10:00	09:35
3: Analysis Completed Date		---	---	16-May-25	16-May-25	16-May-25
4: Analysis Completed Time		---	---	10:44	10:44	10:44
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	12-May-25 15:13	11.9	---	0	0	---
7: TW TW2-Huronville South TW	12-May-25 15:15	11.9	1.80	0	0	< 10
8: DW DW-Inverlyn Club House	12-May-25 15:04	11.9	1.62	0	0	< 10
9: RW RW3-Point Clark RW-Well 2	12-May-25 12:43	11.9	---	0	0	---
10: RW RW4-Point Clark RW-Well 3	12-May-25 12:42	11.9	---	0	0	---
11: TW TW3-Point Clark TW	12-May-25 12:53	11.9	1.78	0	0	< 10
12: DW DW-Point Clark Community Centre	12-May-25 13:26	11.9	1.37	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	12-May-25 14:16	11.9	---	0	0	---
14: TW TW4-Murdoch Glen TW	12-May-25 14:12	11.9	1.60	0	0	< 10
15: DW DW-Chem Shed	12-May-25 13:33	11.9	1.56	0	0	< 10
16: DW DW-Amberley Beach SS (ACW)	12-May-25 12:33	11.9	1.38	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20744-MAY25



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

09-May-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 06 May 2025

LR Report: CA20298-MAY25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				07-May-25	07-May-25	07-May-25
2: Analysis Start Time				09:35	09:35	09:15
3: Analysis Completed Date				09-May-25	09-May-25	09-May-25
4: Analysis Completed Time				11:14	11:14	11:14
5: MAC		---	---	0	0	---
6: DW DW-Chem Shed	05-May-25 13:53	10.8	1.47	0	0	< 10
7: DW DW-Amberly Beach SS (ACW)	05-May-25 12:38	10.8	1.29	0	0	< 10
8: RW RW3-Point Clark RW-Well 2	05-May-25 13:25	10.8	---	0	0	---
9: RW RW4-Point Clark RW-Well 3	05-May-25 13:26	10.8	---	0	0	---
10: TW TW3-Point Clark TW	05-May-25 13:09	10.8	1.80	0	0	< 10
11: DW DW-Point Clark Community Centre	05-May-25 13:45	10.8	1.38	0	0	< 10
12: RW RW2-Huronville South RW-Well 1	05-May-25 15:18	10.8	---	0	0	---
13: TW TW2-Huronville South TW	05-May-25 15:14	10.8	1.75	0	0	10
14: DW DW-Inverlyn Club House	05-May-25 15:03	10.8	1.72	0	0	< 10
15: RW RW5-Murdoch Glen RW-Well 2	05-May-25 14:43	10.8	---	0	0	---
16: TW TW4-Murdoch Glen TW	05-May-25 14:34	10.8	1.34	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20298-MAY25



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

02-May-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 29 April 2025

LR Report: CA21613-APR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	30-Apr-25	30-Apr-25	30-Apr-25
2: Analysis Start Time		---	---	09:35	09:35	09:10
3: Analysis Completed Date		---	---	02-May-25	02-May-25	02-May-25
4: Analysis Completed Time		---	---	09:41	09:41	09:41
5: MAC		---	---	0	0	---
6: DW DW-Chem Shed	28-Apr-25 13:31	9.7	1.50	0	0	< 10
7: DW DW-Amberley Beach SS (ACW)	28-Apr-25 12:33	9.7	1.18	0	0	< 10
8: RW RW3-Point Clark RW-Well 2	28-Apr-25 12:44	9.7	---	0	0	---
9: RW RW4-Point Clark RW-Well 3	28-Apr-25 13:10	9.7	---	0	0	---
10: TW TW3-Point Clark TW	28-Apr-25 12:53	9.7	1.79	0	0	< 10
11: DW DW-Point Clark Community Centre	28-Apr-25 13:22	9.7	1.48	0	0	< 10
12: RW RW5-Murdoch Glen RW-Well 2	28-Apr-25 14:03	9.7	---	0	0	---
13: TW TW4-Murdoch Glen TW	28-Apr-25 14:02	9.7	1.34	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	28-Apr-25 14:19	9.7	---	0	0	---
15: TW TW2-Huronville South TW	28-Apr-25 14:24	9.7	1.84	0	0	< 10
16: DW DW-Inverlyn Club House	28-Apr-25 14:35	9.7	1.47	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21613-APR25

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

25-April-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban
Date Rec. : 22 April 2025

LR Report: CA21167-APR25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				23-Apr-25	23-Apr-25	23-Apr-25
2: Analysis Start Time				10:30	10:30	10:05
3: Analysis Completed Date				25-Apr-25	25-Apr-25	25-Apr-25
4: Analysis Completed Time				10:47	10:47	10:47
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	22-Apr-25 10:46	12.3	---	0	0	---
7: TW TW4-Murdoch Glen TW	22-Apr-25 10:43	12.3	1.60	0	0	< 10
8: RW RW2-Huronville South RW-Well 1	22-Apr-25 11:03	12.3	---	0	0	---
9: TW TW2-Huronville South TW	22-Apr-25 11:10	12.3	1.55	0	0	< 10
10: DW DW-Inverlyn Club House	22-Apr-25 11:20	12.3	1.43	0	0	< 10
11: RW RW3-Point Clark RW-Well 2	22-Apr-25 09:50	12.3	---	0	0	---
12: RW RW4-Point Clark RW-Well 3	22-Apr-25 09:52	12.3	---	0	0	---
13: TW TW3-Point Clark TW	22-Apr-25 09:09	12.3	1.80	0	0	< 10
14: DW DW-Point Clark Community Centre	22-Apr-25 10:05	12.3	1.34	0	0	< 10
15: DW DW-Chem Shed	22-Apr-25 10:14	12.3	1.39	0	0	< 10
16: DW DW-Amberly Beach SS (ACW)	22-Apr-25 08:45	12.3	1.20	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21167-APR25



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-April-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 14 April 2025

LR Report: CA20689-APR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				14-Apr-25	14-Apr-25	14-Apr-25
2: Analysis Start Time				16:40	16:40	16:10
3: Analysis Completed Date				16-Apr-25	16-Apr-25	16-Apr-25
4: Analysis Completed Time				17:53	17:53	17:53
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	14-Apr-25 11:20	10.0	---	0	0	---
7: TW TW2-Huronville South TW	14-Apr-25 11:28	10.0	1.53	0	0	10
8: DW DW-Inverlyn Club House	14-Apr-25 11:08	10.0	1.25	0	0	< 10
9: DW DW-Chem Shed	14-Apr-25 09:27	10.0	1.51	0	0	< 10
10: DW DW-Amberly Beach SS (ACW)	14-Apr-25 08:39	10.0	1.42	0	0	< 10
11: RW RW3-Point Clark RW-Well 2	14-Apr-15 08:49	10.0	---	0	0	---
12: RW RW4-Point Clark RW-Well 3	14-Apr-15 08:54	10.0	---	0	0	---
13: TW TW3-Point Clark TW	14-Apr-15 08:55	10.0	1.81	0	0	< 10
14: DW DW-Point Clark Community Centre	14-Apr-15 09:16	10.0	1.41	0	0	< 10
15: RW RW5-Murdoch Glen RW-Well 2	14-Apr-25 10:29	10.0	---	0	0	---
16: TW TW4-Murdoch Glen TW	14-Apr-25 10:23	10.0	2.30	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20689-APR25

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

11-April-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 08 April 2025

LR Report: CA20502-APR25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				09-Apr-25	09-Apr-25	09-Apr-25
2: Analysis Start Time				10:15	10:15	09:50
3: Analysis Completed Date				11-Apr-25	11-Apr-25	11-Apr-25
4: Analysis Completed Time				10:34	10:34	10:34
5: MAC		---	---	0	0	---
6: DW DW-Chem Shed	07-Apr-25 13:41	5.1	1.63	0	0	< 10
7: DW DW-Amberly Beach SS (ACW)	07-Apr-25 12:49	5.1	1.54	0	0	< 10
8: RW RW3-Point Clark RW-Well 2	07-Apr-25 13:01	5.1	---	0	0	---
9: RW RW4-Point Clark RW-Well 3	07-Apr-25 13:17	5.1	---	0	0	---
10: TW TW3-Point Clark TW	07-Apr-25 13:14	5.1	1.92	0	0	< 10
11: DW DW-Point Clark Community Centre	07-Apr-25 13:33	5.1	1.45	0	0	< 10
12: RW RW5-Murdoch Glen RW-Well 2	07-Apr-25 13:23	5.1	---	0	0	---
13: TW TW4-Murdoch Glen TW	07-Apr-25 13:19	5.1	2.11	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	07-Apr-25 13:51	5.1	---	0	0	---
15: TW TW2-Huronville South TW	07-Apr-25 14:17	5.1	1.51	0	0	< 10
16: DW DW-Inverlyn Club House	07-Apr-25 14:41	5.1	1.56	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20502-APR25



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

04-April-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 01 April 2025

LR Report: CA20132-APR25

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	02-Apr-25	02-Apr-25	02-Apr-25
2: Analysis Start Time		---	---	10:45	10:45	10:10
3: Analysis Completed Date		---	---	04-Apr-25	04-Apr-25	04-Apr-25
4: Analysis Completed Time		---	---	10:50	10:50	10:50
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	31-Mar-25 14:09	6.9	---	0	0	---
7: TW TW2-Huronville South TW	31-Mar-25 14:11	6.9	1.55	0	0	< 10
8: DW DW-Inverlyn Club House	31-Mar-25 14:28	6.9	1.29	0	0	< 10
9: RW RW3-Point Clark RW-Well 2	31-Mar-25 13:49	6.9	---	0	0	---
10: RW RW4-Point Clark RW-Well 3	31-Mar-25 13:50	6.9	---	0	0	---
11: TW TW3-Point Clark TW	31-Mar-25 13:19	6.9	1.80	0	0	< 10
12: DW DW-Point Clark Community Centre	31-Mar-25 14:04	6.9	1.53	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	31-Mar-25 13:14	6.9	---	0	0	---
14: TW TW4-Murdoch Glen TW	31-Mar-25 13:12	6.9	2.40	0	0	< 10
15: DW DW-Chem Shed	31-Mar-25 14:13	6.9	1.58	0	0	< 10
16: DW DW-Amberly Beach SS (ACW)	31-Mar-25 12:48	6.9	1.60	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20132-APR25

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-March-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban

Date Rec. : 25 March 2025
LR Report: CA21180-MAR25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Mar-25	26-Mar-25	26-Mar-25
2: Analysis Start Time				10:00	10:00	09:45
3: Analysis Completed Date				28-Mar-25	28-Mar-25	28-Mar-25
4: Analysis Completed Time				11:10	11:10	11:10
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	24-Mar-25 13:16	8.1	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	24-Mar-25 13:18	8.1	---	0	0	---
8: TW TW3-Point Clark TW	24-Mar-25 13:25	8.1	1.97	0	0	< 10
9: DW DW-Point Clark Community Centre	24-Mar-25 13:43	8.1	1.53	0	0	< 10
10: DW DW-Chem Shed	24-Mar-25 14:01	8.1	1.51	0	0	< 10
11: DW DW-Amberly Beach SS (ACW)	24-Mar-25 14:24	8.1	1.64	0	0	< 10
12: RW RW5-Murdoch Glen RW-Well 2	24-Mar-25 14:59	8.1	---	0	0	---
13: TW TW4-Murdoch Glen TW	24-Mar-25 14:54	8.1	2.48	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	24-Mar-25 15:09	8.1	---	0	0	---
15: TW TW2-Huronville South TW	24-Mar-25 15:19	8.1	1.59	0	0	< 10
16: DW DW-Inverlyn Club House	24-Mar-25 15:27	8.1	1.60	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21180-MAR25

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

21-March-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 18 March 2025
LR Report: CA20881-MAR25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				19-Mar-25	19-Mar-25	19-Mar-25
2: Analysis Start Time				09:35	09:35	09:10
3: Analysis Completed Date				21-Mar-25	21-Mar-25	21-Mar-25
4: Analysis Completed Time				10:08	10:08	10:08
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	17-Mar-25 14:37	11.9	---	0	0	---
7: TW TW4-Murdoch Glen TW	17-Mar-25 14:32	11.9	2.54	0	0	< 10
8: DW DW-Chem Shed	17-Mar-25 13:54	11.9	1.58	0	0	< 10
9: DW DW-Amberly Beach SS (ACW)	17-Mar-25 13:02	11.9	1.56	0	0	< 10
10: RW RW3-Point Clark RW-Well 2	17-Mar-25 13:16	11.9	---	0	0	---
11: RW RW4-Point Clark RW-Well 3	17-Mar-25 13:29	11.9	---	0	0	---
12: TW TW3-Point Clark TW	17-Mar-25 13:23	11.9	1.94	0	0	< 10
13: DW DW-Point Clark Community Centre	17-Mar-25 13:45	11.9	1.62	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	17-Mar-25 14:53	11.9	---	0	0	---
15: TW TW2-Huronville South TW	17-Mar-25 15:00	11.9	1.54	0	0	< 10
16: DW DW-Inverlyn Club House	17-Mar-25 15:09	11.9	1.28	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20881-MAR25

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-March-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban

Date Rec. : 11 March 2025
LR Report: CA20507-MAR25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Mar-25	12-Mar-25	12-Mar-25
2: Analysis Start Time				11:00	11:00	10:30
3: Analysis Completed Date				14-Mar-25	14-Mar-25	14-Mar-25
4: Analysis Completed Time				11:47	11:47	11:47
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	10-Mar-25 14:08	8.3	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	10-Mar-25 14:01	8.3	---	0	0	---
8: TW TW3-Point Clark TW	10-Mar-25 13:11	8.3	1.94	0	0	< 10
9: DW DW-Point Clark Community Centre	10-Mar-25 13:21	8.3	1.52	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	10-Mar-25 14:25	8.3	---	0	0	---
11: TW TW2-Huronville South TW	10-Mar-25 14:26	8.3	1.46	0	0	< 10
12: DW DW-Inverlyn Club House	10-Mar-25 14:36	8.3	1.26	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	10-Mar-25 14:10	8.3	---	0	0	---
14: TW TW4-Murdoch Glen TW	10-Mar-25 14:04	8.3	2.48	0	0	< 10
15: DW DW-Chem Shed	10-Mar-25 13:55	8.3	1.64	0	0	< 10
16: DW DW-Amberly Store	10-Mar-25 12:50	8.3	1.32	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20507-MAR25

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-March-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban

Date Rec. : 04 March 2025
LR Report: CA20174-MAR25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Mar-25	05-Mar-25	05-Mar-25
2: Analysis Start Time				10:25	10:25	09:35
3: Analysis Completed Date				07-Mar-25	07-Mar-25	07-Mar-25
4: Analysis Completed Time				09:53	09:53	09:53
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	03-Mar-25 12:39	8.6	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	03-Mar-25 12:55	8.6	---	0	0	---
8: TW TW3-Point Clark TW	03-Mar-25 12:46	8.6	1.57	0	0	< 10
9: DW DW-Point Clark Community Centre	03-Mar-25 12:49	8.6	1.68	0	0	< 10
10: RW RW5-Murdoch Glen RW-Well 2	03-Mar-25 13:26	8.6	---	0	0	---
11: TW TW4-Murdoch Glen TW	03-Mar-25 13:21	8.6	2.40	0	0	< 10
12: RW RW2-Huronville South RW-Well 1	03-Mar-25 13:53	8.6	---	0	0	---
13: TW TW2-Huronville South TW	03-Mar-25 13:46	8.6	1.45	0	0	< 10
14: DW DW-Inverlyn Club House	03-Mar-25 13:16	8.6	1.66	0	0	< 10
15: DW DW-Chem Shed	03-Mar-25 13:00	8.6	1.64	0	0	< 10
16: DW DW-Amberly Store (ACW)	03-Mar-25 12:35	8.6	1.42	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20174-MAR25

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21160-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	24-Feb-25 13:34	7.8	---	0	0	---
7: TW TW4-Murdoch Glen TW	24-Feb-25 13:31	7.8	2.52	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21161-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	24-Feb-25 13:47	7.8	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	24-Feb-25 13:49	7.8	---	0	0	---
8: TW TW3-Point Clark TW	24-Feb-25 13:30	7.8	1.65	0	0	< 10
9: DW DW-Point Clark Community Centre	24-Feb-25 14:14	7.8	1.37	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21162-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	24-Feb-25 14:08	7.8	---	0	0	---
7: TW TW2-Huronville South TW	24-Feb-25 14:05	7.8	1.53	0	0	< 10
8: DW DW-Inverlyn Club House	24-Feb-25 14:22	7.8	1.35	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21163-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time				09:55	09:55	09:20
3: Analysis Completed Date				28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time				10:41	10:41	10:41
5: MAC		---	---	0	0	---
6: DW DW-Chem Shed	24-Feb-25 14:25	7.8	1.41	0	0	< 10
7: DW DW-Amberly Store (ACW)	24-Feb-25 13:05	7.8	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 19 February 2025
LR Report: CA21029-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	20-Feb-25	20-Feb-25	20-Feb-25
2: Analysis Start Time		---	---	12:55	12:55	12:25
3: Analysis Completed Date		---	---	24-Feb-25	24-Feb-25	24-Feb-25
4: Analysis Completed Time		---	---	10:15	10:15	10:15
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	19-Feb-25 09:23	10.8	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	19-Feb-25 09:01	10.8	---	0	0	---
8: TW TW3-Point Clark TW	19-Feb-25 09:04	10.8	1.02	0	0	< 10
9: DW DW-Point Clark Community Centre	19-Feb-25 09:38	10.8	1.77	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	19-Feb-25 10:35	10.8	---	0	0	---
11: TW TW2-Huronville South TW	19-Feb-25 10:31	10.8	1.53	0	0	< 10
12: DW DW-Inverlyn Club House	19-Feb-25 10:49	10.8	1.24	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	19-Feb-25 10:15	10.8	---	0	0	---
14: TW TW4-Murdoch Glen TW	19-Feb-25 10:10	10.8	2.40	0	0	< 10
15: DW DW-Chem Shed	19-Feb-25 09:49	10.8	1.81	0	0	< 10
16: DW DW-Amberly Store (ACW)	19-Feb-25 08:45	10.8	1.82	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21029-FEB25



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
LR Report: CA20724-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:45	10:45	10:45
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	10-Feb-25 14:12	5.6	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	10-Feb-25 14:14	5.6	---	0	0	---
8: TW TW3-Point Clark TW	10-Feb-25 13:55	5.6	2.64	0	0	< 10
9: DW DW-Point Clark Community Centre	10-Feb-25 14:29	5.6	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

14-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
LR Report: CA20725-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:46	10:46	10:46
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW - Well 3	10-Feb-25 15:06	5.6	---	0	0	---
7: TW TW1-Blairs Grove TW	10-Feb-25 14:59	5.6	2.42	0	0	10
8: DW DW-Chem Shed	10-Feb-25 15:16	5.6	2.03	0	0	< 10
9: DW DW-Elliots Construction	10-Feb-25 13:35	5.6	1.80	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

14-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Date Rec. : 11 February 2025
LR Report: CA20726-FEB25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:46	10:46	10:46
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	10-Feb-25 16:11	5.6	---	0	0	---
7: TW TW2-Huronville South TW	10-Feb-25 16:08	5.6	1.61	0	0	< 10
8: DW DW-Inverlyn Club House	10-Feb-25 16:19	5.6	1.21	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban

Date Rec. : 11 February 2025
LR Report: CA20727-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time		---	---	09:20	09:20	09:05
3: Analysis Completed Date		---	---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time		---	---	10:46	10:46	10:46
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	10-Feb-25 15:44	5.6	---	0	0	---
7: TW TW4-Murdoch Glen TW	10-Feb-25 15:34	5.6	2.50	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20189-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW - Well 3	03-Feb-25 13:47	8.0	---	0	0	---
7: TW TW1-Blairs Grove TW	03-Feb-25 13:44	8.0	1.62	0	0	< 10
8: DW DW-Chem Shed	03-Feb-25 13:28	8.0	1.44	0	0	< 10
9: DW DW-Courtney Subdivision	03-Feb-25 12:30	8.0	1.45	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20190-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	03-Feb-25 12:44	8.0	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	03-Feb-25 12:46	8.0	---	0	0	---
8: TW TW3-Point Clark TW	03-Feb-25 12:56	8.0	2.32	0	0	< 10
9: DW DW-Point Clark Community Centre	03-Feb-25 13:14	8.0	1.47	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


 Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20191-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	03-Feb-25 17:36	8.0	---	0	0	---
7: TW TW2-Huronville South TW	03-Feb-25 17:45	8.0	1.55	0	0	< 10
8: DW DW-Inverlyn Club House	03-Feb-25 18:09	8.0	1.30	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20192-FEB25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time		---	---	10:00	10:00	09:50
3: Analysis Completed Date		---	---	07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time		---	---	09:59	09:59	09:59
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well 2	03-Feb-25 14:49	8.0	---	0	0	---
7: TW TW4-Murdoch Glen TW	03-Feb-25 14:41	8.0	2.54	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

31-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 28 January 2025
LR Report: CA21186-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	29-Jan-25	29-Jan-25	29-Jan-25
2: Analysis Start Time		---	---	09:40	09:40	09:30
3: Analysis Completed Date		---	---	31-Jan-25	31-Jan-25	31-Jan-25
4: Analysis Completed Time		---	---	09:47	09:47	09:47
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	27-Jan-25 14:50	6.8	---	0	0	---
7: TW TW2-Huronville South TW	27-Jan-25 14:53	6.8	1.52	0	0	< 10
8: DW DW-Inverlyn Club House	27-Jan-25 15:05	6.8	1.42	0	0	< 10
9: RW RW1-Blairs Grove RW - Well 3	27-Jan-25 14:06	6.8	---	0	0	---
10: TW TW1-Blairs Grove TW	27-Jan-25 14:12	6.8	1.61	0	0	< 10
11: DW DW-Chem Shed	27-Jan-25 13:56	6.8	1.45	0	0	< 10
12: DW DW-Elliots Construction	27-Jan-25 13:10	6.8	1.39	0	0	< 10
13: RW RW3-Point Clark RW-Well 2	27-Jan-25 13:32	6.8	---	0	0	---
14: RW RW4-Point Clark RW-Well 3	27-Jan-25 13:30	6.8	---	0	0	---
15: TW TW3-Point Clark TW	27-Jan-25 13:28	6.8	1.46	0	0	< 10
16: DW DW-Point Clark Community Centre	27-Jan-25 13:45	6.8	1.49	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well	27-Jan-25 14:35	6.8	---	0	0	---
18: TW TW4-Murdoch Glen TW	27-Jan-25 14:32	6.8	2.34	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
LR Report: CA20911-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:39	10:39	10:39
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	20-Jan-25 13:37	4.9	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	20-Jan-25 14:04	4.9	---	0	0	---
8: TW TW3-Point Clark TW	20-Jan-25 13:31	4.9	1.55	0	0	< 10
9: DW DW-Point Clark Community Centre	20-Jan-25 14:37	4.9	1.45	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21186-JAN25

Environment, Health & Safety



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

24-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
LR Report: CA20912-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:40	10:40	10:40
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well	20-Jan-25 16:29	4.9	---	0	0	---
7: TW TW4-Murdoch Glen TW	20-Jan-25 16:22	4.9	2.20	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

24-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
LR Report: CA20913-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:40	10:40	10:40
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW-Well 3	20-Jan-25 17:04	4.9	---	0	0	---
7: TW TW1-Blairs Grove TW	20-Jan-25 17:02	4.9	1.63	0	0	< 10
8: DW DW-Chem Shed	20-Jan-25 11:53	4.9	1.46	0	0	< 10
9: DW DW-Elliots Construction	20-Jan-25 13:20	4.9	1.51	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban

Date Rec. : 21 January 2025
LR Report: CA20914-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time		---	---	10:42	10:42	10:42
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	20-Jan-25 16:40	4.9	---	0	0	---
7: TW TW2-Huronville South TW	20-Jan-25 16:36	4.9	1.50	0	0	< 10
8: DW DW-Inverlyn Club House	20-Jan-25 16:51	4.9	1.43	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

21-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025
LR Report: CA20566-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Draft Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:29	10:29	10:29
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	13-Jan-25 16:10	6.0	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	13-Jan-25 16:05	6.0	---	0	0	---
8: TW TW3-Point Clark TW	13-Jan-25 16:02	6.0	1.40	0	0	< 10
9: DW DW-Point Clark Community Centre	13-Jan-25 15:22	6.0	1.45	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

17-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025
LR Report: CA20563-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:28	10:28	10:28
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW - Well 3	13-Jan-25 15:10	6.0	---	0	0	---
7: TW TW1-Blairs Grove TW	13-Jan-25 15:07	6.0	1.61	0	0	< 10
8: DW DW-Chem Shed	13-Jan-25 14:46	6.0	1.38	0	0	< 10
9: DW DW-Elliots Construction	13-Jan-25 15:48	6.0	1.30	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety

**SGS Canada Inc.**

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

17-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025**LR Report:** CA20564-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:29	10:29	10:29
5: MAC		---	---	0	0	---
6: RW RW5-Murdoch Glen RW-Well	13-Jan-25 14:26	6.0	---	0	0	---
7: TW TW4-Murdoch Glen TW	13-Jan-25 14:13	6.0	1.55	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)
Attn : Paul Sherban

Date Rec. : 14 January 2025
LR Report: CA20565-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time		---	---	09:10	09:10	09:00
3: Analysis Completed Date		---	---	17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time		---	---	10:29	10:29	10:29
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	13-Jan-25 13:58	6.0	---	0	0	---
7: TW TW2-Huronville South TW	13-Jan-25 13:53	6.0	1.57	0	0	< 10
8: DW DW-Inverlyn Club House	13-Jan-25 13:43	6.0	1.29	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

13-January-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 08 January 2025
LR Report: CA20301-JAN25

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Jan-25	08-Jan-25	08-Jan-25
2: Analysis Start Time		---	---	12:45	12:45	12:05
3: Analysis Completed Date		---	---	10-Jan-25	10-Jan-25	10-Jan-25
4: Analysis Completed Time		---	---	11:12	11:12	11:12
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW-Well 3	06-Jan-25 15:00	8.8	---	0	0	---
7: TW TW1-Blairs Grove TW	06-Jan-25 14:56	8.8	1.61	0	0	< 10
8: DW DW-Chem Shed	06-Jan-25 14:41	8.8	1.18	0	0	< 10
9: DW DW-Elliots Construction (ACW)	06-Jan-25 13:50	8.8	1.47	0	0	30
10: RW RW3-Point Clark RW-Well 2	06-Jan-25 14:09	8.8	---	0	0	---
11: RW RW4-Point Clark RW-Well 3	06-Jan-25 14:14	8.8	---	0	0	---
12: TW TW3-Point Clark TW	06-Jan-25 14:04	8.8	1.41	0	0	< 10
13: DW DW-Point Clark Community Centre	06-Jan-25 14:30	8.8	1.49	0	0	< 10
14: RW RW5-Murdoch Glen RW-Well	06-Jan-25 15:44	8.8	---	0	0	---
15: TW TW4-Murdoch Glen TW	06-Jan-25 15:45	8.8	1.52	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	06-Jan-25 15:25	8.8	---	0	0	---
17: TW TW2-Huronville South TW	06-Jan-25 15:21	8.8	1.56	0	0	< 10
18: DW DW-Inverlyn Club House	06-Jan-25 16:02	8.8	1.36	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20301-JAN25

Environment, Health & Safety