

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

31-March-2025
OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 25 March 2025
LR Report: CA21189-MAR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Mar-25	26-Mar-25	26-Mar-25
2: Analysis Start Time				16:55	16:55	16:25
3: Analysis Completed Date				28-Mar-25	28-Mar-25	28-Mar-25
4: Analysis Completed Time				18:13	18:13	18:13
5: MAC		---	---	0	0	---
6: RW RW1-Ripley RW-Well 2	25-Mar-25 08:26	8.1	---	0	0	---
7: TW TW1-Ripley TW-Wellhouse	25-Mar-25 08:23	8.1	1.63	0	0	< 10
8: RW RW2-Ripley RW-Well 3	25-Mar-25 08:54	8.1	---	0	0	---
9: RW RW3-Ripley RW-Well 4	25-Mar-25 08:56	8.1	---	0	0	---
10: TW TW2-Ripley TW-Elevated Tank	25-Mar-25 08:51	8.1	1.64	0	0	< 10
11: DW DW-Ripley SPS	25-Mar-25 08:02	8.1	1.67	0	0	< 10
12: DW DW-Firehall	25-Mar-25 08:14	8.1	1.43	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

21-March-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 18 March 2025
LR Report: CA20884-MAR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				19-Mar-25	19-Mar-25	19-Mar-25
2: Analysis Start Time				15:55	15:55	15:15
3: Analysis Completed Date				21-Mar-25	21-Mar-25	21-Mar-25
4: Analysis Completed Time				14:16	14:16	14:16
5: MAC		---	---	0	0	---
6: RW RW1-Ripley RW-Well 2	18-Mar-25 08:28	11.9	---	0	0	---
7: TW TW1-Ripley TW-Wellhouse	18-Mar-25 08:25	11.9	1.81	0	0	< 10
8: RW RW2-Ripley RW-Well 3	18-Mar-25 09:08	11.9	---	0	0	---
9: RW RW3-Ripley RW-Well 4	18-Mar-25 09:13	11.9	---	0	0	---
10: TW TW2-Ripley TW-Elevated Tank	18-Mar-25 09:05	11.9	1.64	0	0	< 10
11: DW DW-Ripley SPS	18-Mar-25 08:05	11.9	1.41	0	0	< 10
12: DW DW-Firehall	18-Mar-25 08:17	11.9	1.53	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-March-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 11 March 2025
LR Report: CA20509-MAR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Mar-25	12-Mar-25	12-Mar-25
2: Analysis Start Time				13:55	13:55	13:30
3: Analysis Completed Date				14-Mar-25	14-Mar-25	14-Mar-25
4: Analysis Completed Time				12:52	12:52	12:52
5: MAC		---	---	0	0	---
6: RW RW1-Ripley RW-Well 2	11-Mar-25 08:34	8.3	---	0	0	---
7: TW TW1-Ripley TW-Wellhouse 2	11-Mar-25 08:29	8.3	1.68	0	0	< 10
8: RW RW2-Ripley RW-Well 3	11-Mar-25 09:13	8.3	---	2	0	---
9: RW RW3-Ripley RW-Well 4	11-Mar-25 09:17	8.3	---	6	0	---
10: TW TW2-Ripley TW-Elevated Tank	11-Mar-25 09:08	8.3	1.74	0	0	< 10
11: DW DW-Ripley SPS	11-Mar-25 08:06	8.3	1.51	0	0	< 10
12: DW DW-Firehall	11-Mar-25 08:18	8.3	1.49	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-March-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 04 March 2025
LR Report: CA20179-MAR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Mar-25	05-Mar-25	05-Mar-25
2: Analysis Start Time				15:45	15:45	15:00
3: Analysis Completed Date				07-Mar-25	07-Mar-25	07-Mar-25
4: Analysis Completed Time				14:20	14:20	14:20
5: MAC		---	---	0	0	---
6: RW RW1-Ripley RW-Well 2	04-Mar-25 10:23	8.6	---	0	0	---
7: TW TW1-Ripley TW-Wellhouse	04-Mar-25 10:17	8.6	1.86	0	0	< 10
8: RW RW2-Ripley RW-Well 3	04-Mar-25 11:06	8.6	---	0	0	---
9: RW RW3-Ripley RW-Well 4	04-Mar-25 11:10	8.6	---	0	0	---
10: TW TW2-Ripley TW-Elevated Tank	04-Mar-25 11:00	8.6	1.81	0	0	< 10
11: DW DW-Ripley SPS	04-Mar-25 09:40	8.6	1.71	0	0	< 10
12: DW DW-Firehall	04-Mar-25 10:09	8.6	1.73	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21181-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time		---	---	12:50	12:50	12:25
3: Analysis Completed Date		---	---	28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time		---	---	10:58	10:58	10:58
5: MAC		---	---	0	0	---
6: RW RW1-Ripley RW-Well 2	25-Feb-25 09:03	7.8	---	0	0	---
7: TW TW1-Ripley TW-Wellhouse	25-Feb-25 08:51	7.8	1.88	0	0	< 10
8: RW RW2-Ripley RW-Well 3	25-Feb-25 09:37	7.8	---	0	0	---
9: RW RW3-Ripley RW-Well 4	25-Feb-25 09:42	7.8	---	0	0	---
10: TW TW2-Ripley TW-Elevated Tank	25-Feb-25 09:31	7.8	1.86	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21182-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time		---	---	15:10	15:10	14:20
3: Analysis Completed Date		---	---	28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time		---	---	13:05	13:05	13:05
5: MAC		---	---	0	0	---
6: DW DW-Ripley SPS	25-Feb-25 08:23	7.8	1.75	0	0	< 10
7: DW DW-Firehall	25-Feb-25 08:41	7.8	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 19 February 2025
LR Report: CA21028-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	20-Feb-25	20-Feb-25	20-Feb-25
2: Analysis Start Time		---	---	12:55	12:55	12:25
3: Analysis Completed Date		---	---	24-Feb-25	24-Feb-25	24-Feb-25
4: Analysis Completed Time		---	---	10:15	10:15	10:15
5: MAC		---	---	0	0	---
6: RW RW1-Ripley RW-Well 2	19-Feb-25 11:43	10.8	---	0	0	---
7: TW TW1-Ripley TW-Wellhouse	19-Feb-25 11:36	10.8	1.87	0	0	< 10
8: RW RW2-Ripley RW-Well 3	19-Feb-25 12:31	10.8	---	0	0	---
9: RW RW3-Ripley RW-Well 4	19-Feb-25 12:25	10.8	---	0	0	---
10: TW TW2-Ripley TW-Elevated Tank	19-Feb-25 12:24	10.8	2.10	0	0	130
11: DW DW-Ripley SPS	19-Feb-25 11:15	10.8	1.81	0	0	< 10
12: DW DW-Firehall	19-Feb-25 11:28	10.8	1.85	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

18-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
LR Report: CA20758-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time				17:10	17:10	16:45
3: Analysis Completed Date				14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time				16:19	16:19	16:19
5: MAC		---	---	0	0	---
6: DW DW-Ripley SPS	11-Feb-25 08:29	5.6	1.50	0	0	< 10
7: DW DW-Firehall	11-Feb-25 08:43	5.6	1.79	0	0	< 10
8: DW DW-Arena	11-Feb-25 09:21	5.6	1.79	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

18-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
LR Report: CA20759-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time				17:10	17:10	16:45
3: Analysis Completed Date				14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time				16:19	16:19	16:19
5: MAC		---	---	0	0	---
6: RW RW1-Ripley RW-Well 2	11-Feb-25 09:04	5.6	---	0	0	---
7: TW TW1-Ripley TW-Wellhouse	11-Feb-25 08:56	5.6	1.90	0	0	< 10
8: RW RW2-Ripley RW-Well 3	11-Feb-25 09:32	5.6	---	0	0	---
9: RW RW3-Ripley RW-Well 4	11-Feb-25 09:40	5.6	---	0	0	---
10: TW TW2-Ripley TW-Elevated Tank	11-Feb-25 09:42	5.6	2.10	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20199-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time				14:00	14:00	13:20
3: Analysis Completed Date				07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time				14:25	14:25	14:25
5: MAC		---	---	0	0	---
6: DW DW-Ripley SPS	04-Feb-25 09:46	8.0	1.49	0	0	< 10
7: DW DW-Firehall	04-Feb-25 09:01	8.0	1.68	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20200-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time				14:00	14:00	13:20
3: Analysis Completed Date				07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time				14:25	14:25	14:25
5: MAC		---	---	0	0	---
6: RW RW1-Ripley RW-Well 2	04-Feb-25 09:19	8.0	---	0	0	---
7: TW TW1-Ripley TW-Wellhouse	04-Feb-25 09:15	8.0	1.38	0	0	< 10
8: RW RW2-Ripley RW-Well 3	04-Feb-25 10:23	8.0	---	0	0	---
9: RW RW3-Ripley RW-Well 4	04-Feb-25 10:15	8.0	---	0	0	---
10: TW TW2-Ripley TW-Elevated Tank	04-Feb-25 10:04	8.0	1.80	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

31-January-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 28 January 2025
LR Report: CA21225-JAN25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				29-Jan-25	29-Jan-25	29-Jan-25
2: Analysis Start Time				16:00	16:00	15:35
3: Analysis Completed Date				31-Jan-25	31-Jan-25	31-Jan-25
4: Analysis Completed Time				13:07	13:07	13:07
5: MAC		---	---	0	0	---
6: DW DW-Ripley SPS	28-Jan-25 10:38	6.8	1.73	0	0	< 10
7: DW DW-Firehall	28-Jan-25 11:02	6.8	1.25	0	0	10
8: RW RW1-Ripley RW-Well 2	28-Jan-25 11:30	6.8	---	0	0	---
9: TW TW1-Ripley TW-Wellhouse	28-Jan-25 11:09	6.8	1.76	0	0	< 10
10: RW RW2-Ripley RW-Well 3	28-Jan-25 12:12	6.8	---	1	0	---
11: RW RW3-Ripley RW-Well 4	28-Jan-25 12:03	6.8	---	1	0	---
12: TW TW2-Ripley TW-Elevated Tank	28-Jan-25 11:58	6.8	1.76	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
LR Report: CA20940-JAN25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time				16:20	16:20	15:45
3: Analysis Completed Date				24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time				14:17	14:17	14:17
5: MAC		---	---	0	0	---
6: DW DW-Ripley SPS	21-Jan-25 09:30	4.9	1.77	0	0	< 10
7: DW DW-Firehall	21-Jan-25 09:50	4.9	1.59	0	0	< 10
8: RW RW1-Ripley RW-Well 2	21-Jan-25 09:40	4.9	---	0	0	---
9: TW TW1-Ripley TW-Wellhouse	21-Jan-25 09:42	4.9	1.68	0	0	< 10
10: RW RW2-Ripley RW-Well 3	21-Jan-25 10:29	4.9	---	1	0	---
11: RW RW3-Ripley RW-Well 4	21-Jan-25 10:25	4.9	---	0	0	---
12: TW TW2-Ripley TW-Elevated Tank	21-Jan-25 10:24	4.9	2.07	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025
LR Report: CA20581-JAN25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time				15:00	15:00	14:35
3: Analysis Completed Date				17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time				12:42	12:42	12:42
5: MAC		---	---	0	0	---
6: RW RW1-Ripley RW-Well 2	14-Jan-25 08:53	6.0	---	0	0	---
7: TW TW1-Ripley TW-Wellhouse	14-Jan-25 08:54	6.0	1.61	0	0	< 10
8: RW RW2-Ripley RW-Well 3	14-Jan-25 09:29	6.0	---	1	0	---
9: RW RW3-Ripley RW-Well 4	14-Jan-25 09:32	6.0	---	0	0	---
10: TW TW2-Ripley TW-Elevated Tank	14-Jan-25 09:33	6.0	1.95	0	0	< 10
11: DW DW-Ripley SPS	14-Jan-25 09:12	6.0	1.82	0	0	< 10
12: DW DW-Firehall	14-Jan-25 08:44	6.0	1.83	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

13-January-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 08 January 2025
LR Report: CA20305-JAN25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Jan-25	08-Jan-25	08-Jan-25
2: Analysis Start Time		---	---	18:50	18:50	18:20
3: Analysis Completed Date		---	---	10-Jan-25	10-Jan-25	10-Jan-25
4: Analysis Completed Time		---	---	17:41	17:41	17:41
5: MAC		---	---	0	0	---
6: RW RW1-Ripley RW-Well 2	07-Jan-25 08:51	3.4	---	0	0	---
7: TW TW1-Ripley TW-Wellhouse 2	07-Jan-25 08:51	3.4	1.77	0	0	< 10
8: RW RW2-Ripley RW-Well 3	07-Jan-25 10:05	3.4	---	0	0	---
9: RW RW3-Ripley RW-Well 4	07-Jan-25 10:05	3.4	---	3	0	---
10: TW TW2-Ripley TW-Elevated Tank	07-Jan-25 09:48	3.4	1.82	0	0	< 10
11: DW DW-Ripley SPS	07-Jan-25 08:20	3.4	1.74	0	0	10
12: DW DW-Firehall	07-Jan-25 09:01	3.4	1.23	0	0	< 10
13: DW DW-Arena	07-Jan-25 10:17	3.4	1.54	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
Project Specialist-London,
Environment, Health & Safety