



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.

Lakefield - Ontario - KOL 2H0

Phone: 705-652-2000 FAX: 705-652-6365

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

Works #: 220002663

22-January-2026

Date Rec. : 13 January 2026

LR Report: CA30315-JAN26

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: MAC	7: MDL	8: TW TW1-Lucknow TW-Well 4	9: TW TW2-Lucknow TW-Well 5	10: DW DW-Lucknow SPS	11: DW DW-86667 County Rd 1 South	12: DW DW-Ford
Sample Date & Time							13-Jan-26 09:34	13-Jan-26 09:14	13-Jan-26 10:29	13-Jan-26 10:16	13-Jan-26 09:59
Temperature Upon Receipt [at London Lab °C]	---	---	---	---	---	---	3.1	3.1	3.1	3.1	3.1
Temperature Upon Receipt [at Lakefield Lab °C]	---	---	---	---	---	---	8.6	8.6	8.6	8.6	8.6
Field Free Chlorine [mg/L]	---	---	---	---	---	---	1.84	1.51	1.46	1.60	1.56
Arsenic [ug/L]	19-Jan-26	08:45	19-Jan-26	13:31	10	0.2	3.7	4.9	---	---	---
Nitrite (as N) [mg/L]	15-Jan-26	18:33	16-Jan-26	11:41	1.0	0.003	0.003 <MDL	0.003 <MDL	---	---	---
Nitrate (as N) [mg/L]	15-Jan-26	18:33	16-Jan-26	11:41	10	0.006	0.009	0.006 <MDL	---	---	---
Nitrate + Nitrite (as N) [mg/L]	15-Jan-26	18:33	16-Jan-26	11:41	---	0.006	0.009	0.006 <MDL	---	---	---
Trihalomethanes (total) [ug/L]	15-Jan-26	13:44	16-Jan-26	11:11	100 (RAA)	0.37	---	---	7.7	6.1	4.9
Bromodichloromethane [ug/L]	15-Jan-26	13:44	16-Jan-26	11:11	---	0.26	---	---	1.5	1.2	0.89
Bromoform [ug/L]	15-Jan-26	13:44	16-Jan-26	11:11	---	0.34	---	---	0.34 <MDL	0.34 <MDL	0.34 <MDL
Chloroform [ug/L]	15-Jan-26	13:44	16-Jan-26	11:11	---	0.29	---	---	5.7	4.9	4.0
Dibromochloromethane [ug/L]	15-Jan-26	13:44	16-Jan-26	11:11	---	0.37	---	---	0.41	0.37 <MDL	0.37 <MDL
Total Haloacetic Acids (HAA5) [ug/L]	20-Jan-26	08:27	22-Jan-26	12:24	80 (RAA)	5.3	---	---	5.3 <MDL	5.3 <MDL	5.3 <MDL
Chloroacetic Acid [ug/L]	20-Jan-26	08:27	22-Jan-26	12:24	---	4.7	---	---	4.7 <MDL	4.7 <MDL	4.7 <MDL
Bromoacetic Acid [ug/L]	20-Jan-26	08:27	22-Jan-26	12:24	---	2.9	---	---	2.9 <MDL	2.9 <MDL	2.9 <MDL
Dichloroacetic Acid [ug/L]	20-Jan-26	08:27	22-Jan-26	12:24	---	2.6	---	---	2.6 <MDL	2.6 <MDL	2.6 <MDL
Dibromoacetic Acid [ug/L]	20-Jan-26	08:27	22-Jan-26	12:24	---	2.0	---	---	2.0 <MDL	2.0 <MDL	2.0 <MDL
Trichloroacetic Acid [ug/L]	20-Jan-26	08:27	22-Jan-26	12:24	---	5.3	---	---	5.3 <MDL	5.3 <MDL	5.3 <MDL

MAC - Maximum Acceptable Concentration

Half MAC - Half of the Maximum Acceptable Concentration

MDL - SGS Method Detection Limit



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.

Lakefield - Ontario - K0L 2H0

Phone: 705-652-2000 FAX: 705-652-6365

Works #: 220002663

LR Report : CA30315-JAN26

Method Descriptions

Parameter	Description	SGS Method Code
Arsenic	Arsenic by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006
Bromoacetic Acid	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Bromodichloromethane	VOC wtr - THM	ME-CA-[ENV]GC-LAK-AN-004
Bromoform	VOC wtr - THM	ME-CA-[ENV]GC-LAK-AN-004
Chloroacetic Acid	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Chloroform	VOC wtr - THM	ME-CA-[ENV]GC-LAK-AN-004
Dibromoacetic Acid	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Dibromochloromethane	VOC wtr - THM	ME-CA-[ENV]GC-LAK-AN-004
Dichloroacetic Acid	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Nitrate (as N)	Nitrate by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Nitrate + Nitrite (as N)	Total Nitrate/Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Nitrite (as N)	Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Total Haloacetic Acids (HAA5)	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Trichloroacetic Acid	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Trihalomethanes (total)	VOC wtr - THM	ME-CA-[ENV]GC-LAK-AN-004

Hawley Anderson, Hon.B.Sc
Project Specialist,
Environment, Health & Safety