

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

02-January-2026

Date Rec. : 29 December 2025
LR Report: CA21314-DEC25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	30-Dec-25	30-Dec-25	30-Dec-25
2: Analysis Start Time		---	---	14:10	14:10	13:35
3: Analysis Completed Date		---	---	02-Jan-26	02-Jan-26	02-Jan-26
4: Analysis Completed Time		---	---	10:20	10:20	10:20
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	29-Dec-25 08:53	5.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	29-Dec-25 08:56	5.9	1.78	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	29-Dec-25 09:12	5.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	29-Dec-25 09:11	5.9	1.55	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	29-Dec-25 08:31	5.9	1.79	0	0	< 10
11: DW DW-Lucknow Tower	29-Dec-25 08:41	5.9	1.52	0	0	< 10
12: DW DW-Lucknow SPS	29-Dec-25 08:24	5.9	1.52	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

29-December-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 22 December 2025
LR Report: CA21105-DEC25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	23-Dec-25	23-Dec-25	23-Dec-25
2: Analysis Start Time		---	---	15:30	15:30	15:10
3: Analysis Completed Date		---	---	29-Dec-25	29-Dec-25	29-Dec-25
4: Analysis Completed Time		---	---	10:58	10:58	10:58
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	22-Dec-25 09:33	3.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	22-Dec-25 09:37	3.9	1.74	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	22-Dec-25 09:05	3.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	22-Dec-25 09:11	3.9	1.62	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	22-Dec-25 08:32	3.9	1.62	0	0	< 10
11: DW DW-Lucknow Tower	22-Dec-25 08:21	3.9	1.37	0	0	10
12: DW DW-Lucknow SPS	22-Dec-25 08:42	3.9	1.31	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

19-December-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 16 December 2025
LR Report: CA20842-DEC25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				17-Dec-25	17-Dec-25	17-Dec-25
2: Analysis Start Time				16:35	16:35	16:10
3: Analysis Completed Date				19-Dec-25	19-Dec-25	19-Dec-25
4: Analysis Completed Time				14:55	14:55	14:55
5: MAC	---	---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	16-Dec-25 10:27	2.6	1.58	0	0	< 10
7: DW DW-Lucknow Tower	16-Dec-25 10:21	2.6	1.30	0	0	< 10
8: DW DW-Lucknow SPS	16-Dec-25 10:35	2.6	1.29	0	0	---
9: RW RW1-Lucknow RW-Well 4	16-Dec-25 10:13	2.6	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	16-Dec-25 10:12	2.6	1.86	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	16-Dec-25 08:55	2.6	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	16-Dec-25 08:57	2.6	1.56	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

12-December-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 09 December 2025
LR Report: CA20507-DEC25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-Dec-25	10-Dec-25	10-Dec-25
2: Analysis Start Time		---	---	10:45	10:45	10:05
3: Analysis Completed Date		---	---	12-Dec-25	12-Dec-25	12-Dec-25
4: Analysis Completed Time		---	---	10:39	10:39	10:39
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	09-Dec-25 09:18	0.2	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	09-Dec-25 09:19	0.2	1.83	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	09-Dec-25 09:05	0.2	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	09-Dec-25 09:04	0.2	1.60	0	0	10
10: DW DW-86667 County Road 1 South (ACW)	09-Dec-25 09:43	0.2	1.45	0	0	< 10
11: DW DW-Lucknow Tower	09-Dec-25 09:34	0.2	1.32	0	0	10
12: DW DW-Lucknow SPS	09-Dec-25 09:52	0.2	1.33	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

05-December-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 02 December 2025
LR Report: CA20188-DEC25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	03-Dec-25	03-Dec-25	03-Dec-25
2: Analysis Start Time		---	---	13:50	13:50	13:00
3: Analysis Completed Date		---	---	05-Dec-25	05-Dec-25	05-Dec-25
4: Analysis Completed Time		---	---	11:43	11:43	11:43
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	02-Dec-25 10:34	2.3	1.46	0	0	< 10
7: DW DW-Lucknow Tower	02-Dec-25 10:28	2.3	1.49	0	0	< 10
8: DW DW-Lucknow SPS	02-Dec-25 12:55	2.3	1.38	0	0	---
9: RW RW1-Lucknow RW-Well 4	02-Dec-25 12:47	2.3	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	02-Dec-25 12:46	2.3	1.67	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	02-Dec-25 12:36	2.3	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	02-Dec-25 12:35	2.3	1.46	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-November-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 25 November 2025
LR Report: CA21233-NOV25

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Nov-25	26-Nov-25	26-Nov-25
2: Analysis Start Time		---	---	15:40	15:40	15:05
3: Analysis Completed Date		---	---	28-Nov-25	28-Nov-25	28-Nov-25
4: Analysis Completed Time		---	---	13:53	13:53	13:53
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	25-Nov-25 09:51	6.3	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	25-Nov-25 09:50	6.3	1.63	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	25-Nov-25 09:38	6.3	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	25-Nov-25 09:37	6.3	1.50	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	25-Nov-25 10:09	6.3	1.37	0	0	< 10
11: DW DW-Lucknow Tower	25-Nov-25 10:02	6.3	1.31	0	0	< 10
12: DW DW-Lucknow SPS	25-Nov-25 10:16	6.3	1.39	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

21-November-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada


Date Rec. : 18 November 2025
LR Report: CA20885-NOV25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				19-Nov-25	19-Nov-25	19-Nov-25
2: Analysis Start Time				15:30	15:30	14:55
3: Analysis Completed Date				21-Nov-25	21-Nov-25	21-Nov-25
4: Analysis Completed Time				14:07	14:07	14:07
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	18-Nov-25 12:08	2.9	1.28	0	0	< 10
7: DW DW-Lucknow Tower	18-Nov-25 11:59	2.9	1.35	0	0	< 10
8: DW DW-Lucknow SPS	18-Nov-25 11:01	2.9	1.30	0	0	---
9: RW RW1-Lucknow RW-Well 4	18-Nov-25 11:37	2.9	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	18-Nov-25 11:39	2.9	1.68	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	18-Nov-25 11:23	2.9	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	18-Nov-25 11:21	2.9	1.65	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

17-November-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 12 November 2025
LR Report: CA20595-NOV25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	13-Nov-25	13-Nov-25	13-Nov-25
2: Analysis Start Time		---	---	13:30	13:30	12:10
3: Analysis Completed Date		---	---	17-Nov-25	17-Nov-25	17-Nov-25
4: Analysis Completed Time		---	---	10:38	10:38	10:38
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	12-Nov-25 09:11	4.0	1.26	0	0	< 10
7: DW DW-Lucknow Tower	12-Nov-25 09:00	4.0	1.31	0	0	< 10
8: DW DW-Lucknow SPS	12-Nov-25 09:26	4.0	1.16	0	0	---
9: RW RW1-Lucknow RW-Well 4	12-Nov-25 10:09	4.0	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	12-Nov-25 10:07	4.0	1.61	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	12-Nov-25 09:37	4.0	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	12-Nov-25 09:40	4.0	1.65	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

07-November-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 04 November 2025
LR Report: CA20221-NOV25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Nov-25	05-Nov-25	05-Nov-25
2: Analysis Start Time		---	---	09:45	09:45	09:10
3: Analysis Completed Date		---	---	07-Nov-25	07-Nov-25	07-Nov-25
4: Analysis Completed Time		---	---	11:18	11:18	11:18
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	03-Nov-25 13:48	4.6	1.22	0	0	< 10
7: DW DW-Lucknow Tower	03-Nov-25 13:55	4.6	1.22	0	0	< 10
8: DW DW-Lucknow SPS	03-Nov-25 13:43	4.6	1.28	0	0	---
9: RW RW1-Lucknow RW-Well 4	03-Nov-25 14:04	4.6	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	03-Nov-25 14:03	4.6	1.66	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	03-Nov-25 14:10	4.6	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	03-Nov-25 14:11	4.6	1.52	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

03-November-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, CanadaDate Rec. : 28 October 2025
LR Report: CA21470-OCT25

Copy: #1


Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS
Final Report**

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date					29-Oct-25	29-Oct-25
2: Analysis Start Time					09:30	09:30
3: Analysis Completed Date					31-Oct-25	31-Oct-25
4: Analysis Completed Time					11:57	11:57
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	27-Oct-25 13:23	5.1	1.32	0	0	< 10
7: DW DW-Lucknow Tower	27-Oct-25 13:15	5.1	1.28	0	0	< 10
8: DW DW-Lucknow SPS	27-Oct-25 13:43	5.1	1.33	0	0	---
9: RW RW1-Lucknow RW-Well 4	27-Oct-25 13:50	5.1	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	27-Oct-25 13:49	5.1	1.78	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	27-Oct-25 13:59	5.1	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	27-Oct-25 13:58	5.1	1.53	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Carrie Greenlaw
Project Specialist,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

27-October-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

Date Rec. : 21 October 2025
LR Report: CA21153-OCT25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				22-Oct-25	22-Oct-25	22-Oct-25
2: Analysis Start Time				16:30	16:30	16:00
3: Analysis Completed Date				24-Oct-25	24-Oct-25	24-Oct-25
4: Analysis Completed Time				13:42	13:42	13:42
5: MAC	---	---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	21-Oct-25 08:54	9.4	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	21-Oct-25 08:53	9.4	1.68	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	21-Oct-25 08:40	9.4	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	21-Oct-25 08:38	9.4	1.74	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	21-Oct-25 09:13	9.4	1.29	0	0	< 10
11: DW DW-Lucknow Tower	21-Oct-25 09:05	9.4	1.30	0	0	< 10
12: DW DW-Lucknow SPS	21-Oct-25 09:22	9.4	1.42	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

27-October-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 23 October 2025
LR Report: CA21232-OCT25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date				23-Oct-25	23-Oct-25
2: Analysis Start Time				13:15	13:15
3: Analysis Completed Date				27-Oct-25	27-Oct-25
4: Analysis Completed Time				10:04	10:04
5: MAC		---	---	0	0
6: NR NR-MITF-3/4 Service (1)	23-Oct-25 08:23	9.8	1.76	0	0
7: NR NR-MITF-3/4 Service (2)	23-Oct-25 08:40	9.9	1.24	0	0

MAC - Maximum Acceptable Concentration

NR - Not regulated under applicable Provincial drinking water regulations as per client.

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster

Project Specialist-London,
Environment, Health & Safety

17-October-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 14 October 2025
LR Report: CA20724-OCT25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				15-Oct-25	15-Oct-25	15-Oct-25
2: Analysis Start Time				13:45	13:45	12:50
3: Analysis Completed Date				17-Oct-25	17-Oct-25	17-Oct-25
4: Analysis Completed Time				11:47	11:47	11:47
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	14-Oct-25 09:59	8.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	14-Oct-25 09:58	8.9	1.69	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	14-Oct-25 09:40	8.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	14-Oct-25 09:39	8.9	1.68	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	14-Oct-25 10:22	8.9	1.35	0	0	10
11: DW DW-Lucknow Tower	14-Oct-25 10:13	8.9	1.27	0	0	< 10
12: DW DW-Lucknow SPS	14-Oct-25 10:39	8.9	1.44	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-October-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 07 October 2025
LR Report: CA20398-OCT25

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				08-Oct-25	08-Oct-25	08-Oct-25
2: Analysis Start Time				10:55	10:55	10:20
3: Analysis Completed Date				10-Oct-25	10-Oct-25	10-Oct-25
4: Analysis Completed Time				10:37	10:37	10:37
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	07-Oct-25 10:13	8.4	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	07-Oct-25 10:11	8.4	1.75	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	07-Oct-25 10:34	8.4	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	07-Oct-25 10:32	8.4	1.46	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	07-Oct-25 09:54	8.4	1.49	0	0	< 10
11: DW DW-Lucknow Tower	07-Oct-25 10:01	8.4	1.39	0	0	< 10
12: DW DW-Lucknow SPS	07-Oct-25 10:44	8.4	1.43	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

06-October-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 01 October 2025
LR Report: CA20053-OCT25

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	02-Oct-25	02-Oct-25	02-Oct-25
2: Analysis Start Time		---	---	10:55	10:55	10:15
3: Analysis Completed Date		---	---	06-Oct-25	06-Oct-25	06-Oct-25
4: Analysis Completed Time		---	---	09:50	09:50	09:50
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	01-Oct-25 08:49	13.6	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	01-Oct-25 08:50	13.6	1.86	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	01-Oct-25 08:41	13.6	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	01-Oct-25 08:39	13.6	1.60	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	01-Oct-25 09:11	13.6	1.37	0	0	< 10
11: DW DW-Lucknow Tower	01-Oct-25 09:05	13.6	1.56	0	0	< 10
12: DW DW-Lucknow SPS	01-Oct-25 09:29	13.6	1.49	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

03-October-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 01 October 2025
LR Report: CA20062-OCT256242 Fallon Drive
Lucan, ON
N0M 2J0, Canada**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report


Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date		---	---	02-Oct-25	02-Oct-25
2: Analysis Start Time		---	---	13:15	13:15
3: Analysis Completed Date		---	---	03-Oct-25	03-Oct-25
4: Analysis Completed Time		---	---	15:10	15:10
5: MAC		---	---	0	0
6: NR NR-Gough St Watermain S1	01-Oct-25 09:45	13.6	1.33	0	0
7: NR NR-Gough St Watermain S2	01-Oct-25 10:11	13.6	1.35	0	0

MAC - Maximum Acceptable Concentration

NR - Not regulated under applicable Provincial drinking water regulations as per client.

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster

Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

03-October-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 01 October 2025
LR Report: CA20063-OCT25

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Copy: #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date		---	---	02-Oct-25	02-Oct-25
2: Analysis Start Time		---	---	13:15	13:15
3: Analysis Completed Date		---	---	03-Oct-25	03-Oct-25
4: Analysis Completed Time		---	---	15:10	15:10
5: MAC		---	---	0	0
6: NR NR-North Delhi Watermain S1	01-Oct-25 09:49	13.6	1.64	0	0
7: NR NR-North Delhi Watermain S2	01-Oct-25 10:06	13.6	1.66	0	0

MAC - Maximum Acceptable Concentration

NR - Not regulated under applicable Provincial drinking water regulations as per client.

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster

Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

26-September-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 23 September 2025
LR Report: CA21392-SEP25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				24-Sep-25	24-Sep-25	24-Sep-25
2: Analysis Start Time				14:30	14:30	12:45
3: Analysis Completed Date				26-Sep-25	26-Sep-25	26-Sep-25
4: Analysis Completed Time				12:21	12:21	12:21
5: MAC	---	---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	23-Sep-25 09:28	13.5	1.36	0	0	< 10
7: DW DW-Lucknow Tower	23-Sep-25 09:19	13.5	1.28	0	0	< 10
8: DW DW-Lucknow SPS	23-Sep-25 09:36	13.5	1.51	0	0	---
9: RW RW1-Lucknow RW-Well 4	23-Sep-25 09:09	13.5	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	23-Sep-25 09:08	13.5	1.82	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	23-Sep-25 08:52	13.5	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	23-Sep-25 08:50	13.5	1.81	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

22-September-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 16 September 2025
LR Report: CA21015-SEP25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				17-Sep-25	17-Sep-25	17-Sep-25
2: Analysis Start Time				17:15	17:15	16:35
3: Analysis Completed Date				19-Sep-25	19-Sep-25	19-Sep-25
4: Analysis Completed Time				16:01	16:01	16:01
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	16-Sep-25 08:46	5.4	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	16-Sep-25 08:45	5.4	1.68	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	16-Sep-25 08:34	5.4	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	16-Sep-25 08:31	5.4	1.75	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	16-Sep-25 09:04	5.4	1.47	0	0	< 10
11: DW DW-Lucknow Tower	16-Sep-25 08:57	5.4	1.62	0	0	< 10
12: DW DW-Lucknow SPS	16-Sep-25 09:12	5.4	1.58	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

12-September-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 09 September 2025
LR Report: CA20572-SEP25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date		---	---	10-Sep-25	10-Sep-25
2: Analysis Start Time		---	---	09:30	09:30
3: Analysis Completed Date		---	---	12-Sep-25	12-Sep-25
4: Analysis Completed Time		---	---	09:48	09:48
5: MAC		---	---	0	0
6: NR NR-Blow Off from Temporary Main	09-Sep-25 10:01	8.6	1.68	0	0

MAC - Maximum Acceptable Concentration

NR - Not regulated under applicable Provincial drinking water regulations as per client.

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

12-September-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 09 September 2025
LR Report: CA20573-SEP25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-Sep-25	10-Sep-25	10-Sep-25
2: Analysis Start Time		---	---	09:30	09:30	09:20
3: Analysis Completed Date		---	---	12-Sep-25	12-Sep-25	12-Sep-25
4: Analysis Completed Time		---	---	09:48	09:48	09:48
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	08-Sep-25 14:26	8.6	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	08-Sep-25 14:32	8.6	1.74	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	08-Sep-25 14:16	8.6	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	08-Sep-25 14:10	8.6	2.10	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	08-Sep-25 14:52	8.6	1.27	0	0	< 10
11: DW DW-Lucknow Tower	08-Sep-25 14:45	8.6	1.50	0	0	< 10
12: DW DW-Lucknow SPS	08-Sep-25 13:57	8.6	1.52	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

05-September-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:


Date Rec. : 02 September 2025
LR Report: CA20091-SEP25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				03-Sep-25	03-Sep-25	03-Sep-25
2: Analysis Start Time				14:10	14:10	13:55
3: Analysis Completed Date				05-Sep-25	05-Sep-25	05-Sep-25
4: Analysis Completed Time				13:28	13:28	13:28
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	02-Sep-25 10:19	16.0	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	02-Sep-25 10:10	16.0	1.72	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	02-Sep-25 09:44	16.0	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	02-Sep-25 09:40	16.0	2.08	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	02-Sep-25 10:55	16.0	1.27	0	0	< 10
11: DW DW-Lucknow Tower	02-Sep-25 10:43	16.0	1.22	0	0	< 10
12: DW DW-Lucknow SPS	02-Sep-25 10:00	16.0	1.53	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

29-August-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 26 August 2025
LR Report: CA21489-AUG25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				27-Aug-25	27-Aug-25	27-Aug-25
2: Analysis Start Time				14:50	14:50	13:15
3: Analysis Completed Date				29-Aug-25	29-Aug-25	29-Aug-25
4: Analysis Completed Time				14:34	14:34	14:34
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	26-Aug-25 09:41	10.4	1.23	0	0	< 10
7: DW DW-Lucknow Tower	26-Aug-25 09:59	10.4	1.39	0	0	10
8: DW DW-Lucknow SPS	26-Aug-25 09:20	10.4	1.28	0	0	---
9: RW RW1-Lucknow RW-Well 4	26-Aug-25 10:22	10.4	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	26-Aug-25 10:17	10.4	1.79	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	26-Aug-25 10:53	10.4	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	26-Aug-25 10:48	10.4	1.55	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

22-August-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 19 August 2025
LR Report: CA21119-AUG25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	20-Aug-25	20-Aug-25	20-Aug-25
2: Analysis Start Time		---	---	15:30	15:30	14:45
3: Analysis Completed Date		---	---	22-Aug-25	22-Aug-25	22-Aug-25
4: Analysis Completed Time		---	---	13:20	13:20	13:20
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	19-Aug-25 10:31	6.0	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	19-Aug-25 10:20	6.0	1.59	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	19-Aug-25 11:10	6.0	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	19-Aug-25 11:05	6.0	1.37	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	19-Aug-25 08:41	6.0	1.23	0	0	< 10
11: DW DW-Lucknow Tower	19-Aug-25 09:57	6.0	1.62	0	0	10
12: DW DW-Lucknow SPS	19-Aug-25 09:25	6.0	1.30	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

18-August-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 12 August 2025
LR Report: CA20722-AUG25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				13-Aug-25	13-Aug-25	13-Aug-25
2: Analysis Start Time				17:10	17:10	15:55
3: Analysis Completed Date				15-Aug-25	15-Aug-25	15-Aug-25
4: Analysis Completed Time				16:11	16:11	16:11
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	12-Aug-25 10:53	5.4	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	12-Aug-25 10:54	5.4	1.58	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	12-Aug-25 09:44	5.4	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	12-Aug-25 09:40	5.4	1.44	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	12-Aug-25 10:19	5.4	1.33	0	0	< 10
11: DW DW-Lucknow Tower	12-Aug-25 10:34	5.4	1.24	0	0	< 10
12: DW DW-Lucknow SPS	12-Aug-25 10:06	5.4	1.21	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

08-August-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Date Rec. : 05 August 2025
LR Report: CA20139-AUG25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	06-Aug-25	06-Aug-25	06-Aug-25
2: Analysis Start Time		---	---	12:40	12:40	12:15
3: Analysis Completed Date		---	---	08-Aug-25	08-Aug-25	08-Aug-25
4: Analysis Completed Time		---	---	11:15	11:15	11:15
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	05-Aug-25 10:53	12.3	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	05-Aug-25 10:51	12.3	1.64	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	05-Aug-25 10:34	12.3	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	05-Aug-25 10:33	12.3	1.37	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	05-Aug-25 11:22	12.3	1.26	0	0	< 10
11: DW DW-Lucknow Tower	05-Aug-25 11:11	12.3	1.19	0	0	< 10
12: DW DW-Lucknow SPS	05-Aug-25 10:18	12.3	1.31	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

05-August-2025

Date Rec. : 29 July 2025
LR Report: CA21673-JUL25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				30-Jul-25	30-Jul-25	30-Jul-25
2: Analysis Start Time				17:15	17:15	15:50
3: Analysis Completed Date				01-Aug-25	01-Aug-25	01-Aug-25
4: Analysis Completed Time				15:30	15:30	15:30
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	29-Jul-25 10:41	16.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	29-Jul-25 10:46	16.9	1.60	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	29-Jul-25 09:46	16.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	29-Jul-25 09:44	16.9	1.39	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	29-Jul-25 11:27	16.9	1.22	0	0	< 10
11: DW DW-Lucknow Tower	29-Jul-25 11:12	16.9	1.24	0	0	< 10
12: DW DW-Lucknow SPS	29-Jul-25 08:56	16.9	1.30	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

18-July-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 15 July 2025
LR Report: CA20940-JUL25

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				16-Jul-25	16-Jul-25	16-Jul-25
2: Analysis Start Time				16:10	16:10	15:40
3: Analysis Completed Date				18-Jul-25	18-Jul-25	18-Jul-25
4: Analysis Completed Time				14:41	14:41	14:41
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	15-Jul-25 09:41	11.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	15-Jul-25 09:47	11.8	1.47	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	15-Jul-25 08:04	11.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	15-Jul-25 08:00	11.8	1.53	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	15-Jul-25 10:45	11.8	1.20	0	0	< 10
11: DW DW-Lucknow Tower	15-Jul-25 10:08	11.8	1.27	0	0	< 10
12: DW DW-Lucknow SPS	15-Jul-25 11:13	11.8	1.32	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

14-July-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 08 July 2025
LR Report: CA20518-JUL25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				09-Jul-25	09-Jul-25	09-Jul-25
2: Analysis Start Time				15:30	15:30	15:10
3: Analysis Completed Date				11-Jul-25	11-Jul-25	11-Jul-25
4: Analysis Completed Time				13:25	13:25	13:25
5: MAC	---	---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	08-Jul-25 12:07	10.5	1.24	0	0	< 10
7: DW DW-Lucknow Tower	08-Jul-25 11:59	10.5	1.26	0	0	< 10
8: DW DW-Lucknow SPS	08-Jul-25 11:27	10.5	1.39	0	0	---
9: RW RW1-Lucknow RW-Well 4	08-Jul-25 11:45	10.5	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	08-Jul-25 11:43	10.5	1.68	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

14-July-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 09 July 2025
LR Report: CA20567-JUL256242 Fallon Drive
Lucan, ON
N0M 2J0, Canada**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				10-Jul-25	10-Jul-25	10-Jul-25
2: Analysis Start Time				11:55	11:55	11:15
3: Analysis Completed Date				14-Jul-25	14-Jul-25	14-Jul-25
4: Analysis Completed Time				10:14	10:14	10:14
5: MAC	---	---	---	0	0	---
6: RW RW2-Lucknow RW-Well 5	09-Jul-25 08:23	10.9	---	0	0	---
7: TW TW2-Lucknow TW-Well 5	09-Jul-25 08:20	10.9	1.42	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

30-June-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive, Lucan
Canada, N0M 2J0

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson), Fax:

Date Rec. : 24 June 2025
LR Report: CA21562-JUN25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				25-Jun-25	25-Jun-25	25-Jun-25
2: Analysis Start Time				13:45	13:45	13:10
3: Analysis Completed Date				27-Jun-25	27-Jun-25	27-Jun-25
4: Analysis Completed Time				13:55	13:55	13:55
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	24-Jun-25 09:57	14.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	24-Jun-25 09:55	14.9	1.86	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	24-Jun-25 09:04	14.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	24-Jun-25 09:00	14.9	1.56	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	24-Jun-25 10:35	14.9	1.57	0	0	< 10
11: DW DW-Lucknow Tower	24-Jun-25 10:26	14.9	1.43	0	0	< 10
12: DW DW-Lucknow SPS	24-Jun-25 10:44	14.9	1.31	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

23-June-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 17 June 2025
LR Report: CA21149-JUN25

Copy: #1


CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				18-Jun-25	18-Jun-25	18-Jun-25
2: Analysis Start Time				16:50	16:50	16:20
3: Analysis Completed Date				20-Jun-25	20-Jun-25	20-Jun-25
4: Analysis Completed Time				17:55	17:55	17:55
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	17-Jun-25 09:57	10.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	17-Jun-25 10:02	10.8	1.72	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	17-Jun-25 09:15	10.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	17-Jun-25 09:07	10.8	1.46	0	0	10
10: DW DW-86667 County Road 1 South (ACW)	17-Jun-25 10:23	10.8	1.41	0	0	10
11: DW DW-Lucknow Tower	17-Jun-25 10:15	10.8	1.32	0	0	< 10
12: DW DW-Lucknow SPS	17-Jun-25 10:32	10.8	1.40	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

13-June-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 10 June 2025
LR Report: CA20731-JUN25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	11-Jun-25	11-Jun-25	11-Jun-25
2: Analysis Start Time		---	---	13:40	13:40	13:10
3: Analysis Completed Date		---	---	13-Jun-25	13-Jun-25	13-Jun-25
4: Analysis Completed Time		---	---	12:05	12:05	12:05
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	10-Jun-25 10:23	12.4	1.48	0	0	< 10
7: DW DW-Lucknow Tower	10-Jun-25 10:14	12.4	1.30	0	0	< 10
8: DW DW-Lucknow SPS	10-Jun-25 10:34	12.4	1.29	0	0	---
9: RW RW1-Lucknow RW-Well 4	10-Jun-25 09:58	12.4	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	10-Jun-25 10:04	12.4	1.64	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	10-Jun-25 09:47	12.4	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	10-Jun-25 09:44	12.4	1.60	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

09-June-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 03 June 2025
LR Report: CA20266-JUN25

Copy: #1


CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Jun-25	04-Jun-25	04-Jun-25
2: Analysis Start Time				15:50	15:50	15:25
3: Analysis Completed Date				06-Jun-25	06-Jun-25	06-Jun-25
4: Analysis Completed Time				14:20	14:20	14:20
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	03-Jun-25 11:10	11.0	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	03-Jun-25 10:59	11.0	1.61	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	03-Jun-25 10:40	11.0	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	03-Jun-25 10:34	11.0	1.62	0	0	10
10: DW DW-86667 County Road 1 South (ACW)	03-Jun-25 11:36	11.0	1.42	0	0	10
11: DW DW-Lucknow Tower	03-Jun-25 11:25	11.0	1.35	0	0	< 10
12: DW DW-Lucknow SPS	03-Jun-25 11:50	11.0	1.60	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
*Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

04-June-2025

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 31 May 2025
LR Report: CA21655-MAY25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				31-May-25	31-May-25	31-May-25
2: Analysis Start Time				12:55	12:55	12:45
3: Analysis Completed Date				02-Jun-25	02-Jun-25	02-Jun-25
4: Analysis Completed Time				16:10	16:10	16:10
5: MAC		---	---	0	0	---
6: TW TW1-Huronville TW	30-May-25 13:36	7.7	1.32	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

30-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 27 May 2025
LR Report: CA21538-MAY25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				28-May-25	28-May-25	28-May-25
2: Analysis Start Time				13:05	13:05	12:20
3: Analysis Completed Date				30-May-25	30-May-25	30-May-25
4: Analysis Completed Time				14:26	14:26	14:26
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	27-May-25 09:15	8.6	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	27-May-25 09:12	8.6	1.47	0	0	10
8: RW RW2-Lucknow RW-Well 5	27-May-25 08:58	8.6	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	27-May-25 09:02	8.6	1.77	0	0	10
10: DW DW-86667 County Road 1 South (ACW)	27-May-25 09:30	8.6	1.41	0	0	<10
11: DW DW-Lucknow Tower	27-May-25 09:24	8.6	1.28	0	0	10
12: DW DW-Lucknow SPS	27-May-25 09:39	8.6	1.51	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
*Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

26-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

Date Rec. : 20 May 2025
LR Report: CA21046-MAY25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				21-May-25	21-May-25	21-May-25
2: Analysis Start Time				13:30	13:30	13:05
3: Analysis Completed Date				23-May-25	23-May-25	23-May-25
4: Analysis Completed Time				16:10	16:10	16:10
5: MAC	---	---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	20-May-25 10:19	12.7	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	20-May-25 10:16	12.7	1.59	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	20-May-25 09:42	12.7	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	20-May-25 09:36	12.7	1.65	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	20-May-25 10:56	12.7	1.41	0	0	< 10
11: DW DW-Lucknow Tower	20-May-25 10:42	12.7	1.30	0	0	< 10
12: DW DW-Lucknow SPS	20-May-25 11:11	12.7	1.51	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

26-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 20 May 2025
LR Report: CA21046-MAY25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				21-May-25	21-May-25	21-May-25
2: Analysis Start Time				13:30	13:30	13:05
3: Analysis Completed Date				23-May-25	23-May-25	23-May-25
4: Analysis Completed Time				16:10	16:10	16:10
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	20-May-25 10:19	12.7	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	20-May-25 10:16	12.7	1.59	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	20-May-25 09:42	12.7	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	20-May-25 09:36	12.7	1.65	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	20-May-25 10:56	12.7	1.41	0	0	< 10
11: DW DW-Lucknow Tower	20-May-25 10:42	12.7	1.30	0	0	< 10
12: DW DW-Lucknow SPS	20-May-25 11:11	12.7	1.51	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
*Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

20-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

Date Rec. : 13 May 2025
LR Report: CA20780-MAY25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	14-May-25	14-May-25	14-May-25
2: Analysis Start Time		---	---	16:10	16:10	15:50
3: Analysis Completed Date		---	---	16-May-25	16-May-25	16-May-25
4: Analysis Completed Time		---	---	15:54	15:54	15:54
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	13-May-25 09:42	11.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	13-May-25 09:40	11.9	1.65	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	13-May-25 09:24	11.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	13-May-25 09:19	11.9	1.72	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	13-May-25 10:00	11.9	1.43	0	0	< 10
11: DW DW-Lucknow Tower	13-May-25 09:53	11.9	1.42	0	0	< 10
12: DW DW-Lucknow SPS	13-May-25 10:07	11.9	1.51	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

09-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 06 May 2025
LR Report: CA20328-MAY25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-May-25	07-May-25	07-May-25
2: Analysis Start Time		---	---	15:45	15:45	15:20
3: Analysis Completed Date		---	---	09-May-25	09-May-25	09-May-25
4: Analysis Completed Time		---	---	14:16	14:16	14:16
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	06-May-25 10:16	10.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	06-May-25 10:20	10.8	1.66	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	06-May-25 10:04	10.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	06-May-25 10:01	10.8	1.63	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	06-May-25 10:39	10.8	1.29	0	0	< 10
11: DW DW-Lucknow Tower	06-May-25 10:30	10.8	1.33	0	0	< 10
12: DW DW-Lucknow SPS	06-May-25 10:50	10.8	1.35	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
*Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

02-May-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 29 April 2025
LR Report: CA21640-APR25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				30-Apr-25	30-Apr-25	30-Apr-25
2: Analysis Start Time				17:15	17:15	15:35
3: Analysis Completed Date				02-May-25	02-May-25	02-May-25
4: Analysis Completed Time				13:45	13:45	13:45
5: MAC	---	---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	29-Apr-25 08:48	9.7	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	29-Apr-25 08:54	9.7	1.59	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	29-Apr-25 08:38	9.7	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	29-Apr-25 08:35	9.7	1.63	0	0	< 10
10: DW DW-86667 Country Road 1 South (ACW)	29-Apr-25 09:10	9.7	1.44	0	0	< 10
11: DW DW-Lucknow Tower	29-Apr-25 09:03	9.7	1.37	0	0	< 10
12: DW DW-Lucknow SPS	29-Apr-25 09:17	9.7	1.51	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
*Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

25-April-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Date Rec. : 22 April 2025
LR Report: CA21166-APR25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				23-Apr-25	23-Apr-25	23-Apr-25
2: Analysis Start Time				10:30	10:30	10:05
3: Analysis Completed Date				25-Apr-25	25-Apr-25	25-Apr-25
4: Analysis Completed Time				10:47	10:47	10:47
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	22-Apr-25 11:29	12.3	1.34	0	0	NDOGHPC
7: DW DW-Lucknow Tower	22-Apr-25 11:17	12.3	1.33	0	0	< 10
8: DW DW-Lucknow SPS	22-Apr-25 11:45	12.3	1.43	0	0	---
9: RW RW1-Lucknow RW-Well 4	22-Apr-25 10:31	12.3	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	22-Apr-25 10:41	12.3	1.59	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	22-Apr-25 10:04	12.3	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	22-Apr-25 09:58	12.3	1.62	0	0	< 10

MAC - Maximum Acceptable Concentration
NDOGHPC - No Data: Overgrown with HPC

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-April-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 14 April 2025
LR Report: CA20687-APR25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				14-Apr-25	14-Apr-25	14-Apr-25
2: Analysis Start Time				16:40	16:40	16:10
3: Analysis Completed Date				16-Apr-25	16-Apr-25	16-Apr-25
4: Analysis Completed Time				17:53	17:53	17:53
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	14-Apr-25 10:35	15.1	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	14-Apr-25 10:24	15.1	1.73	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	14-Apr-25 11:38	15.1	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	14-Apr-25 11:36	15.1	1.80	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	14-Apr-25 11:13	15.1	1.46	0	0	< 10
11: DW DW-Lucknow Tower	14-Apr-25 10:55	15.1	1.49	0	0	< 10
12: DW DW-Lucknow SPS	14-Apr-25 11:24	15.1	1.55	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
*Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-April-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 08 April 2025
LR Report: CA20534-APR25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				09-Apr-25	09-Apr-25	09-Apr-25
2: Analysis Start Time				18:20	18:20	17:55
3: Analysis Completed Date				11-Apr-25	11-Apr-25	11-Apr-25
4: Analysis Completed Time				15:08	15:08	15:08
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	08-Apr-25 09:17	5.1	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	08-Apr-25 09:15	5.1	1.72	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	08-Apr-25 09:03	5.1	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	08-Apr-25 09:01	5.1	1.75	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	08-Apr-25 09:36	5.1	1.56	0	0	< 10
11: DW DW-Lucknow Tower	08-Apr-25 09:30	5.1	1.45	0	0	< 10
12: DW DW-Lucknow SPS	08-Apr-25 09:47	5.1	1.43	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
*Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

04-April-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 01 April 2025
LR Report: CA20133-APR25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	02-Apr-25	02-Apr-25	02-Apr-25
2: Analysis Start Time		---	---	10:45	10:45	10:10
3: Analysis Completed Date		---	---	04-Apr-25	04-Apr-25	04-Apr-25
4: Analysis Completed Time		---	---	10:50	10:50	10:50
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	01-Apr-25 08:19	6.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	01-Apr-25 08:13	6.9	1.70	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	01-Apr-25 09:05	6.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	01-Apr-25 09:00	6.9	1.85	0	0	10
10: DW DW-86667 County Road 1 South (ACW)	01-Apr-25 09:45	6.9	1.47	0	0	< 10
11: DW DW-Lucknow Tower	01-Apr-25 09:58	6.9	1.38	0	0	< 10
12: DW DW-Lucknow SPS	01-Apr-25 09:34	6.9	1.45	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
*Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

31-March-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 25 March 2025
LR Report: CA21187-MAR25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				26-Mar-25	26-Mar-25	26-Mar-25
2: Analysis Start Time				16:55	16:55	16:25
3: Analysis Completed Date				28-Mar-25	28-Mar-25	28-Mar-25
4: Analysis Completed Time				18:13	18:13	18:13
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	25-Mar-25 08:45	8.1	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	25-Mar-25 08:55	8.1	1.72	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	25-Mar-25 08:28	8.1	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	25-Mar-25 08:23	8.1	1.85	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	25-Mar-25 09:24	8.1	1.53	0	0	< 10
11: DW DW-Lucknow Tower	25-Mar-25 09:12	8.1	1.31	0	0	< 10
12: DW DW-Lucknow SPS	25-Mar-25 07:54	8.1	1.33	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
*Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

21-March-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 18 March 2025
LR Report: CA20886-MAR25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				19-Mar-25	19-Mar-25	19-Mar-25
2: Analysis Start Time				15:55	15:55	15:15
3: Analysis Completed Date				21-Mar-25	21-Mar-25	21-Mar-25
4: Analysis Completed Time				14:17	14:17	14:17
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	18-Mar-25 10:19	11.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	18-Mar-25 10:25	11.9	1.51	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	18-Mar-25 10:11	11.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	18-Mar-25 10:09	11.9	1.71	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	18-Mar-25 08:43	11.9	1.30	0	0	< 10
11: DW DW-Lucknow Tower	18-Mar-25 10:36	11.9	1.40	0	0	10
12: DW DW-Lucknow SPS	18-Mar-25 09:55	11.9	1.35	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-March-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 11 March 2025
LR Report: CA20511-MAR25

Copy: #1


CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Mar-25	12-Mar-25	12-Mar-25
2: Analysis Start Time				13:55	13:55	13:30
3: Analysis Completed Date				14-Mar-25	14-Mar-25	14-Mar-25
4: Analysis Completed Time				12:52	12:52	12:52
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	11-Mar-25 11:52	8.3	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	11-Mar-25 11:47	8.3	1.48	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	11-Mar-25 10:37	8.3	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	11-Mar-25 10:32	8.3	1.60	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	11-Mar-25 09:43	8.3	1.47	0	0	< 10
11: DW DW-Lucknow Tower	11-Mar-25 12:14	8.3	1.36	0	0	< 10
12: DW DW-Lucknow SPS	11-Mar-25 09:55	8.3	1.33	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-March-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

Date Rec. : 04 March 2025
LR Report: CA20181-MAR25

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Mar-25	05-Mar-25	05-Mar-25
2: Analysis Start Time				15:45	15:45	15:00
3: Analysis Completed Date				07-Mar-25	07-Mar-25	07-Mar-25
4: Analysis Completed Time				14:21	14:21	14:21
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	04-Mar-25 10:16	8.6	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	04-Mar-25 10:09	8.6	1.47	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	04-Mar-25 09:38	8.6	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	04-Mar-25 09:45	8.6	1.61	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	04-Mar-25 11:14	8.6	1.39	0	0	< 10
11: DW DW-Lucknow Tower	04-Mar-25 10:56	8.6	1.38	0	0	< 10
12: DW DW-Lucknow SPS	04-Mar-25 09:31	8.6	1.55	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
*Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

28-February-2025

Date Rec. : 25 February 2025
LR Report: CA21178-FEB25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time		---	---	12:50	12:50	12:25
3: Analysis Completed Date		---	---	28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time		---	---	10:52	10:52	10:52
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	25-Feb-25 09:30	7.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	25-Feb-25 09:35	7.8	1.58	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	25-Feb-25 09:21	7.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	25-Feb-25 09:16	7.8	1.80	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

28-February-2025

Date Rec. : 25 February 2025
LR Report: CA21179-FEB25

Copy: #1

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Feb-25	26-Feb-25	26-Feb-25
2: Analysis Start Time		---	---	12:50	12:50	12:25
3: Analysis Completed Date		---	---	28-Feb-25	28-Feb-25	28-Feb-25
4: Analysis Completed Time		---	---	10:58	10:58	10:58
5: MAC		---	---	0	0	---
6: DW DW-86667 Country Road 1 South (ACW)	25-Feb-25 09:51	7.8	1.50	0	0	< 10
7: DW DW-Lucknow Tower	25-Feb-25 09:43	7.8	1.45	0	0	< 10
8: DW DW-Lucknow SPS	25-Feb-25 09:59	7.8	1.59	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

24-February-2025

Date Rec. : 19 February 2025
LR Report: CA21040-FEB25

Copy: #1


CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				20-Feb-25	20-Feb-25	20-Feb-25
2: Analysis Start Time				14:45	14:45	14:10
3: Analysis Completed Date				24-Feb-25	24-Feb-25	24-Feb-25
4: Analysis Completed Time				10:50	10:50	10:50
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	19-Feb-25 09:22	10.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	19-Feb-25 09:28	10.8	1.60	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	19-Feb-25 10:20	10.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	19-Feb-25 10:15	10.8	1.76	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	19-Feb-25 10:00	10.8	1.53	0	0	< 10
11: DW DW-Lucknow Tower	19-Feb-25 09:47	10.8	1.21	0	0	< 10
12: DW DW-Lucknow SPS	19-Feb-25 10:43	10.8	1.46	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

18-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 11 February 2025
LR Report: CA20760-FEB25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time				17:10	17:10	16:45
3: Analysis Completed Date				14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time				16:19	16:19	16:19
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	11-Feb-25 11:05	5.6	1.39	0	0	< 10
7: DW DW-Lucknow Tower	11-Feb-25 10:12	5.6	1.37	0	0	< 10
8: DW DW-Lucknow SPS	11-Feb-25 10:56	5.6	1.44	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

18-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

Date Rec. : 11 February 2025
LR Report: CA20761-FEB25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date			---	12-Feb-25	12-Feb-25	12-Feb-25
2: Analysis Start Time			---	17:10	17:10	16:45
3: Analysis Completed Date			---	14-Feb-25	14-Feb-25	14-Feb-25
4: Analysis Completed Time			---	16:19	16:19	16:19
5: MAC	---	---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	11-Feb-25 10:26	5.6	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	11-Feb-25 10:22	5.6	1.57	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	11-Feb-25 10:36	5.6	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	11-Feb-25 10:43	5.6	1.88	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 04 February 2025
LR Report: CA20196-FEB25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time				14:00	14:00	13:20
3: Analysis Completed Date				07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time				14:25	14:25	14:25
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	04-Feb-25 10:59	8.0	1.49	0	0	< 10
7: DW DW-Lucknow Tower	04-Feb-25 12:24	8.0	1.39	0	0	< 10
8: DW DW-Lucknow SPS	04-Feb-25 11:19	8.0	1.17	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



*Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:


Date Rec. : 04 February 2025
LR Report: CA20197-FEB25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Feb-25	05-Feb-25	05-Feb-25
2: Analysis Start Time				14:00	14:00	13:20
3: Analysis Completed Date				07-Feb-25	07-Feb-25	07-Feb-25
4: Analysis Completed Time				14:25	14:25	14:25
5: MAC	---	---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	04-Feb-25 12:07	8.0	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	04-Feb-25 12:01	8.0	1.65	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	04-Feb-25 11:49	8.0	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	04-Feb-25 11:45	8.0	1.71	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

31-January-2025

Date Rec. : 28 January 2025
LR Report: CA21227-JAN25

Copy: #1


CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				29-Jan-25	29-Jan-25	29-Jan-25
2: Analysis Start Time				16:00	16:00	15:35
3: Analysis Completed Date				31-Jan-25	31-Jan-25	31-Jan-25
4: Analysis Completed Time				13:07	13:07	13:07
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	28-Jan-25 09:11	6.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	28-Jan-25 09:16	6.8	1.64	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	28-Jan-25 09:36	6.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	28-Jan-25 09:32	6.8	1.58	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	28-Jan-25 08:42	6.8	1.47	0	0	< 10
11: DW DW-Lucknow Tower	28-Jan-25 09:04	6.8	1.43	0	0	< 10
12: DW DW-Lucknow SPS	28-Jan-25 08:56	6.8	1.21	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)

Fax:

Date Rec. : 21 January 2025
LR Report: CA20942-JAN25**Copy:** #1**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				22-Jan-25	22-Jan-25	22-Jan-25
2: Analysis Start Time				16:20	16:20	15:45
3: Analysis Completed Date				24-Jan-25	24-Jan-25	24-Jan-25
4: Analysis Completed Time				14:19	14:19	14:19
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	21-Jan-25 09:39	4.9	1.49	0	0	< 10
7: DW DW-Lucknow Tower	21-Jan-25 10:01	4.9	1.41	0	0	< 10
8: DW DW-Office	21-Jan-25 11:04	4.9	1.21	0	0	---
9: RW RW1-Lucknow RW-Well 4	21-Jan-25 10:06	4.9	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	21-Jan-25 10:12	4.9	1.50	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	21-Jan-25 10:35	4.9	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	21-Jan-25 10:27	4.9	1.28	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Date Rec. : 14 January 2025
LR Report: CA20582-JAN25

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				15-Jan-25	15-Jan-25	15-Jan-25
2: Analysis Start Time				15:00	15:00	14:35
3: Analysis Completed Date				17-Jan-25	17-Jan-25	17-Jan-25
4: Analysis Completed Time				12:42	12:42	12:42
5: MAC	---	---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	14-Jan-25 09:38	6.0	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	14-Jan-25 09:29	6.0	1.50	0	0	10
8: RW RW2-Lucknow RW-Well 5	14-Jan-25 09:03	6.0	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	14-Jan-25 08:55	6.0	1.76	0	0	< 10
10: DW DW-86667 South (ACW)	14-Jan-25 08:43	6.0	1.47	0	0	10
11: DW DW-Lucknow SPS	14-Jan-25 08:33	6.0	1.51	0	0	< 10
12: DW DW-Old Firehall	14-Jan-25 08:10	6.0	1.62	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



*Cristal Schuster
Project Specialist-London,
Environment, Health & Safety*

SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

13-January-2025

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

6242 Fallon Drive

Lucan, ON

N0M 2J0, Canada

Date Rec. : 08 January 2025
LR Report: CA20304-JAN25**Copy:** #1Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:**CERTIFICATE OF ANALYSIS**
Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Jan-25	08-Jan-25	08-Jan-25
2: Analysis Start Time		---	---	18:50	18:50	18:20
3: Analysis Completed Date		---	---	10-Jan-25	10-Jan-25	10-Jan-25
4: Analysis Completed Time		---	---	17:41	17:41	17:41
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	07-Jan-25 09:35	3.4	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	07-Jan-25 09:30	3.4	1.48	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	07-Jan-25 08:30	3.4	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	07-Jan-25 08:24	3.4	1.75	0	0	< 10
10: DW DW-86667 South (ACW)	07-Jan-25 09:06	3.4	1.38	0	0	< 10
11: DW DW-Lucknow SPS	07-Jan-25 08:51	3.4	1.48	0	0	< 10
12: DW DW-Old Firehall	07-Jan-25 09:00	3.4	1.55	0	0	---
13: DW DW-Tower	07-Jan-25 09:20	3.4	1.42	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety