

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

01-May-2026

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 28 April 2026
LR Report: CA21488-APR26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL |
|----------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|
| 1: Analysis Start Date | | --- | --- | 29-Apr-26 | 29-Apr-26 |
| 2: Analysis Start Time | | --- | --- | 12:30 | 12:30 |
| 3: Analysis Completed Date | | --- | --- | 01-May-26 | 01-May-26 |
| 4: Analysis Completed Time | | --- | --- | 12:18 | 12:18 |
| 5: MAC | | --- | --- | 0 | 0 |
| 6: DW DW-Lucknow Tower | 28-Apr-26 10:23 | 6.6 | 1.37 | 0 | 0 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|----------------|----------------------------------|---------------------------|
| E.coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety