

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

20-February-2026

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 17 February 2026
 LR Report: CA20707-FEB26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				18-Feb-26	18-Feb-26	18-Feb-26
2: Analysis Start Time				16:55	16:55	16:30
3: Analysis Completed Date				20-Feb-26	20-Feb-26	20-Feb-26
4: Analysis Completed Time				14:53	14:53	14:53
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	17-Feb-26 10:37	11.9	---	0	0	---
7: TW TW2-Huronville South TW	17-Feb-26 10:26	11.9	1.39	0	0	< 10
8: DW DW-Inverlyn Club House	17-Feb-26 10:16	11.9	1.26	0	0	10
9: RW RW5-Murdoch Glen RW-Well 2	17-Feb-26 11:00	11.9	---	0	0	---
10: TW TW4-Murdoch Glen TW	17-Feb-26 10:57	11.9	1.58	0	0	< 10
11: RW RW3-Point Clark RW-Well 2	17-Feb-26 09:17	11.9	---	0	0	---
12: RW RW4-Point Clark RW-Well 3	17-Feb-26 09:42	11.9	---	0	0	---
13: TW TW3-Point Clark TW	17-Feb-26 09:23	11.9	1.57	0	0	< 10
14: DW DW-Point Clark Community Centre	17-Feb-26 09:53	11.9	1.35	0	0	< 10
15: RW RW1-Blairs Grove RW-Well 3	17-Feb-26 11:37	11.9	---	0	0	---
16: TW TW1-Blairs Grove TW	17-Feb-25 11:29	11.9	1.28	0	0	< 10
17: DW DW-Chem Shed	17-Feb-26 11:57	11.9	1.40	0	0	< 10
18: DW DW-Amberley Beach SS (ACW)	17-Feb-26 09:04	11.9	1.53	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20707-FEB26

Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

13-February-2026

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 10 February 2026
 LR Report: CA20482-FEB26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				11-Feb-26	11-Feb-26	11-Feb-26
2: Analysis Start Time				10:15	10:15	09:40
3: Analysis Completed Date				13-Feb-26	13-Feb-26	13-Feb-26
4: Analysis Completed Time				11:05	11:05	11:05
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	09-Feb-26 12:34	1.9	---	0	0	---
7: TW TW2-Huronville South TW	09-Feb-26 12:12	1.9	1.28	0	0	< 10
8: DW DW-Inverlyn Club House	09-Feb-26 12:40	1.9	1.17	0	0	< 10
9: RW RW5-Murdoch Glen RW-Well 2	09-Feb-26 13:03	1.9	---	0	0	---
10: TW TW4-Murdoch Glen TW	09-Feb-26 12:58	1.9	1.55	0	0	< 10
11: RW RW3-Point Clark RW-Well 2	09-Feb-26 15:03	1.9	---	0	0	---
12: RW RW4-Point Clark RW-Well 3	09-Feb-26 15:12	1.9	---	0	0	---
13: TW TW3-Point Clark TW	09-Feb-26 14:34	1.9	1.71	0	0	< 10
14: DW DW-Point Clark Community Centre	09-Feb-26 14:17	1.9	1.39	0	0	< 10
15: RW RW1-Blairs Grove RW-Well 3	09-Feb-26 13:53	1.9	---	0	0	---
16: TW TW1-Blairs Grove TW	09-Feb-26 13:42	1.9	1.26	0	0	< 10
17: DW DW-Chem Shed	09-Feb-26 13:23	1.9	1.26	0	0	< 10
18: DW DW-Amberley Beach SS (ACW)	09-Feb-26 15:31	1.9	1.21	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20482-FEB26

Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

06-February-2026

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 03 February 2026
LR Report: CA20175-FEB26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Feb-26	04-Feb-26	04-Feb-26
2: Analysis Start Time				10:10	10:10	09:40
3: Analysis Completed Date				06-Feb-26	06-Feb-26	06-Feb-26
4: Analysis Completed Time				10:14	10:14	10:14
5: MAC		---	---	0	0	---
6: RW RW2-Huronville South RW-Well 1	02-Feb-26 15:16	3.9	---	0	0	---
7: TW TW2-Huronville South TW	02-Feb-26 15:07	3.9	1.41	0	0	< 10
8: DW DW-Inverlyn Club House	02-Feb-26 15:27	3.9	1.33	0	0	< 10
9: RW RW1-Blairs Grove RW-Well 3	02-Feb-26 13:59	3.9	---	0	0	---
10: TW TW1-Blairs Grove TW	02-Feb-26 13:49	3.9	1.37	0	0	< 10
11: DW DW-Chem Shed	02-Feb-26 14:17	3.9	1.35	0	0	< 10
12: DW DW-Amberley Beach SS (ACW)	02-Feb-26 12:22	3.9	1.28	0	0	< 10
13: RW RW3-Point Clark RW-Well 2	02-Feb-26 12:57	3.9	---	0	0	---
14: RW RW4-Point Clark RW-Well 3	02-Feb-26 12:55	3.9	---	0	0	---
15: TW TW3-Point Clark TW	02-Feb-26 12:49	3.9	1.48	0	0	< 10
16: DW DW-Point Clark Community Centre	02-Feb-26 13:18	3.9	1.26	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well 2	02-Feb-26 14:45	3.9	---	0	0	---
18: TW TW4-Murdoch Glen TW	02-Feb-26 14:41	3.9	1.58	0	0	< 10

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

30-January-2026

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 27 January 2026
 LR Report: CA21124-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	28-Jan-26	28-Jan-26	28-Jan-26
2: Analysis Start Time		---	---	10:30	10:30	09:50
3: Analysis Completed Date		---	---	30-Jan-26	30-Jan-26	30-Jan-26
4: Analysis Completed Time		---	---	10:35	10:35	10:35
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW- Well 3	27-Jan-26 09:51	1.8	---	0	0	---
7: TW TW1-Blairs Grove TW	27-Jan-26 09:47	1.8	1.75	0	0	< 10
8: DW DW-Chem Shed	26-Jan-26 13:33	1.8	1.18	0	0	< 10
9: DW DW-Amberley Beach SS (ACW)	26-Jan-26 12:32	1.8	1.20	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	26-Jan-26 14:19	1.8	---	0	0	---
11: TW TW2-Huronville South TW	26-Jan-26 14:03	1.8	1.39	0	0	< 10
12: DW DW-Inverlyn Club House	26-Jan-26 14:25	1.8	1.17	0	0	< 10
13: RW RW3-Point Clark RW-Well 2	26-Jan-26 13:04	1.8	---	0	0	---
14: RW RW4-Point Clark RW-Well 3	26-Jan-26 13:12	1.8	---	0	0	---
15: TW TW3-Point Clark TW	26-Jan-26 12:57	1.8	1.29	0	0	10
16: DW DW-Point Clark Community Centre	26-Jan-26 13:21	1.8	1.31	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well 2	26-Jan-26 13:50	1.8	---	0	0	---
18: TW TW4-Murdoch Glen TW	26-Jan-26 13:45	1.8	1.65	0	0	10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21124-JAN26

Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

23-January-2026

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 20 January 2026
 LR Report: CA20825-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				21-Jan-26	21-Jan-26	21-Jan-26
2: Analysis Start Time				09:15	09:15	09:00
3: Analysis Completed Date				23-Jan-26	23-Jan-26	23-Jan-26
4: Analysis Completed Time				10:53	10:53	10:53
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW-Well 3	19-Jan-26 13:41	2.0	---	0	0	---
7: TW TW1-Blairs Grove TW	19-Jan-26 13:35	2.0	1.31	0	0	< 10
8: DW DW-Chem Shed	19-Jan-26 13:08	2.0	1.30	0	0	< 10
9: DW DW-Amberley Beach SS (ACW)	19-Jan-26 12:02	2.0	1.24	0	0	< 10
10: RW RW3-Point Clark RW-Well 2	19-Jan-26 12:17	2.0	---	0	0	---
11: RW RW4-Point Clark RW-Well 3	19-Jan-26 12:22	2.0	---	0	0	---
12: TW TW3-Point Clark TW	19-Jan-26 12:26	2.0	1.27	0	0	< 10
13: DW DW-Point Clark Community Centre	19-Jan-26 12:53	2.0	1.17	0	0	< 10
14: RW RW5-Murdoch Glen RW-Well 2	19-Jan-26 14:02	2.0	---	0	0	---
15: TW TW4-Murdoch Glen TW	19-Jan-26 13:58	2.0	1.78	0	0	< 10
16: RW RW2-Huronville South RW-Well 1	19-Jan-26 14:41	2.0	---	0	0	---
17: TW TW2-Huronville South TW	19-Jan-26 14:31	2.0	1.37	0	0	< 10
18: DW DW-Inverlyn Club House	19-Jan-26 14:20	2.0	1.35	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20825-JAN26

Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

16-January-2026

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 13 January 2026
 LR Report: CA20524-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				14-Jan-26	14-Jan-26	14-Jan-26
2: Analysis Start Time				11:00	11:00	10:35
3: Analysis Completed Date				16-Jan-26	16-Jan-26	16-Jan-26
4: Analysis Completed Time				11:54	11:54	11:54
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW-Well 3	12-Jan-26 14:03	3.1	---	0	0	---
7: TW TW1-Blairs Grove TW	12-Jan-26 13:50	3.1	1.34	0	0	< 10
8: DW DW-Chem Shed	12-Jan-26 13:16	3.1	1.28	0	0	< 10
9: DW DW-Amberley Beach SS (ACW)	12-Jan-26 12:06	3.1	1.26	0	0	< 10
10: RW RW2-Huronville South RW-Well 1	12-Jan-26 15:05	3.1	---	0	0	---
11: TW TW2-Huronville South TW	12-Jan-26 15:00	3.1	1.21	0	0	< 10
12: DW DW-Inverlyn Club House	12-Jan-26 15:13	3.1	1.29	0	0	< 10
13: RW RW5-Murdoch Glen RW-Well 2	12-Jan-26 14:44	3.1	---	0	0	---
14: TW TW4-Murdoch Glen TW	12-Jan-26 14:40	3.1	1.84	0	0	< 10
15: RW RW3-Point Clark RW-Well 2	12-Jan-26 12:48	3.1	---	0	0	---
16: RW RW4-Point Clark RW-Well 3	12-Jan-26 12:50	3.1	---	0	0	---
17: TW TW3-Point Clark TW	12-Jan-26 12:37	3.1	1.41	0	0	< 10
18: DW DW-Point Clark Community Centre	12-Jan-26 13:04	3.1	1.30	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA20524-JAN26

Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-January-2026

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 06 January 2026
 LR Report: CA20220-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-Jan-26	07-Jan-26	07-Jan-26
2: Analysis Start Time		---	---	10:05	10:05	09:40
3: Analysis Completed Date		---	---	09-Jan-26	09-Jan-26	09-Jan-26
4: Analysis Completed Time		---	---	09:55	09:55	09:55
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	05-Jan-26 12:45	3.6	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	05-Jan-26 12:19	3.6	---	0	0	---
8: TW TW3-Point Clark TW	05-Jan-26 12:28	3.6	1.70	0	0	< 10
9: DW DW-Point Clark Community Centre	05-Jan-26 12:56	3.6	1.33	0	0	< 10
10: RW RW1-Blairs Grove RW- Well 3	05-Jan-26 13:16	3.6	---	0	0	---
11: TW TW1-Blairs Grove TW	05-Jan-26 13:14	3.6	1.33	0	0	< 10
12: DW DW-Chem Shed	05-Jan-26 13:26	3.6	1.22	0	0	< 10
13: DW DW-Amberley Beach SS (ACW)	05-Jan-26 12:09	3.6	1.29	0	0	< 10
14: RW RW2-Huronville South RW-Well 1	05-Jan-26 14:10	3.6	---	0	0	---
15: TW TW2-Huronville South TW	05-Jan-26 14:08	3.6	1.37	0	0	< 10
16: DW DW-Inverlyn Club House	05-Jan-26 13:57	3.6	1.10	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well 2	05-Jan-26 13:44	3.6	---	0	0	---
18: TW TW4-Murdoch Glen TW	05-Jan-26 13:42	3.6	1.75	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety