

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

13-February-2026

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 10 February 2026
LR Report: CA20505-FEB26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				11-Feb-26	11-Feb-26	11-Feb-26
2: Analysis Start Time				12:20	12:20	11:45
3: Analysis Completed Date				13-Feb-26	13-Feb-26	13-Feb-26
4: Analysis Completed Time				11:41	11:41	11:41
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	10-Feb-26 09:51	1.9	1.65	0	0	< 10
7: DW DW-Lucknow Tower	10-Feb-26 09:42	1.9	1.54	0	0	< 10
8: DW DW-Lucknow SPS	10-Feb-26 10:04	1.9	1.47	0	0	---
9: RW RW1-Lucknow RW-Well 4	10-Feb-26 09:24	1.9	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	10-Feb-26 09:20	1.9	1.76	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	10-Feb-26 08:56	1.9	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	10-Feb-26 09:01	1.9	1.69	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

06-February-2026

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 03 February 2026
LR Report: CA20207-FEB26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Feb-26	04-Feb-26	04-Feb-26
2: Analysis Start Time				16:15	16:15	15:30
3: Analysis Completed Date				06-Feb-26	06-Feb-26	06-Feb-26
4: Analysis Completed Time				13:40	13:40	13:40
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	03-Feb-26 10:20	3.9	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	03-Feb-26 10:18	3.9	1.74	0	0	10
8: RW RW2-Lucknow RW-Well 5	03-Feb-26 09:47	3.9	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	03-Feb-26 09:44	3.9	1.58	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

06-February-2026

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 03 February 2026
LR Report: CA20209-FEB26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Feb-26	04-Feb-26	04-Feb-26
2: Analysis Start Time				16:15	16:15	15:30
3: Analysis Completed Date				06-Feb-26	06-Feb-26	06-Feb-26
4: Analysis Completed Time				13:40	13:40	13:40
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	03-Feb-26 10:44	3.9	1.68	0	0	< 10
7: DW DW-Lucknow Tower	03-Feb-26 10:37	3.9	1.45	0	0	< 10
8: DW DW-Lucknow SPS	03-Feb-26 10:58	3.9	1.59	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

30-January-2026

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 27 January 2026
LR Report: CA21122-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				28-Jan-26	28-Jan-26	28-Jan-26
2: Analysis Start Time				10:30	10:30	09:50
3: Analysis Completed Date				30-Jan-26	30-Jan-26	30-Jan-26
4: Analysis Completed Time				10:35	10:35	10:35
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	26-Jan-26 13:47	1.8	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	26-Jan-26 13:45	1.8	1.66	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	26-Jan-26 13:27	1.8	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	26-Jan-26 13:25	1.8	1.50	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	26-Jan-26 14:07	1.8	1.65	0	0	< 10
11: DW DW-Lucknow Tower	26-Jan-26 14:00	1.8	1.49	0	0	< 10
12: DW DW-Lucknow SPS	26-Jan-26 14:20	1.8	1.53	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

23-January-2026

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 20 January 2026
LR Report: CA20831-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	21-Jan-26	21-Jan-26	21-Jan-26
2: Analysis Start Time		---	---	13:55	13:55	13:00
3: Analysis Completed Date		---	---	23-Jan-26	23-Jan-26	23-Jan-26
4: Analysis Completed Time		---	---	11:33	11:33	11:33
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	20-Jan-26 10:22	2.0	1.57	0	0	10
7: DW DW-Lucknow Tower	20-Jan-26 10:14	2.0	1.59	0	0	< 10
8: DW DW-Lucknow SPS	20-Jan-26 10:40	2.0	1.57	0	0	---
9: RW RW1-Lucknow RW-Well 4	20-Jan-26 09:57	2.0	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	20-Jan-26 10:01	2.0	1.88	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	20-Jan-26 09:47	2.0	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	20-Jan-26 09:45	2.0	1.55	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

19-January-2026

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 13 January 2026
 LR Report: CA20541-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				14-Jan-26	14-Jan-26	14-Jan-26
2: Analysis Start Time				15:40	15:40	15:00
3: Analysis Completed Date				16-Jan-26	16-Jan-26	16-Jan-26
4: Analysis Completed Time				15:53	15:53	15:53
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	13-Jan-26 09:27	3.1	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	13-Jan-26 09:32	3.1	1.84	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	13-Jan-26 09:18	3.1	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	13-Jan-26 09:12	3.1	1.51	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	13-Jan-26 10:14	3.1	1.60	0	0	< 10
11: DW DW-Lucknow Tower	13-Jan-26 09:50	3.1	1.60	0	0	< 10
12: DW DW-Lucknow SPS	13-Jan-26 10:27	3.1	1.46	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-January-2026

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 06 January 2026
 LR Report: CA20223-JAN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-Jan-26	07-Jan-26	07-Jan-26
2: Analysis Start Time		---	---	14:45	14:45	14:25
3: Analysis Completed Date		---	---	09-Jan-26	09-Jan-26	09-Jan-26
4: Analysis Completed Time		---	---	12:40	12:40	12:40
5: MAC		---	---	0	0	---
6: DW DW-86667 County Road 1 South (ACW)	06-Jan-26 10:22	3.6	1.60	0	0	< 10
7: DW DW-Lucknow Tower	06-Jan-26 10:15	3.6	1.49	0	0	< 10
8: DW DW-Lucknow SPS	06-Jan-26 10:30	3.6	1.39	0	0	---
9: RW RW1-Lucknow RW-Well 4	06-Jan-26 10:01	3.6	---	0	0	---
10: TW TW1-Lucknow TW-Well 4	06-Jan-26 09:59	3.6	1.84	0	0	< 10
11: RW RW2-Lucknow RW-Well 5	06-Jan-26 09:45	3.6	---	0	0	---
12: TW TW2-Lucknow TW-Well 5	06-Jan-26 09:47	3.6	1.66	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
HPC	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety