

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-November-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 14 November 2023
 LR Report: CA20625-NOV23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date					15-Nov-23	15-Nov-23	15-Nov-23
2: Analysis Start Time					10:40	10:40	10:05
3: Analysis Completed Date					17-Nov-23	17-Nov-23	17-Nov-23
4: Analysis Completed Time					12:03	12:03	12:03
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	14-Nov-23 10:20	8.4	---	0.21	0	0	---
7: TW Lucknow #4 Treated	14-Nov-23 10:20	8.4	1.84	0.27	0	0	< 10
8: RW Lucknow #5 Raw	14-Nov-23 09:50	8.4	---	0.24	0	0	---
9: TW Lucknow #5 Treated	14-Nov-23 09:50	8.4	1.94	0.25	0	0	< 10
10: DW DW LLS	14-Nov-23 09:40	8.4	1.50	---	0	0	< 10
11: DW DW LET	14-Nov-23 11:10	8.4	1.70	---	0	0	10
12: DW DW 86667	14-Nov-23 11:05	8.4	1.50	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

10-November-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 07 November 2023
LR Report: CA20338-NOV23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				08-Nov-23	08-Nov-23	08-Nov-23
2: Analysis Start Time				13:00	13:00	12:40
3: Analysis Completed Date				10-Nov-23	10-Nov-23	10-Nov-23
4: Analysis Completed Time				12:26	12:26	12:26
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	07-Nov-23 11:25	10.6	---	0	0	---
7: TW Lucknow #4 Treated	07-Nov-23 11:20	10.6	1.65	0	0	< 10
8: RW Lucknow #5 Raw	07-Nov-23 11:00	10.6	---	0	0	---
9: TW Lucknow #5 Treated	07-Nov-23 10:50	10.6	1.78	0	0	< 10
10: DW DW LLS	07-Nov-23 10:35	10.6	1.33	0	0	< 10
11: DW DW 86667	07-Nov-23 11:55	10.6	1.23	0	0	< 10
12: DW DW Arena	07-Nov-23 11:40	10.6	1.38	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

03-November-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 31 October 2023
LR Report: CA20003-NOV23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date		---	---	01-Nov-23	01-Nov-23
2: Analysis Start Time		---	---	09:45	09:45
3: Analysis Completed Date		---	---	03-Nov-23	03-Nov-23
4: Analysis Completed Time		---	---	11:35	11:35
5: MAC		---	---	0	0
6: NR LET Commission SS 10:50	30-Oct-23 10:50	7.2	1.42	0	0
7: NR LET Commission SS 11:15	31-Oct-23 11:15	7.2	1.41	0	0

MAC - Maximum Acceptable Concentration
 NR - Not reportable under applicable Provincial drinking water regulations as per client.

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

27-October-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 24 October 2023
LR Report: CA21256-OCT23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	25-Oct-23	25-Oct-23	25-Oct-23
2: Analysis Start Time		---	---	13:40	13:40	13:05
3: Analysis Completed Date		---	---	27-Oct-23	27-Oct-23	27-Oct-23
4: Analysis Completed Time		---	---	12:29	12:29	12:29
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	24-Oct-23 11:40	9.2	---	0	0	---
7: TW Lucknow #4 Treated	24-Oct-23 11:35	9.2	1.64	0	0	< 10
8: RW Lucknow #5 Raw	24-Oct-23 12:20	9.2	---	0	0	---
9: TW Lucknow #5 Treated	24-Oct-23 12:25	9.2	1.43	0	0	< 10
10: DW DW Arena	24-Oct-23 11:50	9.2	1.32	0	0	10
11: DW DW 86667 Ross St (ACW)	24-Oct-23 11:55	9.2	1.26	0	0	< 10
12: DW DW LLS	24-Oct-23 12:05	9.2	1.36	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

20-October-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 17 October 2023
 LR Report: CA20913-OCT23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	18-Oct-23	18-Oct-23	18-Oct-23
2: Analysis Start Time		---	---	---	11:55	11:55	11:20
3: Analysis Completed Date		---	---	---	20-Oct-23	20-Oct-23	20-Oct-23
4: Analysis Completed Time		---	---	---	11:50	11:50	11:50
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	17-Oct-23 10:40	8.4	---	0.18	0	0	---
7: TW Lucknow #4 Treated	17-Oct-23 10:45	8.4	1.64	---	0	0	< 10
8: RW Lucknow #5 Raw	17-Oct-23 11:05	8.4	---	0.09	0	0	---
9: TW Lucknow #5 Treated	17-Oct-23 11:00	8.4	1.80	---	0	0	10
10: DW DW LLS	17-Oct-23 10:15	8.4	1.25	---	0	0	< 10
11: DW DW 86667 Ross St (ACW)	17-Oct-23 10:05	8.4	1.36	---	0	0	< 10
12: DW DW Arena	17-Oct-23 09:50	8.4	1.13	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

20-October-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 17 October 2023
 LR Report: CA20913-OCT23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	18-Oct-23	18-Oct-23	18-Oct-23
2: Analysis Start Time		---	---	---	11:55	11:55	11:20
3: Analysis Completed Date		---	---	---	20-Oct-23	20-Oct-23	20-Oct-23
4: Analysis Completed Time		---	---	---	11:50	11:50	11:50
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	17-Oct-23 10:40	8.4	---	0.18	0	0	---
7: TW Lucknow #4 Treated	17-Oct-23 10:45	8.4	1.64	---	0	0	< 10
8: RW Lucknow #5 Raw	17-Oct-23 11:05	8.4	---	0.09	0	0	---
9: TW Lucknow #5 Treated	17-Oct-23 11:00	8.4	1.80	---	0	0	10
10: DW DW LLS	17-Oct-23 10:15	8.4	1.25	---	0	0	< 10
11: DW DW 86667 Ross St (ACW)	17-Oct-23 10:05	8.4	1.36	---	0	0	< 10
12: DW DW Arena	17-Oct-23 09:50	8.4	1.13	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

13-October-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 10 October 2023
 LR Report: CA20489-OCT23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	11-Oct-23	11-Oct-23	11-Oct-23
2: Analysis Start Time		---	---	13:50	13:50	13:20
3: Analysis Completed Date		---	---	13-Oct-23	13-Oct-23	13-Oct-23
4: Analysis Completed Time		---	---	11:29	11:29	11:29
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	10-Oct-23 10:15	6.2	---	0	0	---
7: TW Lucknow #4 Treated	10-Oct-23 10:10	6.2	1.68	0	0	10
8: RW Lucknow #5 Raw	10-Oct-23 09:50	6.2	---	0	0	---
9: TW Lucknow #5 Treated	10-Oct-23 09:45	6.2	1.87	0	0	< 10
10: DW DW 86667 Ross St (ACW)	10-Oct-23 09:10	6.2	1.07	0	0	< 10
11: DW DW LLS	10-Oct-23 09:25	6.2	1.20	0	0	< 10
12: DW DW Arena	10-Oct-23 09:00	6.2	0.82	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20489-OCT23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

06-October-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 03 October 2023
LR Report: CA20162-OCT23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				04-Oct-23	04-Oct-23	04-Oct-23
2: Analysis Start Time				10:50	10:50	10:25
3: Analysis Completed Date				06-Oct-23	06-Oct-23	06-Oct-23
4: Analysis Completed Time				12:51	12:51	12:51
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	03-Oct-23 10:55	14.7	---	0	0	---
7: TW Lucknow #4 Treated	03-Oct-23 10:55	14.7	1.55	0	0	< 10
8: RW Lucknow #5 Raw	03-Oct-23 10:35	14.7	---	0	0	---
9: TW Lucknow #5 Treated	03-Oct-23 10:35	14.7	1.80	0	0	< 10
10: DW DW LLS	03-Oct-23 10:25	14.7	1.43	0	0	< 10
11: DW DW Old Firehall	03-Oct-23 10:10	14.7	1.39	0	0	< 10
12: DW DW 86667	03-Oct-23 10:00	14.7	1.13	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

29-September-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 26 September 2023
LR Report: CA21404-SEP23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	27-Sep-23	27-Sep-23	27-Sep-23
2: Analysis Start Time		---	---	11:55	11:55	11:30
3: Analysis Completed Date		---	---	29-Sep-23	29-Sep-23	29-Sep-23
4: Analysis Completed Time		---	---	11:45	11:45	11:45
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	26-Sep-23 09:55	8.3	---	0	0	---
7: TW Lucknow #4 Treated	26-Sep-23 09:50	8.3	1.67	0	0	< 10
8: RW Lucknow #5 Raw	26-Sep-23 09:35	8.3	---	0	0	---
9: TW Lucknow #5 Treated	26-Sep-23 09:30	8.3	1.68	0	0	< 10
10: DW DW Arena	26-Sep-23 08:40	8.3	1.44	0	0	< 10
11: DW DW 86667 Ross St (ACW)	26-Sep-23 08:55	8.3	1.16	0	0	< 10
12: DW DW LLS	26-Sep-23 09:05	8.3	1.10	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

22-September-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 19 September 2023
 LR Report: CA21011-SEP23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	20-Sep-23	20-Sep-23	20-Sep-23
2: Analysis Start Time		---	---	13:40	13:40	12:40
3: Analysis Completed Date		---	---	22-Sep-23	22-Sep-23	22-Sep-23
4: Analysis Completed Time		---	---	12:39	12:39	12:39
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	19-Sep-23 09:55	6.6	---	0	0	---
7: TW Lucknow #4 Treated	19-Sep-23 09:50	6.6	1.47	0	0	< 10
8: RW Lucknow #5 Raw	19-Sep-23 09:30	6.6	---	0	0	---
9: TW Lucknow #5 Treated	19-Sep-23 09:35	6.6	1.51	0	0	< 10
10: DW DW LLS	19-Sep-23 09:05	6.6	1.22	0	0	< 10
11: DW DW 86667 Ross St (ACW)	19-Sep-23 08:55	6.6	1.03	0	0	< 10
12: DW DW Arena	19-Sep-23 08:45	6.6	1.28	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

15-September-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 12 September 2023
 LR Report: CA20581-SEP23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date					13-Sep-23	13-Sep-23	13-Sep-23
2: Analysis Start Time					14:50	14:50	14:05
3: Analysis Completed Date					15-Sep-23	15-Sep-23	15-Sep-23
4: Analysis Completed Time					16:07	16:07	16:07
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	12-Sep-23 10:30	5.8	---	0.14	0	0	---
7: TW Lucknow #4 Treated	12-Sep-23 10:25	5.8	1.48	---	0	0	< 10
8: RW Lucknow #5 Raw	12-Sep-23 10:05	5.8	---	0.12	0	0	---
9: TW Lucknow #5 Treated	12-Sep-23 10:10	5.8	1.66	---	0	0	< 10
10: DW DW LLS	12-Sep-23 09:35	5.8	1.20	---	0	0	< 10
11: DW DW 86667 Ross St (ACW)	12-Sep-23 09:20	5.8	1.02	---	0	0	< 10
12: DW DW Arena	12-Sep-23 09:10	5.8	1.19	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

08-September-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 05 September 2023
 LR Report: CA20094-SEP23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				06-Sep-23	06-Sep-23	06-Sep-23
2: Analysis Start Time				11:35	11:35	11:10
3: Analysis Completed Date				08-Sep-23	08-Sep-23	08-Sep-23
4: Analysis Completed Time				11:29	11:29	11:29
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	05-Sep-23 09:45	13.9	---	0	0	---
7: TW Lucknow #4 Treated	05-Sep-23 09:50	13.9	1.59	0	0	< 10
8: RW Lucknow #5 Raw	05-Sep-23 09:35	13.9	---	0	0	---
9: TW Lucknow #5 Treated	05-Sep-23 09:30	13.9	1.61	0	0	< 10
10: DW DW Arena	05-Sep-23 08:45	13.9	1.24	0	0	10
11: DW DW 86667 Ross St (ACW)	05-Sep-23 08:55	13.9	1.14	0	0	< 10
12: DW DW LLS	05-Sep-23 09:10	13.9	1.13	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

01-September-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 29 August 2023
LR Report: CA21692-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	30-Aug-23	30-Aug-23	30-Aug-23
2: Analysis Start Time		---	---	12:55	12:55	12:15
3: Analysis Completed Date		---	---	01-Sep-23	01-Sep-23	01-Sep-23
4: Analysis Completed Time		---	---	10:18	10:18	10:18
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	29-Aug-23 09:55	6.6	---	0	0	---
7: TW Lucknow #4 Treated	29-Aug-23 09:50	6.6	1.61	0	0	< 10
8: RW Lucknow #5 Raw	29-Aug-23 09:35	6.6	---	0	0	---
9: TW Lucknow #5 Treated	29-Aug-23 09:30	6.6	1.62	0	0	< 10
10: DW DW 86667 Ross (ACW)	29-Aug-23 09:05	6.6	1.04	0	0	< 10
11: DW DW LLS	29-Aug-23 09:10	6.6	1.21	0	0	< 10
12: DW DW Arena	29-Aug-23 08:55	6.6	1.31	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

25-August-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 22 August 2023
 LR Report: CA21325-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	23-Aug-23	23-Aug-23	23-Aug-23
2: Analysis Start Time		---	---	11:50	11:50	11:00
3: Analysis Completed Date		---	---	25-Aug-23	25-Aug-23	25-Aug-23
4: Analysis Completed Time		---	---	12:36	12:36	12:36
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	22-Aug-23 13:20	14.2	---	0	0	---
7: TW Lucknow #4 Treated	22-Aug-23 13:15	14.2	1.58	0	0	< 10
8: RW Lucknow #5 Raw	22-Aug-23 12:55	14.2	---	0	0	---
9: TW Lucknow #5 Treated	22-Aug-23 12:50	14.2	1.57	0	0	< 10
10: DW DW 484 Ludgard	22-Aug-23 13:30	14.2	1.11	0	0	10
11: DW DW Arena	22-Aug-23 14:00	14.2	1.07	0	0	10
12: DW DW 86669	22-Aug-23 13:55	14.2	1.03	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

18-August-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 15 August 2023
 LR Report: CA20936-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	16-Aug-23	16-Aug-23	16-Aug-23
2: Analysis Start Time		---	---	---	13:50	13:50	13:00
3: Analysis Completed Date		---	---	---	18-Aug-23	18-Aug-23	18-Aug-23
4: Analysis Completed Time		---	---	---	11:02	11:02	11:02
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	15-Aug-23 13:15	5.9	---	0.11	0	0	---
7: TW Lucknow #4 Treated	15-Aug-23 13:10	5.9	1.68	---	0	0	< 10
8: RW Lucknow #5 Raw	15-Aug-23 12:55	5.9	---	0.17	0	0	---
9: TW Lucknow #5 Treated	15-Aug-23 12:50	5.9	1.61	---	0	0	< 10
10: DW DW 86667 Ross St	15-Aug-23 12:20	5.9	1.09	---	0	0	< 10
11: DW DW LLS	15-Aug-23 12:30	5.9	1.16	---	0	0	< 10
12: DW DW Arena	15-Aug-23 10:55	5.9	1.25	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

11-August-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 08 August 2023
 LR Report: CA20440-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	09-Aug-23	09-Aug-23	09-Aug-23
2: Analysis Start Time		---	---	12:25	12:25	11:30
3: Analysis Completed Date		---	---	11-Aug-23	11-Aug-23	11-Aug-23
4: Analysis Completed Time		---	---	11:53	11:53	11:53
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	08-Aug-23 10:45	12.4	---	0	0	---
7: TW Lucknow #4 Treated	08-Aug-23 10:40	12.4	1.63	0	0	< 10
8: RW Lucknow #5 Raw	08-Aug-23 10:10	12.4	---	0	0	---
9: TW Lucknow #5 Treated	08-Aug-23 10:05	12.4	1.70	0	0	< 10
10: DW DW LLS	08-Aug-23 09:45	12.4	1.14	0	0	< 10
11: DW 86667 Ross St (ACW)	08-Aug-23 09:35	12.4	1.04	0	0	< 10
12: DW DW Arena	08-Aug-23 09:20	12.4	1.17	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

04-August-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 01 August 2023
 LR Report: CA20150-AUG23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				02-Aug-23	02-Aug-23	02-Aug-23
2: Analysis Start Time				12:20	12:20	11:45
3: Analysis Completed Date				04-Aug-23	04-Aug-23	04-Aug-23
4: Analysis Completed Time				13:07	13:07	13:07
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	01-Aug-23 10:30	5.8	---	0	0	---
7: TW Lucknow #4 Treated	01-Aug-23 10:25	5.8	1.66	0	0	< 10
8: RW Lucknow #5 Raw	01-Aug-23 08:10	5.8	---	0	0	---
9: TW Lucknow #5 Treated	01-Aug-23 08:15	5.8	1.58	0	0	10
10: DW DW 86667 Ross St ACW	01-Aug-23 10:15	5.8	1.04	0	0	< 10
11: DW DW Old Fire Hall	01-Aug-23 10:00	5.8	1.37	0	0	10
12: DW DW LLS	01-Aug-23 09:45	5.8	1.21	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-July-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 25 July 2023
 LR Report: CA21423-JUL23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Jul-23	26-Jul-23	26-Jul-23
2: Analysis Start Time		---	---	13:50	13:50	13:20
3: Analysis Completed Date		---	---	28-Jul-23	28-Jul-23	28-Jul-23
4: Analysis Completed Time		---	---	15:24	15:24	15:24
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	25-Jul-23 10:35	11.6	---	0	0	---
7: TW Lucknow #4 Treated	25-Jul-23 10:30	11.6	1.55	0	0	< 10
8: RW Lucknow #5 Raw	25-Jul-23 10:15	11.6	---	0	0	---
9: TW Lucknow #5 Treated	25-Jul-23 10:10	11.6	1.54	0	0	20
10: DW DW Arena	25-Jul-23 09:30	11.6	1.32	0	0	< 10
11: DW DW 86667 Ross St (ACW)	25-Jul-23 09:40	11.6	1.09	0	0	< 10
12: DW DW LLS	25-Jul-23 09:50	11.6	1.19	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

21-July-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 18 July 2023
 LR Report: CA21013-JUL23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	19-Jul-23	19-Jul-23	19-Jul-23
2: Analysis Start Time		---	---	12:10	12:10	11:35
3: Analysis Completed Date		---	---	21-Jul-23	21-Jul-23	21-Jul-23
4: Analysis Completed Time		---	---	13:08	13:08	13:08
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	18-Jul-23 10:00	9.9	---	0	0	---
7: TW Lucknow #4 Treated	18-Jul-23 09:55	9.9	1.56	0	0	10
8: RW Lucknow #5 Raw	18-Jul-23 09:40	9.9	---	0	0	---
9: TW Lucknow #5 Treated	18-Jul-23 09:35	9.9	1.57	0	0	10
10: DW DW LLS	18-Jul-23 09:15	9.9	1.29	0	0	< 10
11: DW DW 86667 Ross St (ACW)	18-Jul-23 09:05	9.9	1.04	0	0	10
12: DW DW Arena	18-Jul-23 08:50	9.9	1.18	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-July-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 11 July 2023
 LR Report: CA20575-JUL23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	12-Jul-23	12-Jul-23	12-Jul-23
2: Analysis Start Time		---	---	---	12:30	12:30	12:25
3: Analysis Completed Date		---	---	---	14-Jul-23	14-Jul-23	14-Jul-23
4: Analysis Completed Time		---	---	---	12:15	12:15	12:15
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	11-Jul-23 10:35	5.1	---	0.14	0	0	---
7: TW Lucknow #4 Treated	11-Jul-23 10:30	5.1	1.58	---	0	0	< 10
8: RW Lucknow #5 Raw	11-Jul-23 10:15	5.1	---	---	0	0	---
9: TW Lucknow #5 Treated	11-Jul-23 10:10	5.1	1.51	0.14	0	0	< 10
10: DW DW LLS	11-Jul-23 09:45	5.1	1.31	---	0	0	< 10
11: DW DW 86663 Ross St (ACW)	11-Jul-23 09:35	5.1	1.18	---	0	0	20
12: DW DW Arena	11-Jul-23 09:25	5.1	1.26	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury
 Project Specialist,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

07-July-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 04 July 2023
 LR Report: CA20094-JUL23

100 Cove Rd., Goderich
 Canada, N7A 3Z2
 Phone: 519-524-6583, Fax:519-524-9358

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	05-Jul-23	05-Jul-23	05-Jul-23
2: Analysis Start Time		---	---	11:30	11:30	10:55
3: Analysis Completed Date		---	---	06-Jul-23	06-Jul-23	07-Jul-23
4: Analysis Completed Time		---	---	16:15	16:15	10:11
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	04-Jul-23 09:40	13.0	---	0	0	---
7: TW Lucknow #4 Treated	04-Jul-23 09:35	13.0	1.54	0	0	< 10
8: RW Lucknow #5 Raw	04-Jul-23 09:20	13.0	---	0	0	---
9: TW Lucknow #5 Treated	04-Jul-23 09:15	13.0	1.51	0	0	< 10
10: DW DW LLS	04-Jul-23 08:50	13.0	1.24	0	0	< 10
11: DW DW 86667 Ross St ACW	04-Jul-23 08:40	13.0	1.20	0	0	< 10
12: DW DW Arena	04-Jul-23 08:25	13.0	1.19	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

30-June-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 27 June 2023
 LR Report: CA21518-JUN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	28-Jun-23	28-Jun-23	28-Jun-23
2: Analysis Start Time		---	---	11:10	11:10	10:45
3: Analysis Completed Date		---	---	30-Jun-23	30-Jun-23	30-Jun-23
4: Analysis Completed Time		---	---	10:40	10:40	10:40
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	27-Jun-23 09:25	7.1	---	0	0	---
7: TW Lucknow #4 Treated	27-Jun-23 09:20	7.1	1.58	0	0	< 10
8: RW Lucknow #5 Raw	27-Jun-23 09:15	7.1	---	0	0	---
9: TW Lucknow #5 Treated	27-Jun-23 09:10	7.1	1.61	0	0	< 10
10: DW DW LCS	27-Jun-23 08:50	7.1	1.47	0	0	< 10
11: DW DW 86667 Ross St (ACW)	27-Jun-23 08:40	7.1	1.15	0	0	< 10
12: DW DW Arena	27-Jun-23 08:30	7.1	1.19	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

23-June-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 20 June 2023
LR Report: CA21125-JUN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	21-Jun-23	21-Jun-23	21-Jun-23
2: Analysis Start Time		---	---	12:20	12:20	11:45
3: Analysis Completed Date		---	---	23-Jun-23	23-Jun-23	23-Jun-23
4: Analysis Completed Time		---	---	10:08	10:08	10:08
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	20-Jun-23 10:15	8.7	---	0	0	---
7: TW Lucknow #4 Treated	20-Jun-23 10:10	8.7	1.56	0	0	< 10
8: RW Lucknow #5 Raw	20-Jun-23 09:35	8.7	---	0	0	---
9: TW Lucknow #5 Treated	20-Jun-23 09:30	8.7	1.58	0	0	< 10
10: DW DW LLS	20-Jun-23 09:10	8.7	1.27	0	0	< 10
11: DW DW 86667 Ross St (ACW)	20-Jun-23 08:55	8.7	1.09	0	0	< 10
12: DW DW Arena	20-Jun-23 08:45	8.7	1.20	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

16-June-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 13 June 2023
 LR Report: CA20722-JUN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	14-Jun-23	14-Jun-23	14-Jun-23
2: Analysis Start Time		---	---	---	12:20	12:20	11:55
3: Analysis Completed Date		---	---	---	16-Jun-23	16-Jun-23	16-Jun-23
4: Analysis Completed Time		---	---	---	11:49	11:49	11:49
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	13-Jun-23 10:10	9.6	---	0.21	0	0	---
7: TW Lucknow #4 Treated	13-Jun-23 10:05	9.6	1.58	---	0	0	< 10
8: RW Lucknow #5 Raw	13-Jun-23 09:40	9.6	---	0.31	0	0	---
9: TW Lucknow #5 Treated	13-Jun-23 09:45	9.6	1.63	---	0	0	< 10
10: DW DW LLS	13-Jun-23 09:25	9.6	1.52	---	0	0	< 10
11: DW DW 86667 Ross St (ACW)	13-Jun-23 09:15	9.6	1.31	---	0	0	< 10
12: DW DW Arena	13-Jun-23 09:00	9.6	1.26	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-June-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 06 June 2023
 LR Report: CA20370-JUN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	07-Jun-23	07-Jun-23	07-Jun-23
2: Analysis Start Time		---	---	17:15	17:15	15:45
3: Analysis Completed Date		---	---	09-Jun-23	09-Jun-23	09-Jun-23
4: Analysis Completed Time		---	---	15:37	15:37	15:37
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	06-Jun-23 11:15	8.0	---	0	0	---
7: TW Lucknow #4 Treated	06-Jun-23 11:10	8.0	1.56	0	0	< 10
8: RW Lucknow #5 Raw	06-Jun-23 10:50	8.0	---	0	0	---
9: TW Lucknow #5 Treated	06-Jun-23 10:45	8.0	1.67	0	0	< 10
10: DW DW Arena	06-Jun-23 10:00	8.0	1.29	0	0	< 10
11: DW DW 86667 Ross St ACW	06-Jun-23 10:10	8.0	1.42	0	0	< 10
12: DW DW LLS	06-Jun-23 10:20	8.0	1.25	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

02-June-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 30 May 2023
 LR Report: CA21659-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	31-May-23	31-May-23	31-May-23
2: Analysis Start Time		---	---	11:35	11:35	10:55
3: Analysis Completed Date		---	---	02-Jun-23	02-Jun-23	02-Jun-23
4: Analysis Completed Time		---	---	12:57	12:57	12:57
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	30-May-23 10:30	8.9	---	0	0	---
7: TW Lucknow #4 Treated	30-May-23 10:25	8.9	1.57	0	0	< 10
8: RW Lucknow #5 Raw	30-May-23 10:15	8.9	---	0	0	---
9: TW Lucknow #5 Treated	30-May-23 10:10	8.9	1.47	0	0	10
10: DW DW LLS	30-May-23 09:55	8.9	1.34	0	0	< 10
11: DW DW 86667 Ross St (ACW)	30-May-23 09:40	8.9	1.27	0	0	< 10
12: DW DW Arena	30-May-23 09:20	8.9	1.17	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

26-May-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 23 May 2023
 LR Report: CA21249-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS


Final Report

Sample ID	Sample Date & Temperature Time Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli Heterotrophic cfu/100mL	Plate Count (HPC) cfu/1mL
1: Analysis Start Date	---	---	24-May-23	24-May-23	24-May-23
2: Analysis Start Time	---	---	12:00	12:00	11:25
3: Analysis Completed Date	---	---	26-May-23	26-May-23	26-May-23
4: Analysis Completed Time	---	---	11:34	11:34	11:34
5: MAC	---	---	0	0	---
6: RW Lucknow #4 Raw	23-May-23 10:15	10.5	0	0	---
7: TW Lucknow #4 Treated	23-May-23 10:20	10.5	1.61	0	< 10
8: RW Lucknow #5 Raw	23-May-23 10:05	10.5	---	0	---
9: TW Lucknow #5 Treated	23-May-23 10:00	10.5	1.52	0	< 10
10: DW DW LLS	23-May-23 09:40	10.5	1.41	0	< 10
11: DW DW 86667 Ross St (ACW)	23-May-23 09:20	10.5	1.26	0	< 10
12: DW DW Arena	23-May-23 09:05	10.5	1.09	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

19-May-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 16 May 2023
 LR Report: CA20981-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	17-May-23	17-May-23	17-May-23
2: Analysis Start Time		---	---	---	10:05	10:05	09:45
3: Analysis Completed Date		---	---	---	19-May-23	19-May-23	19-May-23
4: Analysis Completed Time		---	---	---	10:39	10:39	10:39
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	15-May-23 14:50	5.0	---	0.14	0	0	---
7: TW Lucknow #4 Treated	15-May-23 14:45	5.0	1.61	---	0	0	< 10
8: RW Lucknow #5 Raw	15-May-23 14:30	5.0	---	0.20	0	0	---
9: TW Lucknow #5 Treated	15-May-23 14:25	5.0	1.67	---	0	0	< 10
10: DW DW School	15-May-23 14:11	5.0	1.45	---	0	0	< 10
11: DW DW 86667 Ross St (ACW)	15-May-23 14:00	5.0	1.26	---	0	0	< 10
12: DW DW Arena	15-May-23 13:45	5.0	0.84	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

12-May-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 09 May 2023
 LR Report: CA20549-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	10-May-23	10-May-23	10-May-23
2: Analysis Start Time		---	---	13:50	13:50	12:50
3: Analysis Completed Date		---	---	12-May-23	12-May-23	12-May-23
4: Analysis Completed Time		---	---	13:12	13:12	13:12
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	09-May-23 11:45	9.2	---	0	0	---
7: TW Lucknow #4 Treated	09-May-23 11:50	9.2	1.70	0	0	< 10
8: RW Lucknow #5 Raw	09-May-23 12:35	9.2	---	0	0	---
9: TW Lucknow #5 Treated	09-May-23 12:30	9.2	1.56	0	0	< 10
10: DW DW School	09-May-23 12:15	9.2	1.49	0	0	20
11: DW DW 86667 Ross St ACW	09-May-23 11:15	9.2	1.19	0	0	< 10
12: DW DW Arena	09-May-23 11:00	9.2	1.23	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

05-May-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 02 May 2023
 LR Report: CA20240-MAY23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	03-May-23	03-May-23	03-May-23
2: Analysis Start Time		---	---	14:10	14:10	13:35
3: Analysis Completed Date		---	---	05-May-23	05-May-23	05-May-23
4: Analysis Completed Time		---	---	14:30	14:30	14:30
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	02-May-23 10:20	6.9	---	0	0	---
7: TW Lucknow #4 Treated	02-May-23 10:15	6.9	1.68	0	0	< 10
8: RW Lucknow #5 Raw	02-May-23 10:35	6.9	---	0	0	---
9: TW Lucknow #5 Treated	02-May-23 10:40	6.9	1.59	0	0	< 10
10: DW DW 86667 Ross St ACW	02-May-23 10:00	6.9	1.20	0	0	< 10
11: DW DW Arena	02-May-23 09:50	6.9	1.26	0	0	< 10
12: DW DW LLS	02-May-23 09:45	6.9	1.35	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

28-April-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 25 April 2023
 LR Report: CA21224-APR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	26-Apr-23	26-Apr-23	26-Apr-23
2: Analysis Start Time		---	---	14:20	14:20	14:00
3: Analysis Completed Date		---	---	28-Apr-23	28-Apr-23	28-Apr-23
4: Analysis Completed Time		---	---	11:41	11:41	11:41
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	25-Apr-23 10:30	7.6	---	0	0	---
7: TW Lucknow #4 Treated	25-Apr-23 10:25	7.6	1.67	0	0	< 10
8: RW Lucknow #5 Raw	25-Apr-23 10:10	7.6	---	0	0	---
9: TW Lucknow #5 Treated	25-Apr-23 10:05	7.6	1.52	0	0	< 10
10: DW DW LLS	25-Apr-23 09:40	7.6	1.29	0	0	< 10
11: DW DW 86667 Ross St (ACLO)	25-Apr-23 09:30	7.6	1.17	0	0	< 10
12: DW DW Arena	25-Apr-23 09:15	7.6	1.08	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Parameter	Description	SGS Method Code
E.Coli	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
Total Coliform	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Kimberley Didsbury
 Project Specialist,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

21-April-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 18 April 2023
 LR Report: CA20871-APR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				19-Apr-23	19-Apr-23	19-Apr-23
2: Analysis Start Time				14:15	14:15	13:45
3: Analysis Completed Date				21-Apr-23	21-Apr-23	21-Apr-23
4: Analysis Completed Time				12:03	12:03	12:03
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	18-Apr-23 09:20	6.6	---	0	0	---
7: TW Lucknow #4 Treated	18-Apr-23 09:15	6.6	1.67	0	0	< 10
8: RW Lucknow #5 Raw	18-Apr-23 09:05	6.6	---	0	0	---
9: TW Lucknow #5 Treated	18-Apr-23 09:00	6.6	1.67	0	0	< 10
10: DW DW Arena	18-Apr-23 08:10	6.6	1.26	0	0	< 10
11: DW DW 86667 Ross St (ACW)	18-Apr-23 08:20	6.6	1.33	0	0	< 10
12: DW DW LLS	18-Apr-23 08:45	6.6	1.48	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

14-April-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 11 April 2023
 LR Report: CA20434-APR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	12-Apr-23	12-Apr-23	12-Apr-23
2: Analysis Start Time		---	---	---	10:50	10:50	10:10
3: Analysis Completed Date		---	---	---	14-Apr-23	14-Apr-23	14-Apr-23
4: Analysis Completed Time		---	---	---	12:29	12:29	12:29
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	11-Apr-23 11:25	10.1	---	0.18	0	0	---
7: TW Lucknow #4 Treated	11-Apr-23 11:20	10.1	1.69	---	0	0	10
8: RW Lucknow #5 Raw	11-Apr-23 11:10	10.1	---	0.15	0	0	---
9: TW Lucknow #5 Treated	11-Apr-23 11:05	10.1	1.64	---	0	0	< 10
10: DW DW Arena	11-Apr-23 10:15	10.1	---	---	0	0	10
11: DW DW 86667 Ross St (ACW)	11-Apr-23 10:30	10.1	---	---	0	0	< 10
12: DW DW LLS	11-Apr-23 10:40	10.1	---	---	0	0	---

MAC - Maximum Acceptable Concentration

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

LR Report : CA20434-APR23

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

10-April-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 04 April 2023
 LR Report: CA20201-APR23

100 Cove Rd., Goderich
 Canada, N7A 3Z2
 Phone: 519-524-6583, Fax:519-524-9358

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				05-Apr-23	05-Apr-23	05-Apr-23
2: Analysis Start Time				14:25	14:25	13:45
3: Analysis Completed Date				10-Apr-23	10-Apr-23	10-Apr-23
4: Analysis Completed Time				10:44	10:44	10:44
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	04-Apr-23 09:15	7.6	---	0	0	---
7: TW Lucknow #4 Treated	04-Apr-23 09:10	7.6	1.78	0	0	< 10
8: RW Lucknow #5 Raw	04-Apr-23 08:55	7.6	---	0	0	---
9: TW Lucknow #5 Treated	04-Apr-23 08:50	7.6	1.52	0	0	< 10
10: DW DW School	04-Apr-23 08:40	7.6	1.44	0	0	20
11: DW DW 86667 Ross St (ACW)	04-Apr-23 08:25	7.6	1.19	0	0	< 10
12: DW DW Arena	04-Apr-23 08:15	7.6	1.27	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

31-March-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 28 March 2023
LR Report: CA21206-MAR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	29-Mar-23	29-Mar-23	29-Mar-23
2: Analysis Start Time		---	---	12:10	12:10	11:40
3: Analysis Completed Date		---	---	31-Mar-23	31-Mar-23	31-Mar-23
4: Analysis Completed Time		---	---	10:49	10:49	10:49
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	28-Mar-23 10:25	8.4	---	0	0	---
7: TW Lucknow #4 Treated	28-Mar-23 10:20	8.4	1.71	0	0	< 10
8: RW Lucknow #5 Raw	28-Mar-23 10:05	8.4	---	0	0	---
9: TW Lucknow #5 Treated	28-Mar-23 10:00	8.4	1.57	0	0	< 10
10: DW DW LLS	28-Mar-23 08:45	8.4	1.44	0	0	< 10
11: DW DW 86667 Ross St (ACW)	28-Mar-23 09:35	8.4	1.36	0	0	< 10
12: DW DW Arena	28-Mar-23 09:20	8.4	1.24	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-March-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 21 March 2023
 LR Report: CA20935-MAR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Mar-23	22-Mar-23	22-Mar-23
2: Analysis Start Time		---	---	13:00	13:00	12:15
3: Analysis Completed Date		---	---	24-Mar-23	24-Mar-23	24-Mar-23
4: Analysis Completed Time		---	---	13:16	13:16	13:16
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	21-Mar-23 09:40	8.4	---	0	0	---
7: TW Lucknow #4 Treated	21-Mar-23 09:45	8.4	1.78	0	0	10
8: RW Lucknow #5 Raw	21-Mar-23 09:20	8.4	---	0	0	---
9: TW Lucknow #5 Treated	21-Mar-23 09:15	8.4	1.58	0	0	< 10
10: DW DW LLS	21-Mar-23 08:50	8.4	1.44	0	0	< 10
11: DW DW 86667 Ross St (ACW)	21-Mar-23 08:35	8.4	1.39	0	0	10
12: DW DW Arena	21-Mar-23 08:20	8.4	1.23	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

20-March-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 14 March 2023
 LR Report: CA20637-MAR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	15-Mar-23	15-Mar-23	15-Mar-23
2: Analysis Start Time		---	---	---	15:50	15:50	15:25
3: Analysis Completed Date		---	---	---	18-Mar-23	18-Mar-23	18-Mar-23
4: Analysis Completed Time		---	---	---	10:53	10:53	10:53
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	14-Mar-23 11:35	11.4	---	0.21	0	0	---
7: TW Lucknow #4 Treated	14-Mar-23 11:30	11.4	1.74	---	0	0	< 10
8: RW Lucknow #5 Raw	14-Mar-23 10:55	11.4	---	0.13	0	0	---
9: TW Lucknow #5 Treated	14-Mar-23 10:50	11.4	1.71	---	0	0	10
10: DW DW 86667 Ross St. (ACW)	14-Mar-23 10:15	11.4	1.29	---	0	0	< 10
11: DW DW Arena	14-Mar-23 10:00	11.4	1.35	---	0	0	< 10
12: DW DW LLS	14-Mar-23 10:25	11.4	1.51	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

13-March-2023

Veolia Water (Lucknow)

Attn : Gary Nicholson

Date Rec. : 07 March 2023
 LR Report: CA20340-MAR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	08-Mar-23	08-Mar-23	08-Mar-23
2: Analysis Start Time		---	---	14:45	14:45	13:55
3: Analysis Completed Date		---	---	10-Mar-23	10-Mar-23	10-Mar-23
4: Analysis Completed Time		---	---	13:42	13:42	13:42
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	07-Mar-23 10:40	10.6	---	0	0	---
7: TW Lucknow #4 Treated	07-Mar-23 10:35	10.6	1.80	0	0	< 10
8: RW Lucknow #5 Raw	07-Mar-23 10:15	10.6	---	0	0	---
9: TW Lucknow #5 Treated	07-Mar-23 10:10	10.6	1.82	0	0	< 10
10: DW DW Arena	07-Mar-23 09:30	10.6	1.26	0	0	< 10
11: DW DW 86667 Ross St (ACW)	07-Mar-23 09:40	10.6	1.38	0	0	< 10
12: DW DW LLS	07-Mar-23 09:50	10.6	1.32	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

03-March-2023

Veolia Water (Lucknow)

Attn : Nancy Mayhew

Date Rec. : 28 February 2023
 LR Report: CA20011-MAR23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	01-Mar-23	01-Mar-23	01-Mar-23
2: Analysis Start Time		---	---	---	13:30	13:30	12:30
3: Analysis Completed Date		---	---	---	03-Mar-23	03-Mar-23	03-Mar-23
4: Analysis Completed Time		---	---	---	12:23	12:23	12:23
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	28-Feb-23 10:55	10.6	---	---	0	0	---
7: TW Lucknow #4 Treated	28-Feb-23 10:55	10.6	1.60	---	0	0	< 10
8: RW Lucknow #5 Raw	28-Feb-23 09:45	10.6	---	0.16	0	0	---
9: TW Lucknow #5 Treated	28-Feb-23 09:40	10.6	1.75	0.34	0	0	< 10
10: DW DW-Old Firehall	28-Feb-23 08:30	10.6	1.45	---	0	0	< 10
11: DW DW-Arena	28-Feb-23 09:00	10.6	1.20	---	0	0	< 10
12: DW DW-86667	28-Feb-23 09:15	10.6	1.30	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

24-February-2023

Veolia Water (Lucknow)

Attn : Nancy Mayhew

Date Rec. : 21 February 2023
 LR Report: CA20796-FEB23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	22-Feb-23	22-Feb-23	22-Feb-23
2: Analysis Start Time		---	---	11:15	11:15	10:35
3: Analysis Completed Date		---	---	24-Feb-23	24-Feb-23	24-Feb-23
4: Analysis Completed Time		---	---	14:14	14:14	14:14
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	21-Feb-23	9.1	---	0	0	---
7: TW Lucknow #4 Treated	21-Feb-23	9.1	1.75	0	0	10
8: RW Lucknow #5 Raw	21-Feb-23	9.1	---	0	0	---
9: TW Lucknow #5 Treated	21-Feb-23	9.1	1.80	0	0	< 10
10: DW DW 86667 Ross (ACW)	21-Feb-23	9.1	1.29	0	0	< 10
11: DW DW LLS	21-Feb-23	9.1	1.54	0	0	< 10
12: DW DW Arena	21-Feb-23	9.1	1.22	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

17-February-2023

Veolia Water (Lucknow)

Attn : Nancy Mayhew

Date Rec. : 14 February 2023
 LR Report: CA20607-FEB23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date					15-Feb-23	15-Feb-23	15-Feb-23
2: Analysis Start Time					13:00	13:00	12:05
3: Analysis Completed Date					17-Feb-23	17-Feb-23	17-Feb-23
4: Analysis Completed Time					11:57	11:57	11:57
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	14-Feb-23 11:05	9.7	---	0.15	0	0	---
7: TW Lucknow #4 Treated	14-Feb-23 11:10	9.7	1.72	---	0	0	< 10
8: RW Lucknow #5 Raw	14-Feb-23 12:55	9.7	---	0.13	0	0	---
9: TW Lucknow #5 Treated	14-Feb-23 12:50	9.7	1.84	---	0	0	< 10
10: DW DW School	14-Feb-23 12:35	9.7	1.72	---	0	0	< 10
11: DW DW 86667 Ross ACW	14-Feb-23 11:20	9.7	1.27	---	0	0	< 10
12: DW DW Arena	14-Feb-23 11:45	9.7	1.24	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

10-February-2023

Veolia Water (Lucknow)

Attn : Nancy Mayhew

Date Rec. : 07 February 2023
 LR Report: CA20317-FEB23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				08-Feb-23	08-Feb-23	08-Feb-23
2: Analysis Start Time				13:55	13:55	13:20
3: Analysis Completed Date				10-Feb-23	10-Feb-23	10-Feb-23
4: Analysis Completed Time				11:44	11:44	11:44
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	07-Feb-23 10:35	8.7	---	0	0	---
7: TW Lucknow #4 Treated	07-Feb-23 10:30	8.7	1.72	0	0	< 10
8: RW Lucknow #5 Raw	07-Feb-23 10:15	8.7	---	0	0	---
9: TW Lucknow #5 Treated	07-Feb-23 10:10	8.7	1.78	0	0	< 10
10: DW DW LLS	07-Feb-23 09:55	8.7	1.49	0	0	< 10
11: DW DW 86667 Ross St (ACW)	07-Feb-23 09:50	8.7	1.36	0	0	< 10
12: DW DW ARENA	07-Feb-23 09:40	8.7	1.29	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

03-February-2023

Veolia Water (Lucknow)

Attn : Nancy Mayhew

Date Rec. : 31 January 2023
 LR Report: CA20002-FEB23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	01-Feb-23	01-Feb-23	01-Feb-23
2: Analysis Start Time		---	---	10:00	10:00	09:35
3: Analysis Completed Date		---	---	03-Feb-23	03-Feb-23	03-Feb-23
4: Analysis Completed Time		---	---	10:38	10:38	10:38
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	30-Jan-23 16:10	5.8	---	0	0	---
7: TW Lucknow #4 Treated	30-Jan-23 16:05	5.8	1.79	0	0	< 10
8: RW Lucknow #5 Raw	30-Jan-23 15:55	5.8	---	0	0	---
9: TW Lucknow #5 Treated	30-Jan-23 16:00	5.8	1.63	0	0	< 10
10: DW DW LLS	30-Jan-23 15:30	5.8	1.50	0	0	< 10
11: DW DW 86667 Ross (ACW)	30-Jan-23 15:20	5.8	1.48	0	0	< 10
12: DW DW Arena	30-Jan-23 15:10	5.8	1.59	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001

Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

27-January-2023

Veolia Water (Lucknow)

Attn : Nancy Mayhew

Date Rec. : 24 January 2023
 LR Report: CA21082-JAN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	25-Jan-23	25-Jan-23	25-Jan-23
2: Analysis Start Time		---	---	16:10	16:10	15:50
3: Analysis Completed Date		---	---	27-Jan-23	27-Jan-23	27-Jan-23
4: Analysis Completed Time		---	---	15:29	15:29	15:29
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	24-Jan-23 11:15	9.7	---	0	0	---
7: TW Lucknow #4 Treated	24-Jan-23 11:10	9.7	1.84	0	0	< 10
8: RW Lucknow #5 Raw	24-Jan-23 10:55	9.7	---	0	0	---
9: TW Lucknow #5 Treated	24-Jan-23 10:50	9.7	1.64	0	0	< 10
10: DW DW Arena	24-Jan-23 10:00	9.7	1.33	0	0	< 10
11: DW 86667 Ross St (ACW)	24-Jan-23 10:15	9.7	1.42	0	0	< 10
12: DW DW LLS	24-Jan-23 10:35	9.7	1.44	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

20-January-2023

Veolia Water (Lucknow)

Attn : Nancy Mayhew

Date Rec. : 17 January 2023
 LR Report: CA20765-JAN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	18-Jan-23	18-Jan-23	18-Jan-23
2: Analysis Start Time		---	---	---	12:45	12:45	12:10
3: Analysis Completed Date		---	---	---	20-Jan-23	20-Jan-23	20-Jan-23
4: Analysis Completed Time		---	---	---	09:26	09:26	12:40
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	17-Jan-23 11:40	9.0	---	0.23	0	0	---
7: TW Lucknow #4 Treated	17-Jan-23 11:45	9.0	1.71	---	0	0	< 10
8: RW Lucknow #5 Raw	17-Jan-23 11:10	9.0	---	0.17	0	0	---
9: TW Lucknow #5 Treated	17-Jan-23 11:15	9.0	1.61	---	0	0	< 10
10: DW DW Arena	17-Jan-23 10:35	9.0	1.29	---	0	0	30
11: DW DW 86667 Ross ACW	17-Jan-23 10:45	9.0	1.42	---	0	0	10
12: DW DW LLS	17-Jan-23 11:00	9.0	1.41	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

16-January-2023

Veolia Water (Lucknow)

Attn : Nancy Mayhew

Date Rec. : 10 January 2023
LR Report: CA20466-JAN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	11-Jan-23	11-Jan-23	11-Jan-23
2: Analysis Start Time		---	---	12:45	12:45	12:10
3: Analysis Completed Date		---	---	13-Jan-23	13-Jan-23	13-Jan-23
4: Analysis Completed Time		---	---	11:36	11:36	11:36
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	10-Jan-23 11:25	9.6	---	0	0	---
7: TW Lucknow #4 Treated	10-Jan-23 11:20	9.6	1.84	0	0	< 10
8: RW Lucknow #5 Raw	10-Jan-23 11:05	9.6	---	0	0	---
9: TW Lucknow #5 Treated	10-Jan-23 11:10	9.6	1.68	0	0	< 10
10: DW DW ARENA	10-Jan-23 10:20	9.6	1.33	0	0	< 10
11: DW DW 86667 ROSS (ACW)	10-Jan-23 10:35	9.6	1.23	0	0	< 10
12: DW DW LLS	10-Jan-23 10:45	9.6	1.17	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

09-January-2023

Veolia Water (Lucknow)

Attn : Nancy Mayhew

Date Rec. : 03 January 2023
LR Report: CA20102-JAN23

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	04-Jan-23	04-Jan-23	04-Jan-23
2: Analysis Start Time		---	---	15:15	15:15	14:35
3: Analysis Completed Date		---	---	06-Jan-23	06-Jan-23	06-Jan-23
4: Analysis Completed Time		---	---	14:28	14:28	14:28
5: MAC		---	---	0	0	---
6: RW Lucknow #4 Raw	03-Jan-23 09:40	10.8	---	0	0	---
7: TW Lucknow #4 Treated	03-Jan-23 09:35	10.8	1.80	0	0	< 10
8: RW Lucknow #5 Raw	03-Jan-23 09:10	10.8	---	0	0	---
9: TW Lucknow #5 Treated	03-Jan-23 09:15	10.8	1.71	0	0	< 10
10: DW DW Arena	03-Jan-23 07:25	10.8	1.23	0	0	< 10
11: DW DW 86667 Ross St (ACW)	03-Jan-23 08:35	10.8	1.42	0	0	< 10
12: DW DW LLS	03-Jan-23 08:45	10.8	1.47	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

03-January-2023

Veolia Water (Lucknow)

Attn : Nancy Mayhew

Date Rec. : 28 December 2022
LR Report: CA21137-DEC22

100 Cove Rd.
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Field Turbidity NTU	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	29-Dec-22	29-Dec-22	29-Dec-22
2: Analysis Start Time		---	---	---	13:40	13:40	13:05
3: Analysis Completed Date		---	---	---	30-Dec-22	30-Dec-22	03-Jan-23
4: Analysis Completed Time		---	---	---	14:50	14:50	13:20
5: MAC		---	---	---	0	0	---
6: RW Lucknow #4 Raw	28-Dec-22 09:30	10.1	---	0.35	0	0	---
7: TW Lucknow #4 Treated	28-Dec-22 09:35	10.1	1.76	---	0	0	< 10
8: RW Lucknow #5 Raw	28-Dec-22 09:50	10.1	---	0.30	0	0	---
9: TW Lucknow #5 Treated	28-Dec-22 09:55	10.1	1.62	---	0	0	< 10
10: DW DW LLS	28-Dec-22 08:35	10.1	1.37	---	0	0	< 10
11: DW DW Fire Hall	28-Dec-22 08:45	10.1	1.49	---	0	0	< 10
12: DW DW Rec Center	28-Dec-22 09:05	10.1	1.39	---	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety