

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-November-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 25 November 2025
LR Report: CA21220-NOV25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 26-Nov-25 | 26-Nov-25 | 26-Nov-25 |
| 2: Analysis Start Time | | --- | --- | 09:20 | 09:20 | 09:10 |
| 3: Analysis Completed Date | | --- | --- | 28-Nov-25 | 28-Nov-25 | 28-Nov-25 |
| 4: Analysis Completed Time | | --- | --- | 11:05 | 11:05 | 11:05 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 24-Nov-25 15:02 | 6.3 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 24-Nov-25 14:59 | 6.3 | 1.54 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 24-Nov-25 15:37 | 6.3 | --- | 1 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 24-Nov-25 15:42 | 6.3 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 24-Nov-25 15:35 | 6.3 | 1.52 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 24-Nov-25 14:38 | 6.3 | 1.34 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 24-Nov-25 15:06 | 6.3 | 1.47 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

21-November-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 18 November 2025
LR Report: CA20886-NOV25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 19-Nov-25 | 19-Nov-25 | 19-Nov-25 |
| 2: Analysis Start Time | | | | 15:30 | 15:30 | 14:55 |
| 3: Analysis Completed Date | | | | 21-Nov-25 | 21-Nov-25 | 21-Nov-25 |
| 4: Analysis Completed Time | | | | 14:07 | 14:07 | 14:07 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 18-Nov-25 09:24 | 2.9 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 18-Nov-25 09:22 | 2.9 | 1.53 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 18-Nov-25 10:43 | 2.9 | --- | 4 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 18-Nov-25 10:49 | 2.9 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 18-Nov-25 10:41 | 2.9 | 1.56 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 18-Nov-25 09:10 | 2.9 | 1.33 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 18-Nov-25 09:30 | 2.9 | 1.51 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-November-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 12 November 2025
LR Report: CA20594-NOV25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 13-Nov-25 | 13-Nov-25 | 13-Nov-25 |
| 2: Analysis Start Time | | --- | --- | 11:00 | 11:00 | 10:40 |
| 3: Analysis Completed Date | | --- | --- | 17-Nov-25 | 17-Nov-25 | 17-Nov-25 |
| 4: Analysis Completed Time | | --- | --- | 10:25 | 10:25 | 10:25 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 12-Nov-25 10:39 | 4.0 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 12-Nov-25 10:40 | 4.0 | 1.46 | 0 | 0 | 10 |
| 8: RW RW2-Ripley RW-Well 3 | 12-Nov-25 10:54 | 4.0 | --- | 17 | 2 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 12-Nov-25 10:57 | 4.0 | --- | 6 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 12-Nov-25 10:53 | 4.0 | 1.53 | 0 | 0 | 10 |
| 11: DW DW-Ripley SPS | 12-Nov-25 10:21 | 4.0 | 1.30 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 12-Nov-25 10:28 | 4.0 | 1.40 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-November-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 04 November 2025
LR Report: CA20239-NOV25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 05-Nov-25 | 05-Nov-25 | 05-Nov-25 |
| 2: Analysis Start Time | | --- | --- | 15:20 | 15:20 | 13:35 |
| 3: Analysis Completed Date | | --- | --- | 07-Nov-25 | 07-Nov-25 | 07-Nov-25 |
| 4: Analysis Completed Time | | --- | --- | 13:32 | 13:32 | 13:32 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 04-Nov-25 09:14 | 4.6 | 1.32 | 0 | 0 | 10 |
| 7: DW DW-Firehall | 04-Nov-25 09:47 | 4.6 | 1.58 | 0 | 0 | < 10 |
| 8: RW RW1-Ripley RW-Well 2 | 04-Nov-25 09:40 | 4.6 | --- | 0 | 0 | --- |
| 9: TW TW1-Ripley TW-Wellhouse | 04-Nov-25 09:37 | 4.6 | 1.34 | 0 | 0 | < 10 |
| 10: RW RW2-Ripley RW-Well 3 | 04-Nov-25 10:16 | 4.6 | --- | 2 | 0 | --- |
| 11: RW RW3-Ripley RW-Well 4 | 04-Nov-25 10:25 | 4.6 | --- | 2 | 0 | --- |
| 12: TW TW2-Ripley TW-Elevated Tank | 04-Nov-25 10:12 | 4.6 | 1.57 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

03-November-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 28 October 2025

LR Report: CA21468-OCT25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 29-Oct-25 | 29-Oct-25 | 29-Oct-25 |
| 2: Analysis Start Time | | | | 09:30 | 09:30 | 09:15 |
| 3: Analysis Completed Date | | | | 31-Oct-25 | 31-Oct-25 | 31-Oct-25 |
| 4: Analysis Completed Time | | | | 11:56 | 11:56 | 11:56 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 27-Oct-25 12:38 | 5.1 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 27-Oct-25 12:34 | 5.1 | 1.59 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 27-Oct-25 12:51 | 5.1 | --- | NDOGT | NDOGT | --- |
| 9: RW RW3-Ripley RW-Well 4 | 27-Oct-25 12:53 | 5.1 | --- | 35 | 6 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 27-Oct-25 12:50 | 5.1 | 1.43 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 27-Oct-25 12:20 | 5.1 | 1.33 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 27-Oct-25 12:29 | 5.1 | 1.66 | 0 | 0 | 10 |

MAC - Maximum Acceptable Concentration

NDOGT - No Data: Overgrown with Target Bacteria

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Carrie Greenlaw
Project Specialist,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

27-October-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 21 October 2025

LR Report: CA21152-OCT25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 22-Oct-25 | 22-Oct-25 | 22-Oct-25 |
| 2: Analysis Start Time | | | | 16:30 | 16:30 | 16:00 |
| 3: Analysis Completed Date | | | | 24-Oct-25 | 24-Oct-25 | 24-Oct-25 |
| 4: Analysis Completed Time | | | | 13:42 | 13:42 | 13:42 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 21-Oct-25 08:35 | 9.4 | 1.32 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 21-Oct-25 08:55 | 9.4 | 1.50 | 0 | 0 | < 10 |
| 8: RW RW1-Ripley RW-Well 2 | 21-Oct-25 08:50 | 9.4 | --- | 0 | 0 | --- |
| 9: TW TW1-Ripley TW-Wellhouse | 21-Oct-25 08:46 | 9.4 | 1.42 | 0 | 0 | < 10 |
| 10: RW RW2-Ripley RW-Well 3 | 21-Oct-25 09:27 | 9.4 | --- | 0 | 0 | --- |
| 11: RW RW3-Ripley RW-Well 4 | 21-Oct-25 09:34 | 9.4 | --- | 0 | 0 | --- |
| 12: TW TW2-Ripley TW-Elevated Tank | 21-Oct-25 09:29 | 9.4 | --- | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-October-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 14 October 2025
LR Report: CA20678-OCT25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 15-Oct-25 | 15-Oct-25 | 15-Oct-25 |
| 2: Analysis Start Time | | | | 13:45 | 13:45 | 12:50 |
| 3: Analysis Completed Date | | | | 17-Oct-25 | 17-Oct-25 | 17-Oct-25 |
| 4: Analysis Completed Time | | | | 11:43 | 11:43 | 11:43 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 14-Oct-25 09:04 | 8.9 | 1.29 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 14-Oct-25 09:32 | 8.9 | 1.51 | 0 | 0 | < 10 |
| 8: RW RW1-Ripley RW-Well 2 | 14-Oct-25 09:27 | 8.9 | --- | 0 | 0 | --- |
| 9: TW TW1-Ripley TW-Wellhouse | 14-Oct-25 09:24 | 8.9 | 1.52 | 0 | 0 | < 10 |
| 10: RW RW2-Ripley RW-Well 3 | 14-Oct-25 10:04 | 8.9 | --- | 0 | 0 | --- |
| 11: RW RW3-Ripley RW-Well 4 | 14-Oct-25 09:55 | 8.9 | --- | 0 | 0 | --- |
| 12: TW TW2-Ripley TW-Elevated Tank | 14-Oct-25 10:02 | 8.9 | 1.65 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-October-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban
Date Rec. : 07 October 2025

LR Report: CA20397-OCT25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 08-Oct-25 | 08-Oct-25 | 08-Oct-25 |
| 2: Analysis Start Time | | | | 10:55 | 10:55 | 10:20 |
| 3: Analysis Completed Date | | | | 10-Oct-25 | 10-Oct-25 | 10-Oct-25 |
| 4: Analysis Completed Time | | | | 10:37 | 10:37 | 10:37 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 07-Oct-25 10:49 | 8.4 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 07-Oct-25 10:47 | 8.4 | 1.54 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 07-Oct-25 11:25 | 8.4 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 07-Oct-25 11:31 | 8.4 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 07-Oct-25 11:27 | 8.4 | 1.62 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 07-Oct-25 08:35 | 8.4 | 1.50 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 07-Oct-25 10:53 | 8.4 | 1.42 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

06-October-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 01 October 2025
LR Report: CA20052-OCT25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 02-Oct-25 | 02-Oct-25 | 02-Oct-25 |
| 2: Analysis Start Time | | --- | --- | 10:55 | 10:55 | 10:15 |
| 3: Analysis Completed Date | | --- | --- | 06-Oct-25 | 06-Oct-25 | 06-Oct-25 |
| 4: Analysis Completed Time | | --- | --- | 09:50 | 09:50 | 09:50 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 01-Oct-25 10:52 | 13.6 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 01-Oct-25 10:49 | 13.6 | 1.56 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 01-Oct-25 11:10 | 13.6 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 01-Oct-25 11:17 | 13.6 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 01-Oct-25 11:14 | 13.6 | 1.56 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 01-Oct-25 09:35 | 13.6 | 1.22 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 01-Oct-25 12:16 | 13.6 | 1.43 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

26-September-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 23 September 2025
LR Report: CA21390-SEP25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 24-Sep-25 | 24-Sep-25 | 24-Sep-25 |
| 2: Analysis Start Time | | | | 14:30 | 14:30 | 12:45 |
| 3: Analysis Completed Date | | | | 26-Sep-25 | 26-Sep-25 | 26-Sep-25 |
| 4: Analysis Completed Time | | | | 12:20 | 12:20 | 12:20 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 23-Sep-25 08:38 | 13.5 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 23-Sep-25 08:36 | 13.5 | 1.48 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 23-Sep-25 09:28 | 13.5 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 23-Sep-25 09:33 | 13.5 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 23-Sep-25 09:31 | 13.5 | 1.65 | 0 | 0 | 10 |
| 11: DW DW-Ripley SPS | 23-Sep-25 08:17 | 13.5 | 1.33 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 23-Sep-25 08:47 | 13.5 | 1.48 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

22-September-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 16 September 2025
LR Report: CA21014-SEP25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 17-Sep-25 | 17-Sep-25 | 17-Sep-25 |
| 2: Analysis Start Time | | | | 17:15 | 17:15 | 16:35 |
| 3: Analysis Completed Date | | | | 19-Sep-25 | 19-Sep-25 | 19-Sep-25 |
| 4: Analysis Completed Time | | | | 16:01 | 16:01 | 16:01 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 16-Sep-25 08:55 | 5.4 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse 2 | 16-Sep-25 08:52 | 5.4 | 1.46 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 16-Sep-25 09:48 | 5.4 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 16-Sep-25 09:55 | 5.4 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 16-Sep-25 09:52 | 5.4 | 1.53 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 16-Sep-25 08:26 | 5.4 | 1.27 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 16-Sep-25 09:02 | 5.4 | 1.42 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

15-September-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 09 September 2025
LR Report: CA20608-SEP25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 10-Sep-25 | 10-Sep-25 | 10-Sep-25 |
| 2: Analysis Start Time | | | | 16:30 | 16:30 | 16:05 |
| 3: Analysis Completed Date | | | | 12-Sep-25 | 12-Sep-25 | 12-Sep-25 |
| 4: Analysis Completed Time | | | | 15:50 | 15:50 | 15:50 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 09-Sep-25 08:43 | 8.6 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 09-Sep-25 08:41 | 8.6 | 1.31 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 09-Sep-25 09:32 | 8.6 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 09-Sep-25 09:28 | 8.6 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 09-Sep-25 09:27 | 8.6 | 0.75 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 09-Sep-25 08:30 | 8.6 | 1.19 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 09-Sep-25 08:53 | 8.6 | 1.41 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

05-September-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 02 September 2025
LR Report: CA20090-SEP25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 03-Sep-25 | 03-Sep-25 | 03-Sep-25 |
| 2: Analysis Start Time | | | | 14:10 | 14:10 | 13:55 |
| 3: Analysis Completed Date | | | | 05-Sep-25 | 05-Sep-25 | 05-Sep-25 |
| 4: Analysis Completed Time | | | | 13:28 | 13:28 | 13:28 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 02-Sep-25 09:13 | 16.0 | 1.27 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 02-Sep-25 09:22 | 16.0 | 1.26 | 0 | 0 | 20 |
| 8: RW RW1-Ripley RW-Well 2 | 02-Sep-25 09:37 | 16.0 | --- | 0 | 0 | --- |
| 9: TW TW1-Ripley TW-Wellhouse | 02-Sep-25 09:34 | 16.0 | 1.30 | 0 | 0 | < 10 |
| 10: RW RW2-Ripley RW-Well 3 | 02-Sep-25 10:11 | 16.0 | --- | 0 | 0 | --- |
| 11: RW RW3-Ripley RW-Well 4 | 02-Sep-25 10:14 | 16.0 | --- | 0 | 0 | --- |
| 12: TW TW2-Ripley TW-Elevated Tank | 02-Sep-25 10:09 | 16.0 | 1.23 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|----------------|--|---------------------------|
| E.coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| HPC | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

29-August-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 26 August 2025
LR Report: CA21519-AUG25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 27-Aug-25 | 27-Aug-25 | 27-Aug-25 |
| 2: Analysis Start Time | | --- | --- | 13:10 | 13:10 | 12:40 |
| 3: Analysis Completed Date | | --- | --- | 29-Aug-25 | 29-Aug-25 | 29-Aug-25 |
| 4: Analysis Completed Time | | --- | --- | 14:05 | 14:05 | 14:05 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 26-Aug-25 07:56 | 10.4 | 1.20 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 26-Aug-25 08:04 | 10.4 | 1.44 | 0 | 0 | < 10 |
| 8: RW RW1-Ripley RW-Well 2 | 26-Aug-25 08:17 | 10.4 | --- | 0 | 0 | --- |
| 9: TW TW1-Ripley TW-Wellhouse | 26-Aug-25 08:15 | 10.4 | 1.38 | 0 | 0 | < 10 |
| 10: RW RW2-Ripley RW-Well 3 | 26-Aug-25 08:42 | 10.4 | --- | 0 | 0 | --- |
| 11: RW RW3-Ripley RW-Well 4 | 26-Aug-25 08:46 | 10.4 | --- | 0 | 0 | --- |
| 12: TW TW2-Ripley TW-Elevated Tank | 26-Aug-25 08:40 | 10.4 | 1.20 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

22-August-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 19 August 2025
LR Report: CA21120-AUG25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 20-Aug-25 | 20-Aug-25 | 20-Aug-25 |
| 2: Analysis Start Time | | --- | --- | 15:30 | 15:30 | 14:45 |
| 3: Analysis Completed Date | | --- | --- | 22-Aug-25 | 22-Aug-25 | 22-Aug-25 |
| 4: Analysis Completed Time | | --- | --- | 13:20 | 13:20 | 13:20 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 19-Aug-25 08:22 | 6.0 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 19-Aug-25 08:24 | 6.0 | 1.36 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 19-Aug-25 08:56 | 6.0 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 19-Aug-25 09:01 | 6.0 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 19-Aug-25 08:52 | 6.0 | 1.28 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 19-Aug-25 08:00 | 6.0 | 1.34 | 0 | 0 | 10 |
| 12: DW DW-Firehall | 19-Aug-25 08:19 | 6.0 | 1.23 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

18-August-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 12 August 2025
LR Report: CA20721-AUG25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 13-Aug-25 | 13-Aug-25 | 13-Aug-25 |
| 2: Analysis Start Time | | --- | --- | 17:10 | 17:10 | 15:55 |
| 3: Analysis Completed Date | | --- | --- | 15-Aug-25 | 15-Aug-25 | 15-Aug-25 |
| 4: Analysis Completed Time | | --- | --- | 16:11 | 16:11 | 16:11 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 12-Aug-25 09:14 | 5.4 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 12-Aug-25 09:17 | 5.4 | 1.48 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 12-Aug-25 09:55 | 5.4 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 12-Aug-25 10:03 | 5.4 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 12-Aug-25 09:51 | 5.4 | 1.45 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 12-Aug-25 08:50 | 5.4 | 1.48 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 12-Aug-25 08:59 | 5.4 | 1.20 | 0 | 0 | 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

08-August-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 05 August 2025
LR Report: CA20138-AUG25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 06-Aug-25 | 06-Aug-25 | 06-Aug-25 |
| 2: Analysis Start Time | | --- | --- | 12:40 | 12:40 | 12:15 |
| 3: Analysis Completed Date | | --- | --- | 08-Aug-25 | 08-Aug-25 | 08-Aug-25 |
| 4: Analysis Completed Time | | --- | --- | 11:15 | 11:15 | 11:15 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 05-Aug-25 10:31 | 12.3 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 05-Aug-25 10:34 | 12.3 | 1.08 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 05-Aug-25 09:57 | 12.3 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 05-Aug-25 10:04 | 12.3 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 05-Aug-25 09:51 | 12.3 | 2.07 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 05-Aug-25 08:37 | 12.3 | 1.69 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 05-Aug-25 09:09 | 12.3 | 1.66 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

05-August-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 30 July 2025
LR Report: CA21776-JUL25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|-------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 31-Jul-25 | 31-Jul-25 | 31-Jul-25 |
| 2: Analysis Start Time | | --- | --- | 11:15 | 11:15 | 10:30 |
| 3: Analysis Completed Date | | --- | --- | 05-Aug-25 | 05-Aug-25 | 05-Aug-25 |
| 4: Analysis Completed Time | | --- | --- | 08:55 | 08:55 | 08:55 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: TW TW1-Ripley TW-Wellhouse | 30-Jul-25 15:16 | 21.0 | 1.48 | 0 | 0 | < 10 |
| 7: RW RW1-Ripley RW-Well 2 | 30-Jul-25 15:13 | 19.8 | --- | 0 | 0 | --- |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

05-August-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 29 July 2025
LR Report: CA21671-JUL25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCl Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|-----------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 30-Jul-25 | 30-Jul-25 | 30-Jul-25 |
| 2: Analysis Start Time | | | | 17:15 | 17:15 | 15:50 |
| 3: Analysis Completed Date | | | | 01-Aug-25 | 01-Aug-25 | 01-Aug-25 |
| 4: Analysis Completed Time | | | | 15:29 | 15:29 | 15:29 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW2-Ripley RW-Well 3 | 29-Jul-25 10:38 | 16.9 | --- | 0 | 0 | --- |
| 7: RW RW3-Ripley RW-Well 4 | 29-Jul-25 11:08 | 16.9 | --- | 0 | 0 | --- |
| 8: TW TW2-Ripley TW-Elevated Tank | 29-Jul-25 10:56 | 16.9 | 1.89 | 0 | 0 | < 10 |
| 9: DW DW-Ripley SPS | 29-Jul-25 09:36 | 16.9 | 1.71 | 0 | 0 | < 10 |
| 10: DW DW-Firehall | 29-Jul-25 09:54 | 16.9 | 1.23 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

25-July-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 22 July 2025
LR Report: CA21300-JUL25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 23-Jul-25 | 23-Jul-25 | 23-Jul-25 |
| 2: Analysis Start Time | | --- | --- | 14:45 | 14:45 | 13:10 |
| 3: Analysis Completed Date | | --- | --- | 25-Jul-25 | 25-Jul-25 | 25-Jul-25 |
| 4: Analysis Completed Time | | --- | --- | 12:26 | 12:26 | 12:26 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 22-Jul-25 08:49 | 7.7 | --- | NDOGN | NDOGN | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 22-Jul-25 08:45 | 7.7 | 1.58 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 22-Jul-25 09:24 | 7.7 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 22-Jul-25 09:54 | 7.7 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 22-Jul-25 09:40 | 7.7 | 1.93 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 22-Jul-25 08:16 | 7.7 | 1.76 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 22-Jul-25 08:33 | 7.7 | 1.51 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration
NDOGN - No Data: Overgrown with Non Target Bacteria

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

18-July-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 15 July 2025
LR Report: CA20921-JUL25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 16-Jul-25 | 16-Jul-25 | 16-Jul-25 |
| 2: Analysis Start Time | | --- | --- | 13:35 | 13:35 | 13:15 |
| 3: Analysis Completed Date | | --- | --- | 18-Jul-25 | 18-Jul-25 | 18-Jul-25 |
| 4: Analysis Completed Time | | --- | --- | 12:19 | 12:19 | 12:19 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 15-Jul-25 08:48 | 11.8 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 15-Jul-25 08:54 | 11.8 | 1.36 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 15-Jul-25 10:04 | 11.8 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 15-Jul-25 10:06 | 11.8 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 15-Jul-25 10:00 | 11.8 | 1.48 | 0 | 0 | 20 |
| 11: DW DW-Ripley SPS | 15-Jul-25 08:18 | 11.8 | 1.73 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 15-Jul-25 08:34 | 11.8 | 1.41 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-July-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 08 July 2025
LR Report: CA20530-JUL25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|-----------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 09-Jul-25 | 09-Jul-25 | 09-Jul-25 |
| 2: Analysis Start Time | | | | 15:50 | 15:50 | 15:05 |
| 3: Analysis Completed Date | | | | 11-Jul-25 | 11-Jul-25 | 11-Jul-25 |
| 4: Analysis Completed Time | | | | 13:27 | 13:27 | 13:27 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: TW TW1-Ripley TW-Wellhouse | 08-Jul-25 08:29 | 10.5 | 1.33 | 0 | 0 | < 10 |
| 7: RW RW2-Ripley RW-Well 3 | 08-Jul-25 09:27 | 10.5 | --- | 0 | 0 | --- |
| 8: RW RW3-Ripley RW-Well 4 | 08-Jul-25 09:30 | 10.5 | --- | 0 | 0 | --- |
| 9: TW TW2-Ripley TW-Elevated Tank | 08-Jul-25 09:21 | 10.5 | 1.66 | 0 | 0 | < 10 |
| 10: DW DW-Ripley SPS | 08-Jul-25 08:13 | 10.5 | 1.70 | 0 | 0 | < 10 |
| 11: DW DW-Firehall | 08-Jul-25 08:41 | 10.5 | 1.31 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-July-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Date Rec. : 08 July 2025
LR Report: CA20503-JUL25
Reference: Well 2 Inspection

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Total Coliform cfu/100mL | E.Coli cfu/100mL |
|--------------------------------------|--------------------|----------------|--------------------------|------------------|
| 1: Analysis Start Date | | --- | 09-Jul-25 | 09-Jul-25 |
| 2: Analysis Start Time | | --- | 10:10 | 10:10 |
| 3: Analysis Completed Date | | --- | 11-Jul-25 | 11-Jul-25 |
| 4: Analysis Completed Time | | --- | 13:04 | 13:04 |
| 5: MAC | | --- | 0 | 0 |
| 6: RW RW1-Ripley RW-Well 2 Sample #1 | 08-Jul-25 12:58 | 10.5 | 0 | 0 |
| 7: RW RW1-Ripley RW-Well 2 Sample #2 | 08-Jul-25 13:29 | 10.5 | 0 | 0 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|----------------------------------|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-July-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 02 July 2025
LR Report: CA20107-JUL25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 03-Jul-25 | 03-Jul-25 | 03-Jul-25 |
| 2: Analysis Start Time | | | | 16:40 | 16:40 | 16:05 |
| 3: Analysis Completed Date | | | | 07-Jul-25 | 07-Jul-25 | 07-Jul-25 |
| 4: Analysis Completed Time | | | | 11:14 | 11:14 | 11:14 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 02-Jul-25 09:16 | 14.5 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 02-Jul-25 09:12 | 14.5 | 1.48 | 0 | 0 | 10 |
| 8: RW RW2-Ripley RW-Well 3 | 02-Jul-25 10:08 | 14.5 | --- | 2 | 1 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 02-Jul-25 10:13 | 14.5 | --- | 4 | 1 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 02-Jul-25 10:03 | 14.5 | 1.53 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 02-Jul-25 08:30 | 14.5 | 1.67 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 02-Jul-25 08:47 | 14.5 | 1.46 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Units | Description | SGS Method Code |
|-----------|--|---------------------------|
| cfu/100mL | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| cfu/1mL | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| cfu/100mL | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

30-June-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 24 June 2025
LR Report: CA21561-JUN25

6242 Fallon Dr., Lucan
Canada, N0M 2J)
Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy), Fax:

Copy: #1

CERTIFICATE OF ANALYSIS


Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 25-Jun-25 | 25-Jun-25 | 25-Jun-25 |
| 2: Analysis Start Time | | | | 13:45 | 13:45 | 13:10 |
| 3: Analysis Completed Date | | | | 27-Jun-25 | 27-Jun-25 | 27-Jun-25 |
| 4: Analysis Completed Time | | | | 13:54 | 13:54 | 13:54 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 24-Jun-25 08:39 | 14.9 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 24-Jun-25 08:36 | 14.9 | 1.56 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 24-Jun-25 09:23 | 14.9 | --- | 2 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 24-Jun-25 09:27 | 14.9 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 24-Jun-25 09:21 | 14.9 | 1.55 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 24-Jun-25 08:06 | 14.9 | 1.93 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 24-Jun-25 08:18 | 14.9 | 1.53 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|----------------|--|---------------------------|
| E.coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| HPC | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

23-June-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 17 June 2025
LR Report: CA21151-JUN25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 18-Jun-25 | 18-Jun-25 | 18-Jun-25 |
| 2: Analysis Start Time | | | | 16:50 | 16:50 | 16:20 |
| 3: Analysis Completed Date | | | | 20-Jun-25 | 20-Jun-25 | 20-Jun-25 |
| 4: Analysis Completed Time | | | | 17:55 | 17:55 | 17:55 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 17-Jun-25 09:33 | 10.8 | 1.45 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 17-Jun-25 09:50 | 10.8 | 1.53 | 0 | 0 | < 10 |
| 8: RW RW1-Ripley RW-Well 2 | 17-Jun-25 10:12 | 10.8 | --- | 0 | 0 | --- |
| 9: TW TW1-Ripley TW-Wellhouse | 17-Jun-25 10:06 | 10.8 | 1.62 | 0 | 0 | < 10 |
| 10: RW RW2-Ripley RW-Well 3 | 17-Jun-25 11:09 | 10.8 | --- | 0 | 0 | --- |
| 11: RW RW3-Ripley RW-Well 4 | 17-Jun-25 11:14 | 10.8 | --- | 0 | 0 | --- |
| 12: TW TW2-Ripley TW-Elevated Tank | 17-Jun-25 11:03 | 10.8 | 1.52 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|----------------|--|---------------------------|
| E.coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| HPC | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

13-June-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 10 June 2025
LR Report: CA20732-JUN25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 11-Jun-25 | 11-Jun-25 | 11-Jun-25 |
| 2: Analysis Start Time | | --- | --- | 13:40 | 13:40 | 13:10 |
| 3: Analysis Completed Date | | --- | --- | 13-Jun-25 | 13-Jun-25 | 13-Jun-25 |
| 4: Analysis Completed Time | | --- | --- | 12:06 | 12:06 | 12:06 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 10-Jun-25 11:27 | 12.4 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 10-Jun-25 11:23 | 12.4 | 1.53 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 10-Jun-25 11:53 | 12.4 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 10-Jun-25 12:02 | 12.4 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 10-Jun-25 11:58 | 12.4 | 1.96 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 10-Jun-25 11:09 | 12.4 | 1.33 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 10-Jun-25 11:17 | 12.4 | 1.34 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

09-June-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 03 June 2025
LR Report: CA20267-JUN25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 04-Jun-25 | 04-Jun-25 | 04-Jun-25 |
| 2: Analysis Start Time | | | | 15:50 | 15:50 | 15:25 |
| 3: Analysis Completed Date | | | | 06-Jun-25 | 06-Jun-25 | 06-Jun-25 |
| 4: Analysis Completed Time | | | | 14:20 | 14:20 | 14:20 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 03-Jun-25 08:48 | 11.0 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 03-Jun-25 08:42 | 11.0 | 1.43 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 03-Jun-25 09:37 | 11.0 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 03-Jun-25 09:43 | 11.0 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 03-Jun-25 09:16 | 11.0 | 1.39 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 03-Jun-25 08:01 | 11.0 | 1.36 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 03-Jun-25 08:16 | 11.0 | 1.34 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

30-May-2025
OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban
Date Rec. : 27 May 2025

LR Report: CA21540-MAY25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 28-May-25 | 28-May-25 | 28-May-25 |
| 2: Analysis Start Time | | | | 13:05 | 13:05 | 12:20 |
| 3: Analysis Completed Date | | | | 30-May-25 | 30-May-25 | 30-May-25 |
| 4: Analysis Completed Time | | | | 14:26 | 14:26 | 14:26 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 27-May-25 10:34 | 8.6 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 27-May-25 10:31 | 8.6 | 1.47 | 0 | 0 | 10 |
| 8: RW RW2-Ripley RW-Well 3 | 27-May-25 10:57 | 8.6 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 27-May-25 11:07 | 8.6 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 27-May-25 10:52 | 8.6 | 1.45 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 27-May-25 10:20 | 8.6 | 1.42 | 0 | 0 | 10 |
| 12: DW DW-Firehall | 27-May-25 10:28 | 8.6 | 1.43 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

26-May-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 20 May 2025

LR Report: CA21045-MAY25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 21-May-25 | 21-May-25 | 21-May-25 |
| 2: Analysis Start Time | | | | 13:30 | 13:30 | 13:05 |
| 3: Analysis Completed Date | | | | 23-May-25 | 23-May-25 | 23-May-25 |
| 4: Analysis Completed Time | | | | 16:09 | 16:09 | 16:09 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 20-May-25 10:59 | 12.7 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 20-May-25 10:55 | 12.7 | 1.52 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 20-May-25 11:33 | 12.7 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 20-May-25 11:36 | 12.7 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 20-May-25 11:30 | 12.7 | 1.47 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 20-May-25 10:38 | 12.7 | 1.42 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 20-May-25 10:50 | 12.7 | 1.40 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

20-May-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 13 May 2025

LR Report: CA20779-MAY25

6242 Fallon Dr.
 Lucan, ON
 N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 14-May-25 | 14-May-25 | 14-May-25 |
| 2: Analysis Start Time | | --- | --- | 16:10 | 16:10 | 15:50 |
| 3: Analysis Completed Date | | --- | --- | 16-May-25 | 16-May-25 | 16-May-25 |
| 4: Analysis Completed Time | | --- | --- | 15:53 | 15:53 | 15:53 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 13-May-25 10:46 | 11.9 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 13-May-25 10:44 | 11.9 | 1.50 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 13-May-25 11:14 | 11.9 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 13-May-25 11:17 | 11.9 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 13-May-25 11:08 | 11.9 | 1.48 | 0 | 0 | 1270 |
| 11: DW DW-Ripley SPS | 13-May-25 10:30 | 11.9 | 1.40 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 13-May-25 10:39 | 11.9 | 1.40 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

09-May-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 06 May 2025

LR Report: CA20326-MAY25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 07-May-25 | 07-May-25 | 07-May-25 |
| 2: Analysis Start Time | | | | 15:45 | 15:45 | 15:20 |
| 3: Analysis Completed Date | | | | 09-May-25 | 09-May-25 | 09-May-25 |
| 4: Analysis Completed Time | | | | 14:16 | 14:16 | 14:16 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 06-May-25 11:43 | 10.8 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 06-May-25 11:40 | 10.8 | 1.41 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 06-May-25 12:14 | 10.8 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 06-May-25 12:21 | 10.8 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 06-May-25 12:11 | 10.8 | 1.47 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 06-May-25 11:14 | 10.8 | 1.34 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 06-May-25 11:33 | 10.8 | 1.36 | 0 | 0 | 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

02-May-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 29 April 2025
LR Report: CA21638-APR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 30-Apr-25 | 30-Apr-25 | 30-Apr-25 |
| 2: Analysis Start Time | | | | 17:15 | 17:15 | 15:35 |
| 3: Analysis Completed Date | | | | 02-May-25 | 02-May-25 | 02-May-25 |
| 4: Analysis Completed Time | | | | 13:45 | 13:45 | 13:45 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 29-Apr-25 09:56 | 9.7 | 1.41 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 29-Apr-25 10:04 | 9.7 | 1.34 | 0 | 0 | < 10 |
| 8: RW RW1-Ripley RW-Well 2 | 29-Apr-25 10:11 | 9.7 | --- | 0 | 0 | --- |
| 9: TW TW1-Ripley TW-Wellhouse | 29-Apr-25 10:13 | 9.7 | 1.53 | 0 | 0 | < 10 |
| 10: RW RW2-Ripley RW-Well 3 | 29-Apr-25 10:40 | 9.7 | --- | 0 | 0 | --- |
| 11: RW RW3-Ripley RW-Well 4 | 29-Apr-25 10:44 | 9.7 | --- | 0 | 0 | --- |
| 12: TW TW2-Ripley TW-Elevated Tank | 29-Apr-25 10:38 | 9.7 | 1.45 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

25-April-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 22 April 2025
LR Report: CA21165-APR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 23-Apr-25 | 23-Apr-25 | 23-Apr-25 |
| 2: Analysis Start Time | | | | 10:30 | 10:30 | 10:05 |
| 3: Analysis Completed Date | | | | 25-Apr-25 | 25-Apr-25 | 25-Apr-25 |
| 4: Analysis Completed Time | | | | 10:47 | 10:47 | 10:47 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 22-Apr-25 08:26 | 12.3 | 1.42 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 22-Apr-25 08:43 | 12.3 | 1.54 | 0 | 0 | < 10 |
| 8: RW RW1-Ripley RW-Well 2 | 22-Apr-25 09:02 | 12.3 | --- | 0 | 0 | --- |
| 9: TW TW1-Ripley TW-Wellhouse | 22-Apr-25 08:53 | 12.3 | 1.59 | 0 | 0 | < 10 |
| 10: RW RW2-Ripley RW-Well 3 | 22-Apr-25 10:23 | 12.3 | --- | 0 | 0 | --- |
| 11: RW RW3-Ripley RW-Well 4 | 22-Apr-25 10:18 | 12.3 | --- | 0 | 0 | --- |
| 12: TW TW2-Ripley TW-Elevated Tank | 22-Apr-25 10:09 | 12.3 | 1.67 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-April-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 14 April 2025
LR Report: CA20688-APR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 14-Apr-25 | 14-Apr-25 | 14-Apr-25 |
| 2: Analysis Start Time | | | | 16:40 | 16:40 | 16:10 |
| 3: Analysis Completed Date | | | | 16-Apr-25 | 16-Apr-25 | 16-Apr-25 |
| 4: Analysis Completed Time | | | | 17:53 | 17:53 | 17:53 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 14-Apr-25 10:01 | 15.1 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 14-Apr-25 09:56 | 15.1 | 1.38 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 14-Apr-25 10:19 | 15.1 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 14-Apr-25 10:36 | 15.1 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 14-Apr-25 10:29 | 15.1 | 2.10 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 14-Apr-25 08:39 | 15.1 | 1.44 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 14-Apr-25 09:42 | 15.1 | 1.26 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-April-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 08 April 2025

LR Report: CA20536-APR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)

Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 09-Apr-25 | 09-Apr-25 | 09-Apr-25 |
| 2: Analysis Start Time | | | | 18:20 | 18:20 | 17:55 |
| 3: Analysis Completed Date | | | | 11-Apr-25 | 11-Apr-25 | 11-Apr-25 |
| 4: Analysis Completed Time | | | | 15:08 | 15:08 | 15:08 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 08-Apr-25 09:17 | 5.1 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 08-Apr-25 09:12 | 5.1 | 1.60 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 08-Apr-25 10:33 | 5.1 | --- | 1 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 08-Apr-25 10:36 | 5.1 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 08-Apr-25 10:30 | 5.1 | 1.68 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 08-Apr-25 08:34 | 5.1 | 1.57 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 08-Apr-25 08:54 | 5.1 | 1.26 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

04-April-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 01 April 2025
LR Report: CA20134-APR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 02-Apr-25 | 02-Apr-25 | 02-Apr-25 |
| 2: Analysis Start Time | | --- | --- | 10:45 | 10:45 | 10:10 |
| 3: Analysis Completed Date | | --- | --- | 04-Apr-25 | 04-Apr-25 | 04-Apr-25 |
| 4: Analysis Completed Time | | --- | --- | 10:51 | 10:51 | 10:51 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 01-Apr-25 08:37 | 6.9 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 01-Apr-25 08:35 | 6.9 | 1.66 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 01-Apr-25 09:23 | 6.9 | --- | 1 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 01-Apr-25 09:28 | 6.9 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 01-Apr-25 09:16 | 6.9 | 1.73 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 01-Apr-25 08:09 | 6.9 | 1.60 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 01-Apr-25 08:19 | 6.9 | 1.41 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

31-March-2025
OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 25 March 2025
LR Report: CA21189-MAR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 26-Mar-25 | 26-Mar-25 | 26-Mar-25 |
| 2: Analysis Start Time | | | | 16:55 | 16:55 | 16:25 |
| 3: Analysis Completed Date | | | | 28-Mar-25 | 28-Mar-25 | 28-Mar-25 |
| 4: Analysis Completed Time | | | | 18:13 | 18:13 | 18:13 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 25-Mar-25 08:26 | 8.1 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 25-Mar-25 08:23 | 8.1 | 1.63 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 25-Mar-25 08:54 | 8.1 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 25-Mar-25 08:56 | 8.1 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 25-Mar-25 08:51 | 8.1 | 1.64 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 25-Mar-25 08:02 | 8.1 | 1.67 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 25-Mar-25 08:14 | 8.1 | 1.43 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

21-March-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 18 March 2025
LR Report: CA20884-MAR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 19-Mar-25 | 19-Mar-25 | 19-Mar-25 |
| 2: Analysis Start Time | | | | 15:55 | 15:55 | 15:15 |
| 3: Analysis Completed Date | | | | 21-Mar-25 | 21-Mar-25 | 21-Mar-25 |
| 4: Analysis Completed Time | | | | 14:16 | 14:16 | 14:16 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 18-Mar-25 08:28 | 11.9 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 18-Mar-25 08:25 | 11.9 | 1.81 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 18-Mar-25 09:08 | 11.9 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 18-Mar-25 09:13 | 11.9 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 18-Mar-25 09:05 | 11.9 | 1.64 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 18-Mar-25 08:05 | 11.9 | 1.41 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 18-Mar-25 08:17 | 11.9 | 1.53 | 0 | 0 | 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|----------------|--|---------------------------|
| E.coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| HPC | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |



Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

14-March-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 11 March 2025
LR Report: CA20509-MAR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 12-Mar-25 | 12-Mar-25 | 12-Mar-25 |
| 2: Analysis Start Time | | | | 13:55 | 13:55 | 13:30 |
| 3: Analysis Completed Date | | | | 14-Mar-25 | 14-Mar-25 | 14-Mar-25 |
| 4: Analysis Completed Time | | | | 12:52 | 12:52 | 12:52 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 11-Mar-25 08:34 | 8.3 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse 2 | 11-Mar-25 08:29 | 8.3 | 1.68 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 11-Mar-25 09:13 | 8.3 | --- | 2 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 11-Mar-25 09:17 | 8.3 | --- | 6 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 11-Mar-25 09:08 | 8.3 | 1.74 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 11-Mar-25 08:06 | 8.3 | 1.51 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 11-Mar-25 08:18 | 8.3 | 1.49 | 0 | 0 | 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-March-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 04 March 2025
LR Report: CA20179-MAR25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 05-Mar-25 | 05-Mar-25 | 05-Mar-25 |
| 2: Analysis Start Time | | | | 15:45 | 15:45 | 15:00 |
| 3: Analysis Completed Date | | | | 07-Mar-25 | 07-Mar-25 | 07-Mar-25 |
| 4: Analysis Completed Time | | | | 14:20 | 14:20 | 14:20 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 04-Mar-25 10:23 | 8.6 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 04-Mar-25 10:17 | 8.6 | 1.86 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 04-Mar-25 11:06 | 8.6 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 04-Mar-25 11:10 | 8.6 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 04-Mar-25 11:00 | 8.6 | 1.81 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 04-Mar-25 09:40 | 8.6 | 1.71 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 04-Mar-25 10:09 | 8.6 | 1.73 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21181-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 26-Feb-25 | 26-Feb-25 | 26-Feb-25 |
| 2: Analysis Start Time | | --- | --- | 12:50 | 12:50 | 12:25 |
| 3: Analysis Completed Date | | --- | --- | 28-Feb-25 | 28-Feb-25 | 28-Feb-25 |
| 4: Analysis Completed Time | | --- | --- | 10:58 | 10:58 | 10:58 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 25-Feb-25 09:03 | 7.8 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 25-Feb-25 08:51 | 7.8 | 1.88 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 25-Feb-25 09:37 | 7.8 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 25-Feb-25 09:42 | 7.8 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 25-Feb-25 09:31 | 7.8 | 1.86 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

28-February-2025

OCWA-Huron Kinloss (Ripley DWS)
Attn : Paul Sherban

Date Rec. : 25 February 2025
LR Report: CA21182-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|----------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 26-Feb-25 | 26-Feb-25 | 26-Feb-25 |
| 2: Analysis Start Time | | --- | --- | 15:10 | 15:10 | 14:20 |
| 3: Analysis Completed Date | | --- | --- | 28-Feb-25 | 28-Feb-25 | 28-Feb-25 |
| 4: Analysis Completed Time | | --- | --- | 13:05 | 13:05 | 13:05 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 25-Feb-25 08:23 | 7.8 | 1.75 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 25-Feb-25 08:41 | 7.8 | 1.61 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
 Project Specialist-London,
 Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 19 February 2025
LR Report: CA21028-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 20-Feb-25 | 20-Feb-25 | 20-Feb-25 |
| 2: Analysis Start Time | | --- | --- | 12:55 | 12:55 | 12:25 |
| 3: Analysis Completed Date | | --- | --- | 24-Feb-25 | 24-Feb-25 | 24-Feb-25 |
| 4: Analysis Completed Time | | --- | --- | 10:15 | 10:15 | 10:15 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 19-Feb-25 11:43 | 10.8 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 19-Feb-25 11:36 | 10.8 | 1.87 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 19-Feb-25 12:31 | 10.8 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 19-Feb-25 12:25 | 10.8 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 19-Feb-25 12:24 | 10.8 | 2.10 | 0 | 0 | 130 |
| 11: DW DW-Ripley SPS | 19-Feb-25 11:15 | 10.8 | 1.81 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 19-Feb-25 11:28 | 10.8 | 1.85 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

18-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
LR Report: CA20758-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|----------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 12-Feb-25 | 12-Feb-25 | 12-Feb-25 |
| 2: Analysis Start Time | | | | 17:10 | 17:10 | 16:45 |
| 3: Analysis Completed Date | | | | 14-Feb-25 | 14-Feb-25 | 14-Feb-25 |
| 4: Analysis Completed Time | | | | 16:19 | 16:19 | 16:19 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 11-Feb-25 08:29 | 5.6 | 1.50 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 11-Feb-25 08:43 | 5.6 | 1.79 | 0 | 0 | < 10 |
| 8: DW DW-Arena | 11-Feb-25 09:21 | 5.6 | 1.79 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

18-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 11 February 2025
LR Report: CA20759-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 12-Feb-25 | 12-Feb-25 | 12-Feb-25 |
| 2: Analysis Start Time | | | | 17:10 | 17:10 | 16:45 |
| 3: Analysis Completed Date | | | | 14-Feb-25 | 14-Feb-25 | 14-Feb-25 |
| 4: Analysis Completed Time | | | | 16:19 | 16:19 | 16:19 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 11-Feb-25 09:04 | 5.6 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 11-Feb-25 08:56 | 5.6 | 1.90 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 11-Feb-25 09:32 | 5.6 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 11-Feb-25 09:40 | 5.6 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 11-Feb-25 09:42 | 5.6 | 2.10 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Cristal Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20199-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|----------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 05-Feb-25 | 05-Feb-25 | 05-Feb-25 |
| 2: Analysis Start Time | | | | 14:00 | 14:00 | 13:20 |
| 3: Analysis Completed Date | | | | 07-Feb-25 | 07-Feb-25 | 07-Feb-25 |
| 4: Analysis Completed Time | | | | 14:25 | 14:25 | 14:25 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 04-Feb-25 09:46 | 8.0 | 1.49 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 04-Feb-25 09:01 | 8.0 | 1.68 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|----------------|--|---------------------------|
| E.coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| HPC | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |

Angela Stott, B.Sc.
Branch Manager-London
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

07-February-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 04 February 2025
LR Report: CA20200-FEB25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS


Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 05-Feb-25 | 05-Feb-25 | 05-Feb-25 |
| 2: Analysis Start Time | | | | 14:00 | 14:00 | 13:20 |
| 3: Analysis Completed Date | | | | 07-Feb-25 | 07-Feb-25 | 07-Feb-25 |
| 4: Analysis Completed Time | | | | 14:25 | 14:25 | 14:25 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 04-Feb-25 09:19 | 8.0 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 04-Feb-25 09:15 | 8.0 | 1.38 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 04-Feb-25 10:23 | 8.0 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 04-Feb-25 10:15 | 8.0 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 04-Feb-25 10:04 | 8.0 | 1.80 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|----------------|--|---------------------------|
| E.coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| HPC | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


 Angela Stott, B.Sc.
 Branch Manager-London
 Environment, Health & Safety

SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

31-January-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 28 January 2025
LR Report: CA21225-JAN25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 29-Jan-25 | 29-Jan-25 | 29-Jan-25 |
| 2: Analysis Start Time | | | | 16:00 | 16:00 | 15:35 |
| 3: Analysis Completed Date | | | | 31-Jan-25 | 31-Jan-25 | 31-Jan-25 |
| 4: Analysis Completed Time | | | | 13:07 | 13:07 | 13:07 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 28-Jan-25 10:38 | 6.8 | 1.73 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 28-Jan-25 11:02 | 6.8 | 1.25 | 0 | 0 | 10 |
| 8: RW RW1-Ripley RW-Well 2 | 28-Jan-25 11:30 | 6.8 | --- | 0 | 0 | --- |
| 9: TW TW1-Ripley TW-Wellhouse | 28-Jan-25 11:09 | 6.8 | 1.76 | 0 | 0 | < 10 |
| 10: RW RW2-Ripley RW-Well 3 | 28-Jan-25 12:12 | 6.8 | --- | 1 | 0 | --- |
| 11: RW RW3-Ripley RW-Well 4 | 28-Jan-25 12:03 | 6.8 | --- | 1 | 0 | --- |
| 12: TW TW2-Ripley TW-Elevated Tank | 28-Jan-25 11:58 | 6.8 | 1.76 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

24-January-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 21 January 2025
LR Report: CA20940-JAN25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 22-Jan-25 | 22-Jan-25 | 22-Jan-25 |
| 2: Analysis Start Time | | | | 16:20 | 16:20 | 15:45 |
| 3: Analysis Completed Date | | | | 24-Jan-25 | 24-Jan-25 | 24-Jan-25 |
| 4: Analysis Completed Time | | | | 14:17 | 14:17 | 14:17 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: DW DW-Ripley SPS | 21-Jan-25 09:30 | 4.9 | 1.77 | 0 | 0 | < 10 |
| 7: DW DW-Firehall | 21-Jan-25 09:50 | 4.9 | 1.59 | 0 | 0 | < 10 |
| 8: RW RW1-Ripley RW-Well 2 | 21-Jan-25 09:40 | 4.9 | --- | 0 | 0 | --- |
| 9: TW TW1-Ripley TW-Wellhouse | 21-Jan-25 09:42 | 4.9 | 1.68 | 0 | 0 | < 10 |
| 10: RW RW2-Ripley RW-Well 3 | 21-Jan-25 10:29 | 4.9 | --- | 1 | 0 | --- |
| 11: RW RW3-Ripley RW-Well 4 | 21-Jan-25 10:25 | 4.9 | --- | 0 | 0 | --- |
| 12: TW TW2-Ripley TW-Elevated Tank | 21-Jan-25 10:24 | 4.9 | 2.07 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

17-January-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 14 January 2025
LR Report: CA20581-JAN25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | | | 15-Jan-25 | 15-Jan-25 | 15-Jan-25 |
| 2: Analysis Start Time | | | | 15:00 | 15:00 | 14:35 |
| 3: Analysis Completed Date | | | | 17-Jan-25 | 17-Jan-25 | 17-Jan-25 |
| 4: Analysis Completed Time | | | | 12:42 | 12:42 | 12:42 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 14-Jan-25 08:53 | 6.0 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse | 14-Jan-25 08:54 | 6.0 | 1.61 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 14-Jan-25 09:29 | 6.0 | --- | 1 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 14-Jan-25 09:32 | 6.0 | --- | 0 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 14-Jan-25 09:33 | 6.0 | 1.95 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 14-Jan-25 09:12 | 6.0 | 1.82 | 0 | 0 | < 10 |
| 12: DW DW-Firehall | 14-Jan-25 08:44 | 6.0 | 1.83 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety



Works #: 220002636

SGS Canada Inc.

657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

13-January-2025

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 08 January 2025
LR Report: CA20305-JAN25

6242 Fallon Dr.
Lucan, ON
N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
Fax:

CERTIFICATE OF ANALYSIS

Final Report

| Sample ID | Sample Date & Time | Temperature °C | Field ResCI Free mg/L | Total Coliform cfu/100mL | E.Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|------------------------------------|--------------------|----------------|-----------------------|--------------------------|------------------|---|
| 1: Analysis Start Date | | --- | --- | 08-Jan-25 | 08-Jan-25 | 08-Jan-25 |
| 2: Analysis Start Time | | --- | --- | 18:50 | 18:50 | 18:20 |
| 3: Analysis Completed Date | | --- | --- | 10-Jan-25 | 10-Jan-25 | 10-Jan-25 |
| 4: Analysis Completed Time | | --- | --- | 17:41 | 17:41 | 17:41 |
| 5: MAC | | --- | --- | 0 | 0 | --- |
| 6: RW RW1-Ripley RW-Well 2 | 07-Jan-25 08:51 | 3.4 | --- | 0 | 0 | --- |
| 7: TW TW1-Ripley TW-Wellhouse 2 | 07-Jan-25 08:51 | 3.4 | 1.77 | 0 | 0 | < 10 |
| 8: RW RW2-Ripley RW-Well 3 | 07-Jan-25 10:05 | 3.4 | --- | 0 | 0 | --- |
| 9: RW RW3-Ripley RW-Well 4 | 07-Jan-25 10:05 | 3.4 | --- | 3 | 0 | --- |
| 10: TW TW2-Ripley TW-Elevated Tank | 07-Jan-25 09:48 | 3.4 | 1.82 | 0 | 0 | < 10 |
| 11: DW DW-Ripley SPS | 07-Jan-25 08:20 | 3.4 | 1.74 | 0 | 0 | 10 |
| 12: DW DW-Firehall | 07-Jan-25 09:01 | 3.4 | 1.23 | 0 | 0 | < 10 |
| 13: DW DW-Arena | 07-Jan-25 10:17 | 3.4 | 1.54 | 0 | 0 | < 10 |

MAC - Maximum Acceptable Concentration

Method Descriptions

| Parameter | Description | SGS Method Code |
|---------------------------------|--|---------------------------|
| E.Coli | E.Coli by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |
| Heterotrophic Plate Count (HPC) | Heterotrophic Plate Count (HPC) by SP (using SPCA) | ME-CA-[ENV]MIC-LAK-AN-002 |
| Total Coliform | Total Coliform by MF (using DCM) | ME-CA-[ENV]MIC-LAK-AN-001 |


Crista Schuster
Project Specialist-London,
Environment, Health & Safety