



Works #: 220000425

SGS Canada Inc.

657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

03-July-2026

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 29 June 2026
 LR Report: CA21803-JUN26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCI Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				30-Jun-26	30-Jun-26	30-Jun-26
2: Analysis Start Time				14:35	14:35	14:15
3: Analysis Completed Date				02-Jul-26	02-Jul-26	02-Jul-26
4: Analysis Completed Time				14:30	14:30	14:30
5: MAC		---	---	0	0	---
6: RW RW3-Point Clark RW-Well 2	29-Jun-26 08:22	13.9	---	0	0	---
7: RW RW4-Point Clark RW-Well 3	29-Jun-26 08:26	13.9	---	0	0	---
8: TW TW3-Point Clark TW	29-Jun-26 08:20	13.9	1.96	0	0	< 10
9: DW DW-Point Clark Community Centre	29-Jun-26 08:56	13.9	1.61	0	0	10
10: RW RW2-Huronville South RW-Well 1	29-Jun-26 10:30	13.9	---	0	0	---
11: TW TW2-Huronville South TW	29-Jun-26 10:25	13.9	1.73	0	0	< 10
12: DW DW-Inverlyn Club House	29-Jun-26 10:08	13.9	1.56	0	0	10
13: RW RW1-Blairs Grove RW-Well 3	29-Jun-26 09:13	13.9	---	0	0	---
14: TW TW1-Blairs Grove TW	29-Jun-26 09:11	13.9	1.94	0	0	< 10
15: DW DW-Chem Shed	29-Jun-26 09:27	13.9	1.87	0	0	< 10
16: DW DW-Amberley Beach SS (ACW)	29-Jun-26 08:41	13.9	1.65	0	0	< 10
17: RW RW5-Murdoch Glen RW-Well 2	29-Jun-26 09:48	13.9	---	0	0	---
18: TW TW4-Murdoch Glen TW	29-Jun-26 09:51	13.9	1.78	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Crista Schuster
 Project Specialist-London,



SGS Canada Inc.

657 Consortium Court

London - Ontario - N6E 2S8

Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21803-JUN26

Environment, Health & Safety