

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

01-May-2026

OCWA-Huron Kinloss (Lucknow DWS)

Attn : Paul Sherban

Date Rec. : 28 April 2026
 LR Report: CA21475-APR26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	29-Apr-26	29-Apr-26	29-Apr-26
2: Analysis Start Time		---	---	10:05	10:05	09:35
3: Analysis Completed Date		---	---	01-May-26	01-May-26	01-May-26
4: Analysis Completed Time		---	---	11:44	11:44	11:44
5: MAC		---	---	0	0	---
6: RW RW1-Lucknow RW-Well 4	27-Apr-26 14:11	6.6	---	0	0	---
7: TW TW1-Lucknow TW-Well 4	27-Apr-26 14:10	6.6	1.79	0	0	< 10
8: RW RW2-Lucknow RW-Well 5	27-Apr-26 14:04	6.6	---	0	0	---
9: TW TW2-Lucknow TW-Well 5	27-Apr-26 14:02	6.6	1.60	0	0	< 10
10: DW DW-86667 County Road 1 South (ACW)	27-Apr-26 14:22	6.6	1.53	0	0	< 10
11: DW DW-Lucknow Tower	27-Apr-26 14:16	6.6	1.46	0	0	< 10
12: DW DW-Lucknow SPS	27-Apr-26 14:27	6.6	1.36	0	0	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

01-May-2026

OCWA-Huron Kinloss (Lakeshore DWS)

Attn : Paul Sherban

Date Rec. : 28 April 2026
 LR Report: CA21476-APR26

6242 Fallon Drive
 Lucan, ON
 N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	29-Apr-26	29-Apr-26	29-Apr-26
2: Analysis Start Time		---	---	10:05	10:05	09:35
3: Analysis Completed Date		---	---	01-May-26	01-May-26	01-May-26
4: Analysis Completed Time		---	---	11:45	11:45	11:45
5: MAC		---	---	0	0	---
6: RW RW1-Blairs Grove RW- Well 3	27-Apr-26 13:50	6.6	---	0	0	---
7: TW TW1-Blairs Grove TW	27-Apr-26 13:48	6.6	1.41	0	0	< 10
8: DW DW-Chem Shed	27-Apr-26 13:59	6.6	1.64	0	0	< 10
9: DW DW-Amberley Beach SS (ACW)	27-Apr-26 12:31	6.6	1.61	0	0	10
10: RW RW2-Huronville South RW-Well 1	27-Apr-26 14:38	6.6	---	0	0	---
11: TW TW2-Huronville South TW	27-Apr-26 14:42	6.6	1.67	0	0	< 10
12: DW DW-Inverlyn Club House	27-Apr-26 14:59	6.6	1.66	0	0	< 10
13: RW RW3-Point Clark RW-Well 2	27-Apr-26 12:44	6.6	---	0	0	---
14: RW RW4-Point Clark RW-Well 3	27-Apr-26 12:59	6.6	---	0	0	---
15: TW TW3-Point Clark TW	27-Apr-26 13:02	6.6	1.72	0	0	< 10
16: DW DW-Point Clark Community Centre	27-Apr-26 13:24	6.6	1.52	0	0	10
17: RW RW5-Murdoch Glen RW-Well 2	27-Apr-26 14:18	6.6	---	0	0	---
18: TW TW4-Murdoch Glen TW	27-Apr-26 14:22	6.6	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,



SGS Canada Inc.
657 Consortium Court
London - Ontario - N6E 2S8
Phone: 519-672-4500 FAX: 519-672-0361

Works #: 220000425

LR Report : CA21476-APR26

Environment, Health & Safety