

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

01-May-2026

OCWA-Huron Kinloss (Ripley DWS)

Attn : Paul Sherban

Date Rec. : 28 April 2026
 LR Report: CA21474-APR26

6242 Fallon Dr.
 Lucan, ON
 N0M 2J), Canada

Copy: #1

Phone: 226-374-9901(Paul)/226-2377-3563 (Cindy)
 Fax:

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	29-Apr-26	29-Apr-26	29-Apr-26
2: Analysis Start Time		---	---	09:45	09:45	09:25
3: Analysis Completed Date		---	---	01-May-26	01-May-26	01-May-26
4: Analysis Completed Time		---	---	11:42	11:42	11:42
5: MAC		---	---	0	0	---
6: RW RW1-Ripley RW-Well 2	27-Apr-26 12:28	6.6	---	0	0	---
7: TW TW1-Ripley TW-Wellhouse	27-Apr-26 12:24	6.6	1.63	0	0	< 10
8: RW RW2-Ripley RW-Well 3	27-Apr-26 12:47	6.6	---	0	0	---
9: RW RW3-Ripley RW-Well 4	27-Apr-26 12:39	6.6	---	0	0	---
10: TW TW2-Ripley TW-Elevated Tank	27-Apr-26 12:38	6.6	1.96	0	0	< 10
11: DW DW-Ripley SPS	27-Apr-26 12:09	6.6	1.42	0	0	< 10
12: DW DW-Firehall	27-Apr-26 12:19	6.6	1.61	0	0	< 10

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001


Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety