



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 220008863

22-January-2026

OCWA-Huron Kinloss (Whitechurch DWS)

Attn : Paul Sherban

Date Rec. : 13 January 2026
LR Report: CA30328-JAN26

6242 Fallon Drive
Lucan, ON
N0M 2J0, Canada

Copy: #1

Phone: 226-374-9901 (Paul)/226-377-3563 (Cindy Sigurdson)
Fax:

CERTIFICATE OF ANALYSIS Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Completed Date	4: Analysis Completed Time	5: MAC	6: Half MAC	7: MDL	8: TW TW-Whitechurch TW	9: DW DW-Whitechurch DW SS
Sample Date & Time								13-Jan-26 08:50	13-Jan-26 08:29
Temperature Upon Receipt [at London Lab °C]	---	---	---	---	---	---	---	3.1	3.1
Temperature Upon Receipt [at Lakefield Lab °C]	---	---	---	---	---	---	---	8.6	8.6
Field Free Chlorine [mg/L]	---	---	---	---	---	---	---	1.48	1.37
Barium [ug/L]	19-Jan-26	08:45	19-Jan-26	13:33	1000	500	0.02	826	---
Nitrite (as N) [mg/L]	17-Jan-26	11:48	19-Jan-26	11:44	1.0	---	0.003	0.003 <MDL	---
Nitrate (as N) [mg/L]	17-Jan-26	11:48	19-Jan-26	11:44	10	---	0.006	0.006 <MDL	---
Nitrate + Nitrite (as N) [mg/L]	17-Jan-26	11:48	19-Jan-26	11:44	---	---	0.006	0.006 <MDL	---
Trihalomethanes (total) [ug/L]	16-Jan-26	15:48	19-Jan-26	10:32	100 (RAA)	---	0.37	---	20
Bromodichloromethane [ug/L]	16-Jan-26	15:48	19-Jan-26	10:32	---	---	0.26	---	4.4
Bromoform [ug/L]	16-Jan-26	15:48	19-Jan-26	10:32	---	---	0.34	---	0.34 <MDL
Chloroform [ug/L]	16-Jan-26	15:48	19-Jan-26	10:32	---	---	0.29	---	14
Dibromochloromethane [ug/L]	16-Jan-26	15:48	19-Jan-26	10:32	---	---	0.37	---	0.81
Total Haloacetic Acids (HAA5) [ug/L]	20-Jan-26	08:27	22-Jan-26	12:26	80 (RAA)	---	5.3	---	11.4
Chloroacetic Acid [ug/L]	20-Jan-26	08:27	22-Jan-26	12:26	---	---	4.7	---	4.7 <MDL
Bromoacetic Acid [ug/L]	20-Jan-26	08:27	22-Jan-26	12:26	---	---	2.9	---	2.9 <MDL
Dichloroacetic Acid [ug/L]	20-Jan-26	08:27	22-Jan-26	12:26	---	---	2.6	---	4.7
Dibromoacetic Acid [ug/L]	20-Jan-26	08:27	22-Jan-26	12:26	---	---	2.0	---	2.0 <MDL
Trichloroacetic Acid [ug/L]	20-Jan-26	08:27	22-Jan-26	12:26	---	---	5.3	---	6.6

Online LIMS

0004398167

MAC - Maximum Acceptable Concentration
 Half MAC - Half of the Maximum Acceptable Concentration
 MDL - SGS Method Detection Limit

Method Descriptions

Parameter	Description	SGS Method Code
Barium	Barium by ICP-MS Drinking Water	ME-CA-[ENV]SPE-LAK-AN-006
Bromoacetic Acid	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Bromodichloromethane	VOC wtr - THM	ME-CA-[ENV]GC-LAK-AN-004
Bromoform	VOC wtr - THM	ME-CA-[ENV]GC-LAK-AN-004
Chloroacetic Acid	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Chloroform	VOC wtr - THM	ME-CA-[ENV]GC-LAK-AN-004
Dibromoacetic Acid	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Dibromochloromethane	VOC wtr - THM	ME-CA-[ENV]GC-LAK-AN-004
Dichloroacetic Acid	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Nitrate (as N)	Nitrate by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Nitrate + Nitrite (as N)	Total Nitrate/Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Nitrite (as N)	Nitrite by Ion Chromatography	ME-CA-[ENV]IC-LAK-AN-001
Total Haloacetic Acids (HAA5)	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Trichloroacetic Acid	HAA wtr - DW	ME-CA-[ENV]GC-LAK-AN-013
Trihalomethanes (total)	VOC wtr - THM	ME-CA-[ENV]GC-LAK-AN-004

*Hawley Anderson, Hon.B.Sc
 Project Specialist,
 Environment, Health & Safety*